
**Road vehicles — Degrees of protection
(IP code) — Protection of electrical
equipment against foreign objects,
water and access**

*Véhicules routiers — Degrés de protection (codes IP) — Protection des
équipements électriques contre les corps étrangers, l'eau et les contacts*



STANDARDSISO.COM : Click to view the full PDF of ISO 20653:2013



COPYRIGHT PROTECTED DOCUMENT

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Structure and meaning of the IP code	2
4.1 Structure of the IP code.....	2
4.2 Meaning of IP code.....	2
4.3 Examples for the use of letters in the IP code.....	3
5 Degrees of protection against foreign objects and against access	4
6 Degrees of protection against water	5
7 Designation examples	6
7.1 General.....	6
7.2 Example IP34K.....	6
7.3 Example IP16KB.....	6
7.4 Example IP2X/IP5KX.....	7
8 Requirements and testing	7
8.1 Atmospheric conditions.....	7
8.2 Device under test (DUT).....	7
8.3 Requirements and tests for degrees of protection against foreign objects and access.....	7
8.4 Requirements and test for degrees of protection against water.....	13
9 Notes on the assignment of degrees of protection	14
9.1 Assignment of degrees of protection against foreign objects and access.....	14
9.2 Assignment of degrees of protection against water.....	14
Bibliography	23

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 20653 was prepared by Technical Committee ISO/TC 22, *Road vehicles*, Subcommittee SC 3, *Electrical and electronic equipment*.

This second edition cancels and replaces the first edition (ISO 20653:2006), which has been technically revised.

STANDARDSISO.COM : Click to view the full PDF of ISO 20653:2013

Introduction

The IP codes used in this International Standard are in accordance with IEC 60529, except in the case of codes “K”, which describe special requirements for road vehicles that are not covered by IEC 60529.

STANDARDSISO.COM : Click to view the full PDF of ISO 20653:2013

STANDARDSISO.COM : Click to view the full PDF of ISO 20653:2013

Road vehicles — Degrees of protection (IP code) — Protection of electrical equipment against foreign objects, water and access

1 Scope

This International Standard applies to degrees of protection (IP code) provided by enclosures of the electrical equipment of road vehicles. It specifies the following:

- a) Designations and definitions of types and degrees of protection provided by enclosures of electrical equipment (IP codes) for the:
 - protection of electrical equipment within the enclosure against ingress of foreign objects, including dust (protection against foreign objects);
 - protection of persons against access to hazardous parts inside the enclosure (protection against access);
 - protection of electrical equipment inside the enclosure against effects due to ingress of water (protection against water).
- b) Requirements for each degree of protection.
- c) Tests to be carried out in order to confirm that the enclosure complies with requirements of the relevant degree of protection.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 12103-1, *Road vehicles — Test dust for filter evaluation — Part 1: Arizona test dust*

IEC 60068-2-68, *Environmental testing — Part 2: Tests — Test L: Dust and sand*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

enclosure

part providing protection of equipment against certain external influences and in any direction against access

3.2

degree of protection

protection provided by an enclosure against access, foreign objects and/or water and verified by standardized test methods

3.3
International Protection code
IP code

coding system to indicate the degree of protection provided by an enclosure against access, foreign objects and/or water and to give additional information in connection with such parts


3.4
hazardous part
part that is hazardous to approach or touch

3.5
opening
gap or aperture in an enclosure which exists or may be formed by the application of a test probe at the specified force

4 Structure and meaning of the IP code

4.1 Structure of the IP code

The structure of the IP code is as follows.



Where no code element is given, the letter “X” shall be substituted (or “XX”, if none of the two code elements have been indicated).

Additional and/or supplementary letters may be omitted without substitute.

Additional letters following each other directly shall be in alphabetical order.

Wherever the degree of protection of a part of the enclosure or the electrical equipment deviates from the degree of protection of the remaining part, both degrees of protection shall be indicated.

4.2 Meaning of IP code

Table 1 contains an overview of the IP code elements.

Table 1 — Overview of all IP code elements and meaning

Element	IP	Meaning for the protection of electrical equipment	Meaning for the protection of persons
First code element		Against foreign objects (including dust):	Against access:
	0	— not protected	— not protected
	1	— with diameter ≥ 50 mm	— with back of hand
	2	— with diameter $\geq 12,5$ mm	— with finger
	3	— with diameter $\geq 2,5$ mm	— with tool
	4	— with diameter $\geq 1,0$ mm	— with wire
	5K	— dust-protected	— with wire
	6K	— dust-tight	— with wire
Second code element		Against water:	Not applicable
	0	— not protected	
	1	— vertical water drips	
	2	— water drips (15° inclination)	
	3	— water spray	
	4	— splash water	
	4K	— splash water with increased pressure	
	5	— high-velocity water	
	6	— strong high-velocity water	
	6K	— strong high-velocity water with increased pressure	
	7	— temporary immersion	
	8	— continuous submersion	
	9K	— high-pressure/steam-jet cleaning	
Additional letter (optional)		Not applicable	Against access (unless described by first letter)
	A		— with back of hand
	B		— with finger
	C		— with tool
	D		— with wire
Supplementary letter (optional)	M	Movement of moveable parts during water test	Not applicable
	S	Standstill of moveable parts during water test	

4.3 Examples for the use of letters in the IP code

The following examples explain the use and arrangements of letters in the IP code. For more comprehensive examples, see Clause 7.

IP44	no letters, no options;
IPX5	omitting first code element;
IP2X	omitting second code element;
IP20C	using additional letter;
IPXXC	omitting both code elements, using additional letter;

IPX1C	omitting first code element, using additional letter;
IP3XD	omitting second code element, using additional letter;
IP23S	using supplementary letter;
IP21CM	using additional letter and supplementary letter;
IPX5/IPX7	giving two different degrees of protection by an enclosure against both water jets and temporary immersion for “versatile” application.

5 Degrees of protection against foreign objects and against access

Tables 2 and 3 contain short descriptions of the degrees of protection with the relevant requirements.

If the same degree of protection (identical code element) for protection against foreign objects and access is required, then both requirements are indicated by the first code element.

If different degrees of protection for both protection types are required, then an additional letter shall be used. In this case the first code element only defines the protection against foreign objects and the additional letter indicates the protection against access.

Additional letters may only be used if:

- the degree of protection against access is higher than indicated by the first code element, or
- only the degree of protection against access is to be indicated (first code element substituted by X).

The indication of a degree of protection against access and foreign objects always includes the preceding degrees of protection.

Table 2 — Degrees of protection against foreign objects

First code element	Degree of protection	
	Brief description	Requirements
0	not protected	None
1	foreign objects diameter ≥ 50 mm	Test probe with diameter 50 mm shall not penetrate completely.
2	foreign objects diameter $\geq 12,5$ mm	Test probe with diameter 12,5 mm shall not penetrate completely.
3	foreign objects diameter $\geq 2,5$ mm	Test probe with diameter 2,5 mm shall not penetrate completely.
4	foreign objects diameter $\geq 1,0$ mm	Test probe with diameter 1,0 mm shall not penetrate completely.
5K	dust	Dust shall only penetrate in quantities which do not impair performance and safety.
6K	dust	Dust shall not penetrate.
NOTE “Shall not penetrate completely” indicates that the full diameter shall not pass through an opening of the enclosure.		

Table 3 — Degrees of protection against access

First code element	Additional letter	Degree of protection	
		Brief description	Requirements
0	–	not protected	None
1	A	back of hand (no protection against intentional contact)	Test probe with diameter 50 mm shall not penetrate completely and maintain sufficient distance from hazardous parts.
2	B	finger	Jointed test finger with diameter 12 mm may penetrate completely, but shall maintain a sufficient distance from hazardous parts.
3	C	tool (e.g. screwdriver)	Test probe with diameter 2,5 mm, 100 mm long, may penetrate completely, but shall maintain a sufficient distance from hazardous parts.
4	D	wire	Test probe with diameter 1,0 mm, 100 mm long, may penetrate completely, but shall maintain a sufficient distance from hazardous parts.
5K	D	wire	
6K	D	wire	
NOTE “Shall not penetrate completely” indicates that the full diameter shall not pass through an opening of the enclosure.			

6 Degrees of protection against water

[Table 4](#) contains short descriptions of the degrees of protection with the relevant requirements.

Up to and including degree of protection 6K for the protection against water, the designation implies compliance also with the requirements for all lower degrees of protection.

For degrees of protection against water 7, 8 and 9K, lower degrees of protection up to and including 6K are not covered by the designation. In such cases where a lower degree of protection up to and including 6K is required in addition to protection against water 7, 8 or 9K, it shall be indicated separately, e.g. IPX4K/IPX7, IPX5/IPX7, IPX6K/IPX8 and IPX6K/IPX9K.

Table 4 — Degrees of protection against water

Second code element	Degree of protection	
	Brief description	Requirements
0	not protected	None
1	water drips vertically	Vertical drips shall not have any harmful effects or impair performance.
2	water drips with enclosure inclined by 15°	Vertical drips shall not have any harmful effects or impair performance when the enclosure is tilted at any angle up to 15° on either side of the vertical.
3	water spray	Water spray at an angle up to 60° on either side of the vertical shall have no harmful effects or impair performance.
4	splash water	Water which splashes against the enclosure from any direction shall not have any harmful effects or impair performance.
4K	splash water with increased pressure	Water which splashes against the enclosure from any direction with increased pressure shall not have any harmful effects or impair performance.
5	high-velocity water	Water which is directed against the enclosure from any direction as a jet shall not have any harmful effects or impair performance.

Table 4 (continued)

Second code element	Degree of protection	
	Brief description	Requirements
6	strong high-velocity water	Water which is directed against the enclosure from any direction as a strong jet shall not have any harmful effects or impair performance.
6K	strong high-velocity water with increased pressure	Water which is directed against the enclosure from any direction as a strong jet with increased pressure shall not have any harmful effects or impair performance.
7	temporary immersion in water	Water shall not penetrate in a quantity causing harmful effects or impair performance if the enclosure is immersed in water temporarily under specified pressure and time conditions.
8	continuous immersion in water	Water shall not penetrate in a quantity causing harmful effects if the enclosure is continuously immersed in water under conditions which shall be agreed between supplier and car manufacturer, but which are more severe than code 7.
9K	water during high-pressure/steam-jet cleaning	Water which is directed against the enclosure from any direction shall not have any harmful effects or impair performance.

7 Designation examples

7.1 General

The degree of protection shall be indicated using the IP code.

7.2 Example IP34K

The marking of an enclosure with the IP code IP34K means:

- (3) Protection of the electrical equipment access to the enclosure against foreign objects with a diameter of more than 2,5 mm (protection against foreign objects), and
protection of persons handling rods of 2,5 mm diameter or more against access within the enclosure (protection against access).
- (4K) Protection of electrical equipment within the enclosure against harmful effects resulting from water splashing against the enclosure with increased pressure from any direction (protection against water).

7.3 Example IP16KB

The marking of an enclosure with the IP code IP16KB means:

- (1) Protection of the electrical equipment within the enclosure against foreign objects with a diameter of more than 50 mm (protection against foreign objects).
- (6K) Protection of electrical equipment within the enclosure against harmful effects resulting from water directed against the enclosure from any direction as a strong jet with increased pressure (protection against water).
- (B) Protection of persons against finger contact with hazardous parts within the enclosure (protection against access).

7.4 Example IP2X/IP5KX

The designation

- IP2X for the complete enclosure, and
- IP5KX for the cover of a part inside the complete enclosure

means:

- (2) Protection of the electrical equipment within the complete enclosure against foreign objects with a diameter of more than 12,5 mm (protection against foreign objects), and
protection of persons against finger contact with hazardous parts within the complete enclosure (protection against access).
- (X) No statement on the degree of protection against water for the complete enclosure, and additionally
- (5K) protection of the part against harmful effects resulting from ingress of dust (protection against foreign objects), and
protection of persons handling wires of 1 mm diameter or more against contact with hazardous parts within the cover of this part (protection against access).
- (X) No statement on the degree of protection against ingress of water for the cover of this part.

NOTE 1 If all other parts are also not harmed by the penetrated dust, apart from protection against foreign objects degree 2, insensitivity to dust within the complete enclosure is also achieved.

NOTE 2 This higher degree of protection of the cover of the part located within the complete enclosure does not influence the complete enclosure surrounding it, whose lower degree of protection 2 applies.

8 Requirements and testing

8.1 Atmospheric conditions

Unless otherwise specified, tests shall be carried out under the following ambient atmospheric conditions:

- Temperature range: $(23 \pm 5) ^\circ\text{C}$;
- Relative humidity: 25 % to 75 %;
- Atmospheric pressure: 86 kPa to 106 kPa (860 mbar to 1 060 mbar).

8.2 Device under test (DUT)

Unless otherwise agreed, the DUT shall be unused and clean. Further specifications regarding DUT may be made.


8.3 Requirements and tests for degrees of protection against foreign objects and access

8.3.1 Test set-up

Probes for determining the degrees of protection against access and foreign objects are shown in [Table 5](#). If the guard and handle impede practical testing, the test shall be carried out with the rigid test sphere only.

A principle test set-up for determining degrees of protection against foreign objects 5K and 6K (dust-protected or dust-tight) with vertical flow of the air–dust mixture is depicted in [Figure 1](#). Alternatively, a principle dust chamber with horizontal dust flow (see [Figure 2](#)) can be agreed upon, based on IEC 60068-2-68.


Unless otherwise agreed, test dust A2 (Arizona dust) according to ISO 12103-1 shall be used. Where a dust chamber in accordance with [Figure 1](#) is used, approximately 2 kg of test dust per m³ chamber volume shall be filled in and kept in suspension during the test. Where dust chambers according to [Figure 2](#) are used, the density of the air-dust mixture shall be (5 ± 2) g/m³ and a flow rate of 1,5 m/s shall be maintained in accordance with IEC 60068-2-68 (unless otherwise agreed).



Key

- 1 DUT
- 2 glass window
- 3 dust
- 4 vibrator
- 5 protective grating
- 6 circulating pump or other equipment for suspending the dust

Figure 1 — Principle test set-up for determining the protection against dust in vertical orientation; degree of protection against foreign objects 5K and 6K

**Key**

- 1 pre-chamber
- 2 dust density controller (control unit)
- 3 test chamber
- 4 probe
- 5 DUT
- 6 laminar air flow
- 7 air baffles
- 8 test bench
- 9 protective grating
- 10 dust circulating pump (radial fan)
- 11 reservoir for test dust
- 12 solenoid valve (proportioning valve)
- 13 heating
- 14 collecting tank for test dust
- 15 air duct

Figure 2 — Principle test set-up for determining the degree of protection against dust in horizontal orientation; protection against foreign objects 5K and 6K

8.3.2 Requirements for tests using probes

The requirements for tests using the probes according to [Table 5](#) are specified in [Table 6](#).

Table 5 — Probes for the testing of degrees of protection against foreign objects and access

Degree of protection against access of foreign objects		Test probe designation and dimension
First code element	Additional letter	
1	A	Sphere diameter 50
		Dimensions in millimetres
		Key 1 handle (insulating material) 2 guard (insulating material) 3 rigid test sphere (metal)
—	B	Jointed test finger diameter 12; length 80
		Dimensions in millimetres
		Key 1 stop face (insulating material) 2 jointed test finger (metal)
		NOTE For structural details of the finger, refer to Figure 2 , test probe B in IEC 61032.

Table 5 (continued)

Degree of protection against access of foreign objects		Test probe designation and dimension
First code element	Additional letter	
2	-	Sphere diameter 12,5
		Dimensions in millimetres
		Key 1 handle (insulating material) 2 guard (insulating material) 3 rigid test sphere (metal)
3	C	Test rod diameter 2,5; length 100
		Dimensions in millimetres
		Key 1 handle (insulating material) 2 stop face (insulating material) 3 rigid test rod (metal) (edges free from burrs)

Table 5 (continued)


Degree of protection against access of foreign objects		Test probe designation and dimension
First code element	Additional letter	
4/5K/6K	D	Test rod diameter 1,0; length 100
		Dimensions in millimetres
		
		Key 1 handle (insulating material) 2 stop face (insulating material) 3 rigid test wire (metal) (edges free from burrs)

Table 6 — Test conditions and requirements for testing degrees of protection against foreign objects and access using probes

Degree of protection against foreign objects First code element	Degree of protection against access First code element or additional letter	Test force $N \pm 10\%$	Requirements
or			
0	0	–	None
–	1 or A	50	The sphere (diameter 50 mm) shall not penetrate fully through any openings and shall be sufficiently distant from hazardous parts.
1	–		The sphere (diameter 50 mm) shall not penetrate fully through any opening.
–	2 or B	10	The jointed test finger may penetrate over its full length of 80 mm but shall be sufficiently distant from hazardous parts, even when its joints are bent at any optional angle (up to 90° from its axis) and are brought into any possible position. The stop face (Ø50 mm × 20 mm) shall not pass through the opening.
2	–	30	The sphere (diameter 12,5 mm) shall not penetrate fully through any opening.
NOTE “Sufficiently distant from hazardous parts” has the following meaning in this context: The probes shall not contact hazardous parts while hazardous parts are being moved.			

Table 6 (continued)

Degree of protec- tion against foreign objects First code element	Degree of protec- tion against access First code element or additional letter	Test force N ± 10 %	Requirements
or			
-	C	3	The rigid test rod (diameter 2,5 mm, 100 mm long) may penetrate over its full length of 100 mm, but shall be sufficiently distant from hazardous parts in any possible angular position. The stop face (sphere Ø35 mm) shall not pass through the opening.
3			The rigid test rod (diameter 2,5 mm) shall not penetrate.
-	D	1	The rigid test wire (diameter 1,0 mm, 100 mm long) may penetrate over its full length of 100 mm, but shall be sufficiently distant from hazardous parts in any possible angular position. The stop face (sphere Ø35 mm) shall not pass through the opening.
4	4/5K/6K		The rigid test wire (diameter 1,0 mm) shall not penetrate.
NOTE “Sufficiently distant from hazardous parts” has the following meaning in this context: The probes shall not contact hazardous parts while hazardous parts are being moved.			

8.3.3 Requirements for testing with dust

8.3.3.1 Execution of the test for protection against ingress of dust

The enclosure to be tested shall be placed in the test chamber in its normal operating position, with all its shrouds, covers and open drain holes, and exposed to the following conditions:

a) Test chamber according to [Figure 1](#):

- 6 s movement of the air-dust mixture,
- 15 min break.

Unless otherwise agreed, 20 such cycles shall be performed.

b) Test chamber according to [Figure 2](#):

Subject to agreement: exposure time 0,5 h to 24 h and speed (0 to 3) min⁻¹.

8.3.3.2 Requirements

For requirements, refer to [Table 2](#), which generally stipulates successful completion of an agreed performance test for degree of protection against foreign objects 5K and 6K. In special cases, a permissible degree of dust or another test criterion may be agreed upon.

8.4 Requirements and test for degrees of protection against water

8.4.1 Test set-up

The test set-up and the special arrangement with reference to the DUT are illustrated in [Figures 3](#) to [7](#).

8.4.2 Execution of the tests for protection against ingress of water

The test conditions are specified in [Table 7](#).

8.4.3 Requirements

The requirements are contained in [Table 4](#), whereby the acceptable quantity of penetrated water or another test criterion (e.g. passing a performance test to be specified) shall be agreed.

The requirements are contained in [Table 4](#), whereby the test criteria, the acceptable harmful effects and impaired performance shall be agreed between customer and supplier.

NOTE Test criteria could be acceptable quantity of penetrated water, passing a specified performance test, no signs of corrosion after a specified time.


9 Notes on the assignment of degrees of protection

9.1 Assignment of degrees of protection against foreign objects and access

The decisive criterion is the type of design of the enclosure and the impact of foreign bodies to be expected during operation of the relevant vehicle at the mounting or attachment position.

9.2 Assignment of degrees of protection against water


For examples refer to [Table 8](#).



Key

- 1 adjustable water level
- 2 DUT
- 3 turntable / holder
- 4 holder
- a Hole pattern (sectional drawing).

Figure 3 — Test set-up for determining the protection against vertical water drips (drip apparatus); degrees of protection against water 1 and 2



Key

1 holes with diameter D

2 DUT

3 turntable / holder

4 counterweights

5 flow rate indicator and pressure gauge

$r = 200, 400, 600, 800$ or 1600 mm; select the smallest radius depending on the size of DUT.

$D = 0,4$ mm for tests regarding degrees of protection against water 3 and 4.

$D = 0,8$ mm for tests regarding degrees of protection against water 4K.

Speed of DUT from $(1 \text{ to } 3) \text{ r/min}$.

Figure 4 — Test set-up for determining the protection against splash water and water spray (swivel tube); degrees of protection against water 3, 4 and 4K




- 1 moveable cover
- 2 shower tube
- 3 hose
- 4 flow rate indicator and pressure gauge
- 5 stop-cock
- 6 DUT
- 7 counterweight
- 8 diameter of apertures

NOTE The shower tube contains 121 apertures with diameter 0,5 mm:

- 1 centre aperture,
- 2 inner circles (12 apertures at 30° pitch),
- 4 outer circles (24 openings at 15° pitch), and
- a moveable cover made from aluminium.

The shower tube shall be made from copper-zinc alloy (brass).

Figure 5 — Manual test set-up for determining the protection against splash water and water spray (shower tube); degrees of protection against water 3 and 4



$D = 6,3$ mm for tests regarding degrees of protection against water 5 and 6K.

$D = 12,5$ mm for tests regarding degree of protection against water 6.

Figure 6 — Nozzle for determining the protection against high-velocity water; degrees of protection against water 5, 6 and 6K