



CHIMNEYS, FIREPLACES AND VENTS 1972



\$1.25

Copyright © 1972

NATIONAL FIRE PROTECTION ASSOCIATION
International

60 Batterymarch Street, Boston, Mass. 02110

Official NFPA Definitions

Adopted Jan. 23, 1964; Revised Dec. 9, 1969. Where variances to these definitions are found, efforts to eliminate such conflicts are in process.

SHALL is intended to indicate requirements.

SHOULD is intended to indicate recommendations or that which is advised but not required.

APPROVED means acceptable to the authority having jurisdiction. The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment or materials nor does it approve or evaluate testing laboratories. In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of nationally recognized testing laboratories,* i.e., laboratories qualified and equipped to conduct the necessary tests, in a position to determine compliance with appropriate standards for the current production of listed items, and the satisfactory performance of such equipment or materials in actual usage.

*Among the laboratories nationally recognized by the authorities having jurisdiction in the United States and Canada are the Underwriters' Laboratories, Inc., the Factory Mutual Research Corp., the American Gas Association Laboratories, the Underwriters' Laboratories of Canada, the Canadian Standards Association Testing Laboratories, and the Canadian Gas Association Approvals Division.

LISTED: Equipment or materials included in a list published by a nationally recognized testing laboratory that maintains periodic inspection of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

LABELED: Equipment or materials to which has been attached a label, symbol or other identifying mark of a nationally recognized testing laboratory that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling is indicated compliance with nationally recognized standards or tests to determine suitable usage in a specified manner.

AUTHORITY HAVING JURISDICTION: The organization, office or individual responsible for "approving" equipment, an installation, or a procedure.

Statement on NFPA Procedures

This material has been developed in the interest of safety to life and property under the published procedures of the National Fire Protection Association. These procedures are designed to assure the appointment of technically competent Committees having balanced representation from those vitally interested and active in the areas with which the Committees are concerned. These procedures provide that all Committee recommendations shall be published prior to action on them by the Association itself and that following this publication these recommendations shall be presented for adoption to the Annual Meeting of the Association where anyone in attendance, member or not, may present his views. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or non-compliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

Copyright and Republishing Rights

This publication is copyrighted © by the National Fire Protection Association. Permission is granted to republish in full the material herein in laws, ordinances, regulations, administrative orders or similar documents issued by public authorities. All others desiring permission to reproduce this material in whole or in part shall consult the National Fire Protection Association.

Standard for Chimneys, Fireplaces, and Vents

NFPA No. 211 — 1972

This edition of NFPA No. 211, adopted by the Association in May, 1972, supersedes the edition of 1971. Changes in this edition from the 1971 edition are in: 20, 401, 402, 405, 501, 602, 1002A, 1003, 1007 (Table 1), 1007C, 1009B, 110, 1101A, 1101C, 1103A, 1103D, 1104, 1105A, 1106A and Appendix B.

The 1970 edition of this standard was approved by the American National Standards Institute under date of July 27, 1971 and designated ANSI A52.1. The 1972 edition is being submitted for similar approval. The ANSI designation and date of approval will be printed on the front cover of copies of this edition printed after approval has been received.

Origin and Development of No. 211

In 1906 the NFPA Committee on Chimneys and Flues presented its first report. In 1914, under the jurisdiction of the then Committee on Field Practice, recommendations on chimneys and flues were prepared as Chapter VII of the Field Practice Manual, presented in 1914 and adopted in 1915. In 1926 the Association adopted the Chimney Construction Ordinance of
(continued on page 211-2)

Committee on Chimneys and Heating Equipment

H. E. Kuhlman, *Chairman*,

Insurance Services Offices of Oklahoma, P.O. Box 559, Oklahoma City, Okla. 73101

Warren M. Apgar, *Secretary*,

Municipal Survey Service, Insurance Services Office,
180 Water St., New York, N. Y. 10038

Rixford A. Beals, National Oil Fuel
Institute

C. E. Blome, Gas Appliance Manufacturers Assn.

Lt. William Carpenter, Fire Marshals
Assn. of North America

J. J. Fannon, Insurance Services Office
of Maryland

Clifton P. Geisert, Insurance Services
Office of Illinois

C. Allen Ivey, Cerny & Ivey Associates

James MacDonald, Travelers Insurance
Company

David S. Martin, Underwriters' Laboratories
of Canada

Ernest R. Menold, Sheet Metal & Air
Conditioning Contractors' National
Association

Robert A. Scholl, Edison Electric In-
stitute

Earl A. Schollenberger, American In-
surance Association

Joseph F. Schulz, Incinerator Institute
of America

Fred W. Stanley, Building Officials and
Code Administrators Int'l, Inc.

Ross A. W. Switzer, Dept. of Public
Works, Ottawa, Ont., Canada

Herb Witte, Gas Vent Institute

R. H. Zelinske, Underwriters' Labora-
tories, Inc.

Alternates

Gaylon R. Claiborne, Building Officials
and Code Administrators Int'l, Inc.
(Alternate to Fred W. Stanley)

James Davidson, Jr., Edison Electric
Institute (Alternate to Robert A.
Scholl)

Robert D. Lynch, National Oil Fuel
Institute (Alternate to Rixford A.
Beals)

Dan Schwartz, Incinerator Institute of
America (Alternate to Joseph F.
Schulz)

Scope: To prepare fire protection standards on chimneys, fireplaces, heating appliance venting systems, incinerators, and similar heat producing or heat removal devices, including clearances between heat sources and combustible materials.

the National Board of Fire Underwriters. In 1944 the Association adopted Article XI of the 1943 Edition of the Building Code of the National Board of Fire Underwriters to supersede the former chimney ordinance. This action was taken by the Board of Directors in the name of the Association, on recommendation of the Committee on Field Practice.

In 1948 the subject of Chimneys and Flues was transferred to the Committee on Building Construction. In 1950 the Association adopted Article X of the 1949 National Building Code of the National Board of Fire Underwriters, to supersede the 1944 standard, upon recommendation of the Committee on Building Construction and action by the Board of Directors.

In 1955 the subject of chimneys and flues was transferred to the newly appointed Committee on Chimneys and Heating Equipment. The 1957 revision of No. 211 was to make the text consistent with the provisions on the same subject appearing in the National Building Code of the National Board of Fire Underwriters. Standard No. 211 was revised in 1961 and completely revised in 1964. The 1964 edition included requirements for chimney connectors which were previously covered in NFPA No. 212. This latter standard was withdrawn in 1964. Since 1964, revised editions of the standard have been adopted by the Association in 1966, 1968, 1970, 1971 and 1972. In 1969 new text was added to cover the subject of spark arresters which had been covered in NFPA Standard No. 213 but was withdrawn in 1969.

CONTENTS

<i>Section</i>	<i>Page</i>
10. General	211-3
20. Selection of Chimney or Vent	211-3
30. Spark Arresters	211-4
40. Draft	211-4
50. Termination (Height)	211-5
60. Factory-built Chimneys	211-5
70. Liners	211-5
80. Masonry Chimneys	211-5
90. Metal Chimneys (Smokestacks)	211-11
100. Chimney, Vent Connectors	211-17
110. Vents	211-24
120. Fireplaces	211-30
Appendix A	211-32
Appendix B	211-34
Appendix C	211-35
Appendix D	211-38

Standard for

Chimneys, Fireplaces, and Vents

NFPA No. 211 — 1972

10. GENERAL.

101. Introduction.

All fuel-burning appliances, including fireplaces, produce products of combustion (waste gases) when in use. These waste gases must be safely and completely expelled to the outside atmosphere.

The safe removal of these waste gases, the fire-safe construction and installation of chimneys, fireplaces, and venting systems for domestic, commercial, and industrial appliances are the primary concern of this Standard.

102. Scope and Purpose.

This edition of NFPA Standard No. 211 represents basic standards for chimneys, fireplaces, and venting systems, their safe installation and use. The Standard applies to residential as well as commercial, and industrial applications. Definitions relating to chimneys, fireplaces, and venting systems are contained in the Glossary of Terms, NFPA No. 97M1.

103. Combustible Material

Combustible material as pertaining to materials adjacent to or in contact with heat-producing appliances, chimneys, chimney connectors, vents, vent connectors, steam and hot water pipes, warm air ducts, grease ducts, and rubbish chutes means material made of or surfaced with wood, compressed paper, plant fibers, or other material that will ignite and burn. Such material shall be considered as combustible even though flameproofed, fire-retardant treated, or plastered.

20. SELECTION OF CHIMNEY OR VENT

201. Selection is dependent on the appliance connected thereto and the fuel used by the appliance. This standard gives minimum construction and installation requirements for chimneys and vents suitable for use with appliances classified as residential type, building heating, low, medium and high heat appliances. Appendix

A covers the selection of a chimney for various appliances. Appendix B covers the selection of a vent for certain appliances listed as suitable for use with such vents.

30. SPARK ARRESTERS.

301. The net free area of the arrester shall be not less than four times the net free area of the outlet of the chimney flue it serves.

302. Arresters shall have a vertical height of not less than 1.3 times the minimum diameter of the chimney flue or the minimum horizontal dimension of rectangular chimney flue.

303. Arresters, including bolts, rivets, screws and supporting members, shall be made of stainless steel (ASTM A167, Type 316, or ASTM A478, Type 316, or the equivalent).

304. Openings shall not permit the passage of spheres having a diameter larger than one-half inch, nor block the passage of spheres having a diameter of less than three-eighths inch.

305. Means shall be provided for securely attaching the spark arresters to chimneys to provide adequate support and prevent movement of the arrester.

40. DRAFT

401. A chimney or vent shall be capable of producing a draft at the appliance not less than that required for safe operation of the appliance(s) connected thereto.

402. A mechanical draft system of either forced or induced draft design may be used to increase draft or capacity. When a mechanical draft system is installed, provision shall be made to prevent the flow of fuel to the appliance(s) when that system is not operating.

403. Chimneys serving incinerators, or other process equipment where the combustion process cannot be completely stopped by fuel shutoff alone, shall be sized for natural draft conditions. When air pollution control devices, or other devices, in the chimney system require a mechanical draft system, the chimney system shall be so arranged that upon a power failure the natural draft chimney alone can satisfactorily remove the products of combustion until the combustible material is completely consumed.

404. Forced draft systems and all portions of induced draft systems under positive pressure during operation shall be designed and installed so as to be gastight or as to prevent leakage of combustion products into a building.

405. Natural draft chimneys or vents shall not terminate at an elevation less than 5 ft. above the flue collar or highest connected draft hood outlet except as provided in 1106.

50. TERMINATION (HEIGHT).

501. Chimneys and vents shall terminate above the roof level in accordance with the requirements of this Standard, except as provided in 902A2, 1103E, and 1106. See also Appendix D.

60. FACTORY-BUILT CHIMNEYS AND CHIMNEY UNITS.

601. Factory-built chimneys and chimney units shall be listed and shall be installed in accordance with the conditions of the listing and the manufacturer's instructions.

602. Factory-built chimneys which pass through floors of buildings requiring the protection of vertical openings shall be enclosed with approved walls having a fire resistance rating of not less than 1 hour when such chimneys are located in a building less than 4 stories in height, and not less than 2 hours when such chimneys are located in a building 4 stories or more in height.

70. LINERS.

701. When lining chimneys or connectors, castable or plastic refractories may be used instead of firebrick provided such refractory is equivalent, in its resistance to heat and erosion by fuel gases, to that of the firebrick which would otherwise have been specified. Liners made of castable or plastic refractories shall be secured to the supporting walls by anchors made of corrosion resistant steel capable of supporting the refractory load at 1500 F.

80. MASONRY CHIMNEYS.

801. General Requirements.

A. Support. Masonry chimneys shall be supported on properly designed foundations of masonry or reinforced portland or refractory cement concrete, or on noncombustible material having a

fire-resistance rating of not less than 3 hours provided such supports are independent of the building construction and the load is transferred to the ground.

B. Corbeling. No masonry chimneys shall be corbeled from a wall more than 6 inches, nor shall a chimney be corbeled from a wall which is less than 12 inches in thickness unless it projects equally on each side of the wall provided that in the second story of 2-story dwellings corbeling of chimneys on the exterior of the enclosing walls may equal the wall thickness. Corbeling shall not exceed one inch projection for each course of brick projected.

C. Change in size or shape at roof not permitted. No change in the size or shape of a chimney flue where the chimney passes through the roof, shall be made within a distance of 6 inches above or below the roof joists or rafters.

D. Cleanout openings. Cleanout openings provided in chimneys shall be equipped with ferrous metal doors and frames arranged to remain tightly closed when not in use. Adequate clearance between cleanout doors and combustible material shall be provided.

E. Firestopping. All spaces between chimneys and floors and ceilings through which chimneys may pass shall be firestopped with noncombustible material. The firestopping of spaces between chimneys and wood joists, beams, or headers shall be to a depth of one inch only placed on strips of metal or metal lath laid across the spaces between combustible material and the chimney.

F. Smoke test. Masonry chimneys shall be proved tight by a smoke test after erection and before being put into use.

802. Masonry Chimneys for Residential Type Appliances (See Appendix A).

A. Construction.

1. Masonry chimneys for residential-type appliances shall be constructed of solid masonry units or reinforced portland or refractory cement concrete with walls not less than 4 inches thick or rubble stone masonry not less than 12 inches thick. Masonry shall be laid with full, push-filled, cross and bed, mortar joints.

2. Masonry chimneys for residential-type appliances shall be lined with fire-clay flue lining (ASTM C315) or the equivalent not less than $\frac{5}{8}$ of an inch thick, or with liner of other approved material that will resist corrosion, softening or cracking from flue gases at temperatures up to 1800 F.

3. Fire-clay flue liner shall be installed ahead of the construction of the chimney as it is carried up, carefully bedded one on the other in refractory mortar (ASTM C105, medium duty) or the equivalent, with close fitting joints left smooth on the inside.

4. Liners shall be separate from the chimney wall and the space between the liner and masonry shall not be filled; only enough mortar shall be used to make a good joint and hold the liners in position.

5. Flue liners shall start from a point not less than 8 inches below the intake. They shall extend, as nearly vertically as possible, for the entire height of the chimney.

6. Where two adjoining flues in the same chimney are separated only by flue liners the joints of the adjacent flue liners shall be staggered at least 7 inches.

7. Where more than two flues are located in the same chimney, masonry wythes (partitions) at least 4 inches wide and bonded into the masonry walls of the chimney shall be built at such points between adjacent flue linings that there are not more than two flues in any group of adjoining flues without such wythe separation.

B. Termination (height). Masonry chimneys for residential type appliances shall extend at least 3 feet above the highest point where they pass through the roof of a building and at least 2 feet higher than any portion of a building within 10 feet. See Appendix D.

C. Clearance from combustible material.

1. All wood beams, joists and studs shall be trimmed away from chimneys. Headers, beams, joists and studs shall be not less than 2 inches from the outside face of a chimney or from masonry enclosing a flue. Ends of wood girders may be supported on a corbeled shelf of a masonry chimney provided there is not less than 8 inches of solid masonry between the ends and the flue liner.

2. Combustible lathing, furring, or plaster grounds shall not be placed against a chimney at any point more than $1\frac{1}{2}$ inches from the corner of the chimney, but this shall not prevent plastering directly on the masonry or on metal lath and metal furring, nor shall it prevent placing chimneys for residential type appliances entirely on the exterior of a building against the sheathing.

803. Masonry Chimneys for Low Heat Appliances.

A. Construction.

1. Masonry chimneys for low-heat appliances shall be constructed of solid masonry units or reinforced portland or refractory cement concrete with walls not less than 8 inches thick or rubble stone masonry not less than 12 inches thick. Masonry shall be laid with full, push-filled, cross and bed, mortar joints.

2. Masonry chimneys for low heat appliances shall be lined with fire-clay flue lining (ASTM C315), or the equivalent, not less than $\frac{5}{8}$ of an inch thick, or with liner of other approved material that will resist erosion, softening or cracking from flue gases at temperatures up to 1800 F.

3. Fire-clay flue liners shall be installed ahead of the construction of the chimney as it is carried up, carefully bedded one on the other in refractory mortar (ASTM C105, medium duty) or the equivalent, with close fitting joints left smooth on the inside.

4. Flue liners shall start from a point not less than 8 inches below the intake. They shall extend, as nearly vertically as possible, for the entire height of the chimney.

5. Where two adjoining flues in the same chimney are separated only by flue liners, the joints of the adjacent flue liners shall be staggered at least 7 inches.

6. Where more than two flues are located in the same chimney, masonry wythes (partitions) at least 4 inches wide and bonded into the masonry walls of the chimney shall be built at such points between adjacent flue linings that there are not more than two flues in any group of adjoining flues without such wythe separation.

B. Termination (height). Masonry chimneys for low-heat appliances shall extend at least 3 feet above the highest point where they pass through the roof of a building and at least 2 feet higher than any portion of a building within 10 feet. See Appendix D.

C. Clearance from combustible material.

1. All wood beams, joists and studs shall be trimmed away from chimneys. Headers, beams, joists and studs shall be not less than 2 inches from the outside face of a chimney or from masonry enclosing a flue.

2. Combustible lathing, furring, or plaster grounds shall not be placed against a chimney at any point more than 1½ inches from the corner of the chimney, but this shall not prevent plastering directly on the masonry or on metal lath and metal furring, nor shall it prevent placing chimneys for low heat appliances entirely on the exterior of a building against the sheathing.

804. Masonry Chimneys for Medium Heat Appliances.

A. Construction. Masonry chimneys for medium heat appliances shall be constructed of solid masonry units or of reinforced portland or refractory cement concrete with walls not less than 8 inches thick or with stone masonry not less than 12 inches thick. Such chimneys shall be lined with medium-duty fire brick (ASTM C106 Type F) or the equivalent, not less than 4½ inches thick laid on the 4½ inch bed in refractory mortar (ASTM C105 medium duty) or the equivalent. The lining shall start 2 feet or more below the lowest chimney connector entrance and shall extend to a height of at least 25 feet above the highest chimney connector entrance. Chimneys terminating 25 feet or less above a chimney connector entrance shall be lined to the top.

B. Termination (height). Masonry chimneys for medium heat appliances shall extend not less than 10 feet higher than any portion of any building within 25 feet.

C. Clearance From Combustible Material. A clearance of not less than 4 inches shall be provided between the exterior surfaces of a masonry chimney for medium heat appliances and combustible material.

805. Masonry Chimneys for High Heat Appliances.

A. Construction. Masonry chimneys for high heat appliances shall be constructed with double walls of solid masonry units or reinforced portland or refractory cement concrete, each wall to be not less than 8 inches thick with an air space of not less than 2 inches between them. The inside of the interior wall shall be lined

with high duty fire brick (ASTM C106 Type A) or the equivalent, not less than $4\frac{1}{2}$ inches thick laid on the $4\frac{1}{2}$ inch bed in refractory mortar (ASTM C105, high duty) or the equivalent. The lining shall start at the base of the chimney and extend continuously to the top.

B. Termination (height). Masonry chimneys for high heat appliances shall extend not less than 20 feet higher than any portion of any building within 50 feet.

C. Clearance from combustible material. Masonry chimneys for high heat appliances shall have sufficient clearance from buildings and structures to avoid overheating combustible material, to permit inspection, maintenance operations on the chimney and to avoid danger of burns to persons. Clearances shall be based on good engineering practice and acceptable to the authority having jurisdiction.

806. Masonry Chimneys for Incinerators.

A. Residential. Masonry chimneys for residential type incinerators shall be constructed in accordance with the requirements for Chimneys for Residential Type Appliances, 802.

B. Chute-Fed and Flue-Fed Incinerators. See Standard for Incinerators and Rubbish Handling, NFPA No. 82.

C. Commercial and industrial type incinerators.

1. Construction.

a. Masonry chimneys for commercial and industrial incinerators shall be constructed of solid masonry units or reinforced portland or refractory cement concrete with walls not less than 8 inches thick and lined with medium duty fire brick (ASTM C106, Type F) or the equivalent, not less than $4\frac{1}{2}$ inches thick laid on the $4\frac{1}{2}$ inch bed in refractory mortar (ASTM C105, medium duty) or the equivalent. The lining shall start at the base of the chimney and extend continuously to the top.

b. Masonry chimneys for commercial and industrial incinerators shall be supported on properly designed foundations of masonry or reinforced portland or refractory cement concrete or on noncombustible material having a fire-resistance rating of not less than 3 hours provided such supports are independent of the building construction and the load is transferred to the ground. Chimneys may be supported on incinerator walls if the incinerator foundation and walls are built to support the load thus imposed. They shall be so constructed as not to place excessive stress upon the roof of the combustion chamber.

2. Termination (height). Masonry chimneys for commercial and industrial incinerators shall extend not less than 10 feet higher than any portion of any building within 25 feet. The terminus of the chimney flue for the incinerator shall be equipped with an approved spark arrester if the incinerator does not include effective means for arresting sparks and fly ash. See Section 30.

3. Clearances. A clearance of not less than 4 inches shall be provided between the exterior surface of masonry chimneys for commercial and industrial-type incinerators and combustible materials.

90. METAL CHIMNEYS (Smokestacks).

901. General Requirements.

A. Single wall metal chimneys shall not be used inside 1- and 2-family dwellings.

B. Metal chimneys shall be constructed of steel or cast iron. Sheet steel shall have a thickness not less than that indicated in the following table. Metal chimneys shall be properly riveted or welded, securely supported and constructed in accordance with good engineering practice.

Mfrs. Std. Gage No.	Area (Sq. In.)
16	Up to 154
14	154 to 201
12	201 to 254
10	Larger than 254

C. Metal chimneys shall not be carried up inside of ventilating ducts unless such ducts are constructed and installed as required by this standard for chimneys and the ventilating ducts are used solely for exhaust of air from the room or space in which the appliance served by the metal chimney is located.

D. Metal chimneys shall have sufficient clearance from buildings and structures to avoid overheating combustible material, to permit inspection and maintenance operations on the chimney, and to avoid danger of burns to persons.

E. Metal chimneys shall be supported on properly designed foundations of masonry or reinforced portland or refractory cement

concrete or on non-combustible material having a fire-resistance rating of not less than 3 hours provided such supports are independent of the building construction and the load is transferred to the ground.

A factory built chimney, if so listed, and a metal chimney may be supported also at intervals by the building structure, in which case, expansion joints shall be provided at each support level. All joints shall be liquid tight or of a design such that liquid will drain to the interior of the chimney.

902. Metal Chimneys for Residential Type or Low Heat Appliances.

A. Termination (height).

1. Metal chimneys for residential type or low heat appliances except as provided in 902.A.2, shall extend at least 3 feet above the highest point where they pass through the roof of a building and at least 2 feet higher than any portion of a building within 10 feet. See Appendix D.

2. The outlet of a metal chimney for residential type and low-heat appliances equipped with an exhauster may terminate at a location not less than 3 feet from an adjacent building or building opening and at least 10 feet above grade or walkways. In any case, the outlet shall be so arranged that the flue gases are not directed so as to jeopardize people, overheat combustible structures, or enter building openings in the vicinity of the outlet.

B. Clearances.

1. Exterior.

a. Exterior metal chimneys used only for residential type or low heat appliances as defined in Appendix A shall have a clearance of not less than 6 inches from a wall of wood frame construction and from any combustible material.

b. Exterior metal chimneys over 18 inches in diameter shall have a clearance of not less than 4 inches, and those 18 inches or less in diameter a clearance of not less than 2 inches from a building wall of other than wood frame construction.

c. A metal chimney erected on the exterior of a building shall not be installed nearer than 24 inches to any door or window or to any walkway, unless insulated or shielded in an approved manner to avoid burning a person who might touch the chimney.

2. Interior.

a. Where a metal chimney extends through any story of a building above that in which the appliances connected to the chimney are installed, it shall be enclosed in such upper stories, within a continuous enclosure constructed of materials which are not combustible, such as masonry (see 103), and extending from the ceiling of the appliance room to or through the roof so as to maintain the integrity of the fire separations required by the applicable building code provisions. The enclosure walls shall have a fire resistance rating of not less than 1 hour if the building is less than 4 stories in height and not less than 2 hours if the building is 4 stories or more in height.

b. The enclosure shall provide a space on all sides of the chimney sufficient to permit inspection and repair, but in no case shall it be less than 12 inches.

c. The enclosing walls shall be without openings, except doorways equipped with approved self-closing fire doors at various floor levels for inspection purposes.

d. Where a metal chimney used for residential type or low heat appliances as defined in Appendix A is located in the same story of a building as that in which the appliances connected thereto are located, it shall have a clearance of not less than 18 inches from a wall of wood frame construction and from any combustible material. Such interior metal chimneys over 18 inches in diameter shall have a clearance of not less than 4 inches, and those 18 inches or less in diameter a clearance of not less than 2 inches from a building wall of other than wood frame construction.

e. Where a metal chimney serving only residential type or low heat appliances as defined in Appendix A passes through a roof constructed of combustible material, it shall be guarded by a ventilating thimble of galvanized iron or approved corrosion resistant metal, extending not less than 9 inches below and 9 inches above the roof construction, and of a size to provide not less than 6 inches clearance on all sides of the chimney; or the combustible material in the roof construction shall be cut away so as to provide not less than 18 inches clearance on all sides of the chimney, with any material used to close up such opening entirely noncombustible.

903. Metal Chimneys for Medium Heat Appliances.

A. **Construction.** Metal chimneys for medium heat appliances as defined in Appendix A, and producing flue gases having a

temperature above 1000 F, measured at the entrance to the chimney shall be lined with medium duty fire brick (ASTM C106, Type F) or the equivalent laid in fire clay mortar (ASTM C105, medium duty) or the equivalent. The lining shall be at least 2½ inches thick for chimneys having a diameter or greatest cross-section dimension of 18 inches or less and shall have a thickness of not less than 4½ inches laid on the 4½-inch bed for chimneys having a diameter or greatest cross-section dimension greater than 18 inches. The lining shall start 2 feet or more below the lowest chimney connector entrance and shall extend to a height of at least 25 feet above the highest chimney connector entrance. Chimneys terminating 25 feet or less above a chimney connector entrance shall be lined to the top.

B. Termination (height). Metal chimneys for medium heat appliances shall extend not less than 10 feet higher than any portion of any building within 25 feet.

C. Clearances.

1. Exterior.

a. Exterior metal chimneys used for medium heat appliances as defined in Appendix A shall have a clearance of not less than 24 inches from a wall of wood frame construction and from any combustible material.

b. Exterior metal chimneys over 18 inches in diameter shall have a clearance of not less than 4 inches, and those 18 inches or less in diameter a clearance of not less than 2 inches from a building wall of other than wood frame construction.

c. A metal chimney erected on the exterior of a building shall not be installed nearer than 24 inches to any door or window or to any walkway, unless insulated or shielded in an approved manner to avoid burning a person who might touch the chimney.

2. Interior.

a. Where a metal chimney extends through any story of a building above that in which the appliances connected to the chimney are installed, it shall be enclosed in such upper stories, within a continuous enclosure constructed of materials which are not combustible, such as masonry (see 103), and extending from the ceiling of the appliance room to or through the roof so as to maintain the integrity of the fire separations required by the applicable building code provisions. The enclosure walls shall have a fire

resistance rating of not less than 1 hour if the building is less than 4 stories in height and not less than 2 hours if the building is 4 stories or more in height.

b. The enclosing walls shall provide a space on all sides of the chimney to permit inspection and repair, but in no case shall it be less than 12 inches.

c. The enclosing walls shall be without openings, except doorways equipped with approved self-closing fire doors at various floor levels for inspection purposes.

d. Where a metal chimney serving a medium heat appliance as defined in Appendix A passes through a roof constructed of combustible material, it shall be guarded by a ventilating thimble of galvanized iron or approved corrosion resistant metal, extending not less than 9 inches below and 9 inches above the roof construction, and of a size to provide not less than 18 inches clearance on all sides of the chimney.

e. Where a metal chimney used for medium heat appliances as defined in Appendix A is located in the same story of a building as that in which the appliances connected are located, it shall have a clearance of not less than 36 inches from a wall of wood frame construction and from any combustible material. Such interior metal chimneys over 18 inches in diameter shall have a clearance of not less than 4 inches, and those 18 inches or less in diameter a clearance of not less than 2 inches from a building wall of other than wood frame construction.

904. Metal Chimneys for High Heat Appliances.

A. Construction. Metal chimneys for high heat appliances as defined in Appendix A shall be lined with high duty fire brick (ASTM C106, Type A) or the equivalent, not less than $4\frac{1}{2}$ inches thick laid on the $4\frac{1}{2}$ inch bed in refractory mortar (ASTM C105, high duty) or the equivalent. The lining shall start 2 feet or more below the lowest chimney connector entrance and shall extend to a height of at least 25 feet above the highest chimney connector entrance. Chimneys terminating 25 feet or less above a chimney connector entrance shall be lined to the top.

B. Termination (height). Metal chimneys for high heat appliances shall extend not less than 20 feet higher than any portion of any building within 50 feet.

C. Clearance from combustible material. Metal chimneys for high heat appliances shall have sufficient clearance from buildings and structures to avoid overheating combustible material, to permit inspection, maintenance operations on the chimney and to avoid danger of burns to persons. Clearances shall be based on good engineering practice and acceptable to the authority having jurisdiction.

905. Metal Chimneys for Incinerators.

A. Residential-Type Incinerators. Galvanized steel pipe not less than No. 20 galvanized-sheet gage number or other equivalent non-combustible, fire- and corrosion-resistant material may be used for residential-type incinerators installed in locations such as open sheds, breezeways, or carports provided the pipe is exposed and readily examinable for its full length and clearance not less than 18 inches is maintained from combustible material. The pipe shall extend at least 3 feet above the highest point where it passes by or through a roof and at least 2 feet higher than any portion of a building within 10 feet. If the pipe passes through a roof constructed of combustible material, it shall be guarded by a ventilating thimble of galvanized steel or approved corrosion-resistant noncombustible material extending not less than 9 inches below and 9 inches above the roof construction, and of a size to provide not less than 6-inch clearance on all sides of the pipe; or the combustible material in the roof construction shall be cut away so as to provide not less than 18-inch clearance on all sides of the pipe, with any material used to close up such opening entirely noncombustible.

B. Commercial and industrial type incinerators.

1. Construction.

Metal chimneys for commercial and industrial-type incinerators shall be lined with medium duty fire brick (ASTM C106, Type F, or the equivalent), not less than 4½ inches thick laid on the 4½-inch bed in refractory mortar (ASTM C105, medium duty), or the equivalent. The lining shall start at the base of the chimney and extend continuously to the top.

2. Termination (height). Metal chimneys for commercial and industrial incinerators shall extend not less than 10 feet higher than any portion of any building within 25 feet. The terminus of the chimney flue for the incinerator shall be equipped with an ap-

proved spark arrester if the incinerator does not include effective means for arresting sparks and fly ash (see Section 30).

3. Clearance. Metal chimneys for commercial and industrial incinerators shall be installed to provide clearances as specified in 903C for metal chimneys for medium heat appliances.

100. CHIMNEY CONNECTOR AND VENT CONNECTORS.

1001. Connectors Required.

Connectors shall be used to connect appliances to the vertical chimney or vent unless the chimney or vent is attached directly to the appliance.

1002. Materials.

A. Connectors shall be made of noncombustible corrosion resistant material such as steel or refractory masonry capable of withstanding the flue gas temperatures produced by the appliances and of sufficient thickness to withstand physical damage. Connectors for appliances installed in attics shall be of Type B or Type L vent material for listed gas appliances with draft hoods or of Type L vent material for oil appliances listed as suitable for Type L vents. For other appliances allowed in attics, a chimney shall be attached directly to the appliance.

When selecting the gage of metal for single wall metal pipe connectors of residential type and low heat appliances not installed in attics, consideration should be given to factors such as location, maintenance, use, etc., as well as engineering design factors. As a guide the following are gages of galvanized steel for given diameter connectors, except as provided in Paragraphs B, C and D below.

Galvanized Sheet Gage No.	Diameter of Connector, Inches
24	10 or less
22	10 to 12
20	14 to 16
16	16

B. Metal connectors for medium heat appliances and commercial and industrial incinerators shall be constructed of steel not lighter than that designated for metal chimneys in 901.B. In addition a connector for a medium heat appliance exhausting flue gases at a temperature in excess of 1000 F measured at the entrance to the connector, and a connector for a commercial or industrial incinerator shall be lined with medium duty fire brick (ASTM C106, Type F) laid in fire clay mortar (ASTM C105, medium duty) or the equivalent. The lining shall be at least 2½ inches thick for

connectors having a diameter or greatest cross-section dimension of 18 inches or less, and not less than $4\frac{1}{2}$ inches thick laid on the $4\frac{1}{2}$ -inch bed for connectors having a diameter or greatest cross-section dimension greater than 18 inches. Connections may consist of listed medium-heat chimney sections if the sections are joined together with continuous welds, flanges, or couplings.

C. Metal connectors for high heat appliances shall be made of steel not lighter than that designated for chimneys in 901B. In addition they shall be lined with high duty fire brick (ASTM C106, Type A) or the equivalent having a thickness of not less than $4\frac{1}{2}$ inches laid on the $4\frac{1}{2}$ -inch bed in fire clay mortar (ASTM C105, high duty) or the equivalent.

D. Masonry connectors or breeching shall be made of refractory material equivalent in resistance to heat and corrosion to high duty fire brick (ASTM C106, Type A) not less than $4\frac{1}{2}$ inches thick.

E. Connectors used for gas appliances having draft hoods and for listed conversion-burner-equipped appliances having draft hoods may be constructed of materials having resistance to corrosion and heat not less than that of No. 28 gage galvanized steel, or they may be of Type B or Type L vent material.

F. Connectors made of Type L vent material may be used with gas, oil and solid fuel-burning residential-type appliances including residential-type incinerators.

1003. Length.

A connector shall be as short and straight as possible. The appliance shall be located as close as practicable to the chimney or vent. The horizontal run of an uninsulated connector to a natural draft chimney, or vent, serving a single appliance, shall be not more than 75 percent of the height of the vertical portion of the chimney or vent above the connector, unless part of an engineered venting system.

The horizontal run of an insulated connector to a natural draft chimney, or vent, serving a single gas or liquid fuel fired appliance shall be not more than 100 percent of the height of the vertical portion of the chimney or vent above the connector, unless part of an engineered venting system. The horizontal length, design, and construction of combined connectors, or connectors to a manifold joining two or more appliances to a chimney or vent shall be determined in accordance with approved engineering methods.

1004. Size.

The connector, for its entire length, shall be sized in accordance

with approved engineering methods. As an alternate, the effective area of a connector for a single appliance shall be not less than the area of the appliance flue collar and a connector or manifold serving two or more appliances shall have an effective area equivalent to the combined areas of the appliance flue collars or individual connectors. Linings, if used, shall not reduce the required effective area of the connector.

1005. Clearance.

Clearances from combustible material shall be in accordance with Table 1.

1006. Location.

When the connector used for a gas appliance having a draft hood must be located in or pass through a crawl space or other cold area, that portion of the connector shall be of listed Type B or Type L vent material or be provided with equivalent means of insulation.

1007. Installation.

A. A connector to a masonry chimney shall extend through the wall to the inner face or liner but not beyond, and shall be firmly cemented to masonry. A thimble may be used to facilitate removal of the chimney connector for cleaning, in which case the thimble shall be permanently cemented in place with high-temperature cement.

TABLE 1
Chimney Connector and Vent Connector Clearances
from Combustible Materials

Description of Appliance	Minimum Clearance, Inches (See Note 1)
RESIDENTIAL TYPE APPLIANCES	
<i>Column 1, Appendix A</i>	
Single-Wall Metal Pipe Connectors	
Gas Appliances Without Draft Hoods	18
Electric, Gas, and Oil Incinerators	18
Oil and Solid-Fuel Appliances	18
Unlisted Gas Appliances With Draft Hoods	9
Boilers and Furnaces Equipped With Listed Gas Burners and With Draft Hoods	9
Oil Appliances Listed as Suitable For Use With Type L Vents, but only when connected to chimneys.	9
Listed Gas Appliances With Draft Hoods. See Note 3.	6

Description of Appliance	Minimum Clearance, Inches (See Note 1)
Type L Vent Piping Connectors	
Gas Appliances Without Draft Hoods	9
Electric, Gas, and Oil Incinerators	9
Oil and Solid-Fuel Appliances	9
Unlisted Gas Appliances With Draft Hoods	6
Boilers and Furnaces Equipped With Listed Gas Burners and With Draft Hoods	6
Oil Appliances Listed As Suitable For Use With Type L Vents	(See Note 2)
Listed Gas Appliances With Draft Hoods <i>Column 1, Appendix B</i>	(See Note 3)
Type B Gas Vent Piping Connectors	
Listed Gas Appliances With Draft Hoods	(See Note 3)

COMMERCIAL-INDUSTRIAL TYPE APPLIANCES

Low-Heat Appliances	
<i>Column 2, Appendix A</i>	
Single-Wall Metal Pipe Connectors	
Gas, Oil, and Solid-Fuel Boilers, Furnaces, and Water Heaters	18
Ranges, Restaurant Type	18
Oil Unit Heaters	18
Unlisted Gas Unit Heaters	18
Listed Gas Unit Heaters With Draft Hoods	6
Other Low-Heat Industrial Appliances	18
Medium-Heat Appliances	
<i>Column 3, Appendix A</i>	
Single-Wall Metal Pipe Connectors	
All Gas, Oil, and Solid-Fuel Appliances	36

NOTE 1: These clearances apply except if the listing of an appliance specifies different clearance, in which case the listed clearance takes precedence.

NOTE 2: If listed Type L vent piping is used, the clearance may be in accordance with the vent listing.

NOTE 3: If listed Type B or Type L vent piping is used, the clearance may be in accordance with the vent listing.

The clearances from connectors to combustible materials may be reduced if the combustible material is protected in accordance with Table 2.

TABLE 2.

Clearances, Inches, With Specified Forms of Protection.*

Type of Protection. Applied to the combustible material and covering all surfaces within the distance specified as the required clearance with no protection. (See Fig. 1). Thicknesses are minimum.	Where the required Clearance with no protection is:			
	36 inches	18 inches	9 inches	6 inches
(a) ¼ in. asbestos millboard spaced out 1 in.†	30	12	6	3
(b) 28 gage sheet metal on ¼ in. asbestos millboard	24	12	4	2
(c) 28 gage sheet metal spaced out 1 in.†	18	9	4	2
(d) 28 gage sheet metal on ⅛ in. asbestos millboard spaced out 1 in.†	18	9	4	2
(e) ¼ in. asbestos millboard on 1 in. mineral wool bats reinforced with wire mesh or equivalent ..	18	6	4	2
(f) 22 gage sheet metal on 1 in. mineral wool bats reinforced with wire or equivalent	12	3	2	2

*All clearances shall be measured from the outer surface of the connector to the combustible material disregarding any intervening protection applied to the combustible material but in no case shall the clearance be such as to interfere with the requirements for accessibility.

†Spacers shall be of noncombustible material.

B. A chimney connector or vent connector, shall not pass through any floor or ceiling, nor through a fire wall or fire partition.

C. Connectors for listed gas appliances with draft hoods (Appendix B, Column I) and oil appliances listed for Type L vents (Appendix B, Column III) may pass through walls or partitions constructed of combustible material if:

1. Made of listed Type B or Type L vent material for gas appliances, listed Type L vent material for oil appliances, and installed with not less than listed clearances to combustible material.

2. Made of single wall metal pipe and guarded by a ventilated metal thimble not less than 4 inches larger in diameter than the vent connector.

D. Connectors for low heat appliances (Appendix A, Columns II and III) shall not pass through walls or partitions constructed of combustible material unless they are guarded at the point of passage by:

1. Metal ventilated thimbles not less than 12 inches larger in diameter than the connector;

CONSTRUCTION USING COMBUSTIBLE MATERIAL, PLASTERED OR UNPLASTERED




Figure 1.

A equals the required clearance with no protection, specified in Table 1.

B equals the reduced clearance permitted in accordance with Table 2.

The protection applied to the construction using combustible material shall extend far enough in each direction to make *C* equal to *A*.

2. Metal or burned fire clay thimbles built in brickwork or other approved fireproofing materials extending not less than 8 inches beyond all sides of the thimble.

E. In lieu of thimbles all combustible material in the wall or partition shall be cut away from the connector a sufficient distance to provide the clearance required from such connector. Any material used to close up such openings shall be noncombustible insulating material.

F. A connector for a medium or high heat appliance (Appendix A, Columns IV and V) shall not pass through walls or partitions constructed of combustible material.

G. Connectors shall maintain a pitch or rise of at least $\frac{1}{4}$ inch to the foot (horizontal length of pipe) from the appliance to the chimney.

H. Connectors shall be installed so as to avoid sharp turns or other construction features which would create excessive resistance to the flow of flue gases. No device which will obstruct the free flow of flue gases shall be installed in a connector, chimney, or vent. This shall not be construed to prohibit the use of devices specifically listed for installation in a connector, such as heat reclaimers, draft regulators, and safety controls.

I. Connectors shall be securely supported and joints fastened with sheet-metal screws, rivets, or other approved means.

J. The entire length of a connector shall be readily accessible for inspection, cleaning, and replacement, unless listed materials are used and previous approval has been obtained from the authority having jurisdiction.

K. A vent connector shall not be connected to a chimney flue serving a fireplace unless the fireplace opening is sealed or the chimney flue which vents the fireplace is permanently sealed below the connection.

1008. Interconnection.

A. Connectors serving appliances operating under natural draft shall not be connected into any portion of a mechanical draft system operating under positive pressure.

B. Two or more fuel-burning appliances may be connected to a single chimney or vent provided sufficient draft is available for safe combustion in each appliance and removal of all the products of combustion safely to the outdoors. Gas and oil appliances so connected shall be equipped with primary safety controls.

1009. Dampers.

A. Manually operated dampers shall not be placed in chimneys, vents or connectors of stoker fired, liquid or gas-burning appliances. Fixed baffles on the appliance side of draft hoods and draft regulators shall not be classified as dampers.

B. Automatically operated dampers shall be of approved type designed to maintain a safe damper position at all times and arranged to prevent the initiation or increase of firing unless the damper is opened to a safe position.

1010. Draft Hoods.

For information concerning the use and installation of draft hoods, refer to the Standard for Gas Appliances and Gas Piping, NFPA No. 54, 1969.

1011. Draft Regulators.

A. Gas appliances connected to chimneys, other than those required by NFPA No. 54, to be installed with draft hoods, may be installed with draft regulators if in accordance with the appliance manufacturer's instructions.

B. For information concerning the use and installation of draft regulators with oil-burning appliances, refer to the Standard for Oil-Burning Equipment, NFPA No. 31, 1972.

C. Solid fuel-burning appliances may be installed with draft regulators to reduce draft intensity. Such regulators shall be installed and set in accordance with the instructions furnished with the appliance or the draft regulator.

D. A barometric draft regulator, if used, shall be installed in the same room or enclosure as the appliance in such a manner that no difference in pressure between the air in the vicinity of the regulator and the combustion air supply will be permitted.

110. VENTS

Appliance vents may be one of the following types installed as required by this section.

1101. Types and Uses (See Appendix B).

A. Type B gas vents shall be used to vent only listed gas appliances with draft hoods and other gas appliances listed for use with Type B gas vents; except they shall not be used for venting.

1. Vented wall furnaces listed for use with Type BW gas vents only.

2. Incinerators.

3. Appliances which may be converted readily to the use of solid or liquid fuels.

4. Combination gas oil burning appliances.

5. Appliances listed for use with chimneys only.

B. Type BW vents shall be used only with listed vented gas wall furnaces having a capacity not greater than that of the listed Type BW gas vent.

C. Type L vents shall be used only with appliances listed as suitable for such use and gas appliances listed as suitable for use with Type B gas vents.

D. Single wall metal pipe may be used to vent gas appliances in accordance with the following:

1. The pipe shall be of sheet copper not lighter than No. 24 B & S gage or of galvanized iron not lighter than No. 20 galvanized sheet gage number.

2. Single wall metal pipe shall be used only for runs directly from the space in which the appliance is located through the roof or exterior wall to the outer air.

3. Single wall metal pipe shall not originate in any unoccupied attic or concealed space and shall not pass through any attic, inside wall, concealed space nor through any floor or ceiling.

1102. Location.

Outside vents for gas appliances should not be used in cold climates unless adequately insulated.

1103. Termination.

A. Except as provided in 1103E and in 1106, all vents shall terminate above the roof surface. See Appendix D.

1. Vents installed with mechanical exhausters may be terminated not less than 12 inches above the highest point where they pass through the roof surface.

2. Vents installed with listed caps shall terminate in accordance with the terms of the cap's listing.

3. Vents installed without listed caps, or mechanical exhausters shall extend 2 feet above the highest point where they pass through the roof surface of a building and at least 2 feet higher than any portion of a building within 10 feet.

B. Natural-draft vents for gas appliances shall terminate at an elevation not less than 5 feet above the highest connected appliance outlet except as provided in 1106B.

C. Gas vents serving vented wall furnaces shall terminate at an elevation not less than 12 feet above the bottom of the furnace.

D. Vents passing through roofs shall extend through roof flashing.

E. Mechanical draft systems need not comply with 1103A, B, and C provided they comply with the following:

1. The exit terminal of the mechanical draft system shall be located not less than 12 inches from any opening through which combustion products could enter the building nor less than 2 feet from an adjacent building, and not less than 7 feet above grade when located adjacent to public walkways.

2. The exit terminal shall be so arranged that flue gases are not directed so as to jeopardize people, overheat combustible structures or enter buildings.

3. Forced draft systems and all portions of induced draft systems under positive pressure during operation shall be designed and installed so as to be gastight or so as to prevent leakage of combustion products into a building.

1104. Marking of Gas Vents.

In those sections of the country where solid and liquid fuels are used extensively, gas vents shall be plainly and permanently identified by a label reading:

"This gas vent is for appliances which burn gas only. Do not connect to incinerators or solid or liquid fuel-burning appliances."

1105. Installation.

A. Type B, Type BW, and Type L vents shall be installed in full compliance with the terms of their listing. Vents which pass through floors of buildings requiring the protection of vertical openings shall be enclosed with approved walls having a fire resistance rating of not less than 1 hour when such vent is located in a building less than 4 stories in height and not less than 2 hours when such vent is located in a building 4 stories or more in height.

B. Single wall metal pipe shall be installed as follows:

1. Single wall metal pipe shall be installed with minimum clearances from combustible material as follows:

- a. Appliances without draft hoods, 18 inches.
- b. Unlisted appliances equipped with draft hoods, 9 inches.
- c. Boilers and furnaces equipped with listed conversion burners and with draft hoods, 9 inches.
- d. Listed appliances with draft hoods except incinerators, 6 inches.

2. Where a single wall metal pipe passes through an exterior wall constructed of combustible material, except as provided in 1105.B.2.d, it shall be guarded at the point of passage by a ventilating metal thimble not smaller than the following:

a. For listed gas burning appliances with draft hoods, except incinerators — 4 inches larger in diameter than the vent pipe, unless there is a run of not less than 6 feet of vent pipe in the open, between the draft hood outlet and the thimble, in which case the thimble may be 2 inches larger in diameter than the vent pipe.

b. For unlisted gas burning appliances with draft hoods — 6 inches larger in diameter than the vent pipe.

c. For incinerators and appliances without draft hoods — 12 inches larger in diameter than the vent pipe.

d. In lieu of thimble protection all combustible material in the wall shall be cut away from the vent pipe a sufficient distance to provide the clearance required by 1105.B.1 of this Section from such vent pipe to combustible material, with any material used to close up such opening entirely noncombustible.

3. Where a single wall metal pipe passes through a roof constructed of combustible material it shall be guarded at the point of passage as specified for passage through a combustible exterior wall by 1105.B.2, or with listed gas appliances that can be connected to Type B gas vents by a noncombustible non-ventilating thimble not less than 4 inches larger in diameter than the vent pipe and extending not less than 18 inches above and 6 inches below the roof with the annular space open at the bottom and closed only at the top.

C. Additional requirements for the installation of venting systems serving gas appliances appear in Part V, Venting of Appliances, of Standard for Gas Appliances and Gas Piping, NFPA No. 54.

1106. Special Venting Arrangements.

A. **Sealed Combustion System Appliances — Direct vent appliances.** Sealed combustion system or direct vent appliances shall be listed and shall be installed in accordance with their listing and the manufacturer's instructions.

B. Ventilating Hoods and Exhaust Systems.

1. Ventilating hoods and exhaust systems serving commercial cooking appliances may be used to vent gas-burning appliances installed in commercial applications. The connector from the appliance shall terminate under the hood 18 inches from any grease filter or screen installed in the hood.

NOTE: For information on ventilation of restaurant cooking equipment see the Standard for Installation of Equipment for the Removal of Smoke and Grease-Laden Vapors from Commercial Cooking Equipment, NFPA No. 96.

2. When automatically operated appliances, such as water heaters, are vented through natural draft ventilating hoods, dampers shall not be installed in the ventilating system. If the ventilating hood or exhaust system is equipped with mechanical exhaust system, the appliance control system shall be interlocked so as to permit appliance operation only when the mechanical exhaust system is in operation (see 1103.E.3.).

3. A ventilating hood shall be installed above an open-top broiler in a residence. The hood shall be made with tight joints of sheet copper not lighter than No. 24 B & S gage or galvanized sheet steel not lighter than No. 28 galvanized sheet gage with a clearance of not less than $\frac{1}{4}$ inch between the hood and the underside of combustible material or metal cabinets. The vertical clearance above the broiler to the underside of combustible material or metal cabinet protected by the hood shall be not less than 24 inches. The width and breadth of the hood shall be not less than that of the open-top broiler unit and the hood shall be centered over the unit.

4. The hood required by 1106.B.3 shall be exhausted directly through an outside wall to the outside or connected to a suitable

chimney flue used for no other purpose. Connecting ducts shall be made of galvanized sheet metal not lighter than No. 28 gage. A clearance of not less than 6 inches shall be provided between the exhaust duct and unprotected combustible material. This clearance may be reduced if the combustible material is protected in accordance with Table 2.

C. Clothes Dryers.

1. All ducts expelling lint shall be provided with a lint collector, unless the dryer is so equipped.

2. For Type 1 gas-fired clothes dryer exhaust see the Standard for Gas Appliances and Gas Piping, NFPA No. 54.

3. Type 2 clothes dryers shall be exhausted to the outside air.

4. Provision for make-up air shall be provided for Type 2 clothes dryers, with a minimum free area of 1 square inch for each 1000 Btu per hour total input rating of the dryer(s) installed.

5. A clothes dryer exhaust shall not be connected into any vent connector, gas vent or chimney.

6. Ducts for exhausting clothes dryers shall not be put together with sheet-metal screws or other fastening means which extend into the duct and which would catch lint and reduce the efficiency of the exhaust.

7. Exhaust ducts for Type 2 clothes dryers shall be constructed of sheet metal or other noncombustible material. Such ducts shall be of adequate strength to meet the conditions of service with minimum thicknesses equivalent to No. 24 galvanized sheet gage.

8. Exhaust ducts for Type 2 clothes dryers shall have a clearance of at least 6 inches to combustible material except as provided in 9 below.

9. Exhaust ducts for Type 2 clothes dryers may be installed with reduced clearances to combustible material provided the combustible material is protected as described in Table 2.

10. When ducts pass through walls, floors or partitions, the space around the duct shall be sealed with noncombustible material.

11. Multiple installations of Type 2 clothes dryers shall be made in a manner to prevent adverse operation due to back pressures that might be created in the exhaust.

120. FIREPLACES.

1201. Factory-Built Fireplaces.

Factory-built fireplaces shall be listed and shall be installed in accordance with the conditions of the listing. Hearth extensions shall be provided in accordance with 1203F, and the manufacturer's instructions.

1202. Factory-Built Fireplace Stoves.

Factory-built fireplace stoves shall be listed and shall be installed in accordance with the conditions of the listing. Hearth extension shall be provided in accordance with 1203F, and the manufacturer's instructions.

1203. Masonry Fireplaces.

A. Fireplaces shall be constructed of solid masonry or of reinforced portland or refractory cement concrete with back and sides of the thickness specified in this paragraph, except as provided in 1201. Where a lining of low duty firebrick (ASTM C106, Type G), or the equivalent, at least 2 inches thick laid in fire clay mortar (ASTM C105, medium duty), or the equivalent, or other approved lining is provided, the total thickness of back and sides, including the lining, shall be not less than 8 inches. Where no such lining is provided, the thickness of back and sides shall be not less than 12 inches.

B. Steel fireplace units incorporating a firebox liner of not less than 1/4-inch thick steel and an air chamber may be installed with masonry to provide a total thickness at the back and sides of not less than 8 inches, not less than 4 inches of which shall be solid masonry.

C. Warm air ducts employed with steel fireplace units of the circulating air type shall be constructed of metal or masonry.

D. Fireplace hearth extensions shall be provided of approved noncombustible material for all fireplaces. Where the fireplace opening is less than 6 sq. ft., the hearth extension shall extend at least 16 in. in front of, and at least 8 in. beyond each side of the fireplace opening. Where the fireplace opening is 6 sq. ft. or larger, the hearth extension shall extend at least 20 in. in front of, and at least 12 in. beyond each side of the fireplace opening. Where a fireplace is elevated above or overhangs a floor, the hearth extension shall also extend over the area under the fireplace.

E. Fireplaces constructed of masonry or reinforced portland or refractory cement concrete shall have hearth extensions of brick, concrete, stone, tile or other approved noncombustible material properly supported and with no combustible material against the underside thereof. Wooden forms or centers used during the construction of hearth and hearth extension shall be removed when the construction is completed.

F. Hearth extensions of approved factory built fireplaces and fireplace stoves shall be not less than $\frac{3}{8}$ in. thick of asbestos, concrete, hollow metal, stone, tile or other approved noncombustible material. Such hearth extensions may be placed on the sub or finish flooring whether the flooring is combustible or not. The hearth extension shall be readily distinguishable from the surrounding floor.

G. All wood beams, joists and studs shall be trimmed away from fireplaces. Headers supporting trimmer arches at fireplaces shall be not less than 20 inches from the face of the chimney breast. Trimmers shall be not less than 6 inches from the inside face of the nearest flue lining.

H. Woodwork shall not be placed within 4 inches of the back face of a fireplace, but this shall not prevent plastering directly on the masonry or on metal lath and metal furring.

I. Woodwork shall not be placed within 6 inches of a fireplace opening. Woodwork above and projecting more than $1\frac{1}{2}$ inches from a fireplace opening shall not be placed less than 12 inches from the top of a fireplace opening.

APPENDIX A

Chimney Selection Chart

Chimneys for Residential Type Appliances	Chimneys for LOW HEAT Appliances		Chimneys for MEDIUM HEAT Appliances ¹	Chimneys for HIGH HEAT Appliances ³
	Building Heating Appliances	Industrial Type Low Heat Appliances		
1. Factory built. 2. Masonry (residential type). ⁴	1. Factory built. 2. Masonry (low heat type). ⁴ 3. Metal (low heat type). ⁵	1. Factory Built (industrial low heat type). 2. Masonry (low heat type). ⁴ 3. Metal (low heat type). ⁵	1. Factory built (industrial medium heat type). 2. Masonry (medium heat type). ⁴ 3. Metal (medium heat type). ⁵	1. Masonry (high heat type). ⁴ 2. Metal (high heat type). ⁵
TYPES OF APPLIANCES TO BE USED WITH EACH TYPE CHIMNEY				
Column I	Column II	Column III	Column IV	Column V
A. Residential type appliances, such as: 1. Ranges. 2. Warm air furnaces. 3. Water heaters. 4. Hot water heating boilers. 5. Low pressure steam heating boilers (not over 15 psig). 6. Incinerators 7. Floor furnaces. 8. Wall furnaces. 9. Room heaters. 10. Fireplace stoves B. Fireplaces.	A. All appliances shown in Column I. B. Nonresidential type building heating appliances for heating a total volume of space exceeding 25,000 cubic feet.* C. Steam boilers operating at not over 50 lb. per sq. in. gage pressure; pressing machine boilers.	All appliances shown in Columns I and II, and appliances such as: 1. Annealing baths for hard glass (fats, paraffine, salts, or metals). 2. Bake ovens (in bakeries). 3. Boiling vats, for wood fibre, straw, lignin, etc. 4. Candy furnaces. 5. Coffee roasting ovens. 6. Core ovens. 7. Cruller furnaces. 8. Feed drying ovens. 9. Fertilizer drying ovens. 10. Fireplaces, other than residential type. 11. Forge furnaces (solid fuel). 12. Gypsum kilns. 13. Hardening furnaces (below dark red). 14. Hot air engine furnaces. 15. Ladle drying furnaces. 16. Lead melting furnaces.	All appliances shown in Columns I, II and III, and appliances such as: 1. Alabaster gypsum kilns. 2. Annealing furnaces (glass or metal). 3. Charcoal furnaces. 4. Cold stirring furnaces. 5. Feed driers (direct fire heated). 6. Fertilizer driers (direct fire heated). 7. Galvanizing furnaces. 8. Gas producers. 9. Hardening furnaces (cherry to pale red). 10. Incinerators, commercial and industrial type. 11. Lehrs and glory holes. 12. Lime kilns. 13. Linseed oil boiling furnaces. 14. Porcelain biscuit kilns. 15. Pulp driers (direct fire heated).	All appliances shown in Columns I, II, III, and IV and appliances² such as: 1. Bessemer retorts. 2. Billet and bloom furnaces. 3. Blast furnaces. 4. Bone calcining furnaces. 5. Brass furnaces. 6. Carbon point furnaces. 7. Cement brick and tile kilns. 8. Ceramic kilns. 9. Coal and water gas retorts. 10. Cupolas. 11. Earthenware kilns. 12. Glass blow furnaces. 13. Glass furnaces (smelting). 14. Glass kilns. 15. Open hearth furnaces. 16. Ore roasting furnaces. 17. Porcelain baking and glazing kilns.