

NFPA No.

328

**FLAMMABLE, COMBUSTIBLE
LIQUIDS & GASES IN**

**MANHOLES,
SEWERS
1975**



Copyright © 1975

All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION

470 Atlantic Avenue, Boston, MA 02210

4M-12-75-FP

Printed in U.S.A.

**JOIN NOW . . .
AND DO SOMETHING
FOR YOUR CAREER!!**



Membership in the
NATIONAL FIRE PROTECTION ASSOCIATION brings you:

- Reports of major fires and their causes
- News of changes in fire codes and standards
- Current information on NEW fire prevention techniques
- Personal assistance from NFPA experts

... and MUCH MORE, including FIRE JOURNAL and FIRE NEWS with your membership. With the guidance of NFPA, your career has nowhere to go but up!!

Write for Details and Membership Application

Licensing Provision

This document is copyrighted by the National Fire Protection Association (NFPA). Public authorities and others are urged to reference this document in laws, ordinances, regulations and administrative orders or similar instruments. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method ("adoption by reference") are requested to notify the NFPA (attention: Assistant Vice President — Standards) in writing of such use.

The term "adoption by reference" means the citing of the title and publishing information only.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

See Inside Back Cover for Official NFPA Definitions

MGR-FM-75

Recommended Practices on the Control of Flammable & Combustible Liquids & Gases in Manholes and Sewers

NFPA No. 328 — 1975

1975 Edition of NFPA No. 328

This edition of NFPA No. 328 supersedes the 1970 and previous editions. This report was developed by the Sectional Committee on Maintenance and Repair, approved by the Correlating Committee on Flammable Liquids and adopted at the NFPA Fall Meeting held November 17-20, 1975 in Pittsburgh, PA.

Origin and Development of NFPA No. 328

Sufficient case histories of fires and explosions in underground structures fully justify a careful review of the material contained within this report. The sources of flammable vapor-air mixtures in these locations, coupled with a study of unsafe practices and protective practices contained herein, certainly will indicate the desirability of utilizing the applicable corrective measures suggested in the summary of this report. This recommended practice was first adopted in 1956 and subsequent editions were published in 1964 and 1970.

Interpretation Procedure of the Committee on Flammable Liquids

Those desiring an interpretation shall supply the Chairman with five identical copies of a statement in which shall appear specific reference to a single problem, paragraph, or section. Such a statement shall be on the business stationery of the inquirer and shall be duly signed.

When applications involve actual field situations they shall so state and all parties involved shall be named.

The Interpretations Committee will reserve the prerogative to refuse consideration of any application that refers specifically to proprietary items of equipment or devices. Generally inquiries should be confined to interpretation of the literal text or the intent thereof.

Requests for interpretations should be addressed to the National Fire Protection Association, 470 Atlantic Avenue, Boston, MA 02210.

Committee on Flammable Liquids

Correlating Committee

Paul C. Lamb, *Chairman*
140 Dwight Place, Englewood, NJ 07631

Miles E. Woodworth, *† Secretary*
National Fire Protection Assn., 470 Atlantic Ave., Boston, MA 02210

G. E. Cain, Manufacturing Chemists' Assn.

Clifton P. Geisert, Insurance Services
Office of Illinois

Donald Johnson, Western Oil & Gas Assn.

F. O. Kubias, Glidden-Durkee, Div. of SCM
Corp.

J. C. Sanders, Fire Marshals Assn. of N.
America

W. J. Smith, Underwriters' Laboratories,
Inc.

E. C. Sommer, American Petroleum In-
stitute

Dr. Ing. Gert Magnus†, Mannheim, Germany

†Nonvoting Members

Sectional Committee on Maintenance and Repair

Donald M. Johnson, *Chairman*
Standard Oil Co. of California, 555 Market St., San Francisco, CA 94105
(rep. Western Oil & Gas Assn.)

Miles E. Woodworth, *† Secretary*
National Fire Protection Assn., 470 Atlantic Ave., Boston, MA 02210

J. A. Cedervall, Underwriters' Laboratories,
Inc.

Joe Egger, Fire Marshals Assn. of N.
America

H. J. Kolodner, Manufacturing Chemists'
Assn.

Robert J. Nespeco, National Oil Fuel
Institute, Inc.

Felix P. Raczak, Fire Marshals Assn. of N.
America

O. M. Slye, American Petroleum Institute

Pat R. Wrigley, National Petroleum Re-
finers Assn.

Alternates

Robert D. Lynch, National Oil Fuel In-
stitute (Alternate to R. Nespeco)

J. F. McKenna, American Petroleum In-
stitute (Alternate to O. M. Slye)

†Nonvoting

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

Control of Flammable and Combustible Liquids and Gases in Manholes, Sewers and Similar Underground Structures

Foreword

Manholes, sewers and similar underground conduits have long been recognized by fire protection engineers as constituting areas where fire and explosion hazards of some severity may exist. Modern civilization, accompanied by the increase in number of gasoline service stations, solvent disposal operations, dry-cleaning establishments, fuel gas production and distribution facilities, refrigeration plants, and many other industrial activities with potentially dangerous gas or vapor by-products makes the safe operation of underground structures more difficult each year.

The probability of an explosion within an underground space is dependent on two factors: one, that the atmosphere contains a mixture of flammable vapor and air within the flammable range, and two, that there be a coincident source of ignition. Explosions occur infrequently because the proper mixture and the source of ignition are not present at the same time. For example, in the City of Los Angeles, which had approximately 140,000 manholes and vaults within the metropolitan, suburban and county areas, routine gas detection surveys made over a fifteen-year period prior to 1948 showed a total of over 9,000 vaults and manholes where the presence of flammable vapors was detected. In this period of time approximately 1,000,000 tests were made. The experience report indicated that an average of less than eight explosions occurred annually within the area.

The severity of an individual explosion and its consequences are dependent on various factors. There is always present the possibility that any one explosion may result in a major catastrophe.

This report is limited to a study of the flammable and combustible liquids and gases found in manholes, sewers, vaults and similar underground structures. The underground structures include: sanitary sewers, storm drains, water lines, fuel gas distribu-

tion systems, electric light and power conduits, telephone and telegraph communication lines, street lighting conduits, police and fire signal systems, traffic signal lines, refrigeration service lines, steam lines, and petroleum pipelines.

The term "underground structures" is not intended to include subways, tunnels and the substructural areas of buildings such as underground garages.

The purpose of this report is to give to enforcement officials, fire authorities, contractors and owners of underground structures guidance on problems involving flammable and combustible liquids and gases which may be found in underground structures.

THE PROBLEM.

With greater congestion today, the present trend in civic planning is directed toward the installation of all types of utility services beneath the street surface. This results in a continuous program of excavation and construction, with frequent damage to existing structures.

Sources of Ignition.

The possibility of flammable gases or vapors which may collect in underground areas being ignited is limited by certain fundamental conditions. The vapor must be mixed with sufficient air to make a flammable mixture, or it must be escaping into air at a point where a flammable mixture can be created. Heat of sufficient intensity to ignite the particular air-vapor mixture involved must be present at the place where a flammable mixture exists. Such heat may be caused by an open flame, an electric arc or spark, an incandescent heated particle, or a sufficiently heated hot surface.

The flammable limits of the gases and vapors which have been found in underground structures are listed in Appendix A. Flammable mixtures are formed when the concentration of these gases in air is between the minimum and maximum shown.

Flame: Any open flame is a potential source of ignition. These may be encountered in everyday work operations. Little control can be exerted over the casual sources of ignition when flammable vapors are escaping from or into underground structures. Such casual sources of ignition include burners and warning lanterns used by street surface maintenance crews, automobile exhausts, tar pots and pedestrian smokers.

Arcs: The heat of an electric arc occurring in electric underground structures may cause the distillation of insulating material producing flammable gases which in turn may be ignited by the arc itself when the proper air-gas ratio is reached. This usually will occur when the arc reaches a manhole or vault after having started in a duct. Other gases or flammable vapors, if present, may also be ignited by such an arc.

Static: Static electricity may be a source of ignition and its generation is generally greatest in an atmosphere of low humidity. The hazard appears when static accumulates to the extent that a spark discharge may occur. Static electricity may be generated when a liquid or gas under pressure escapes from a pipe at high velocity into an atmosphere of low humidity. Particles of dust, scale, and rust inside the pipe may become heavily charged with static and, if they impinge on an insulated body, the body will accumulate the charge and a spark discharge may occur.

Sources of Flammable and Combustible Liquids and Gases.

The contributory causes responsible for the presence of these liquids and gases in underground structures are not generally appreciated. Investigations over a period of years on reported cases of flammable vapors detected in sewers, drains, drainage canals and telephone and electric power vaults have disclosed a diversity of products within the structures. The condition created by the existence of these gases and vapors can be grouped into two classes: (1) flammable and (2) injurious to life. The latter condition results from the toxic, asphyxiating or suffocating properties of the gases or vapors. Some of these liquids and gases fall into more than one class. However, this study will be limited to those liquids and gases that are of a flammable nature (see Appendix A). The release of piped oxygen, which may be present in underground structures, will accelerate the combustion of any flammable vapor.

Natural Gas: Natural gas means gas which originated from naturally occurring gas- or oil-bearing strata. In oil and natural gas producing areas, cracks and faults in the underlying strata or abandoned wells may permit gas to permeate the soil and enter underground conduits and vaults. Within the boundaries of some cities there are actively producing oil and gas fields and many of these underlie developed areas, residential and industrial, where underground structures are now installed.

Fuel Gas: Fuel gases include natural gas, liquefied petroleum gases, coke-oven gas, coal gas, oil gas, carbureted water gas, water

gas, producer gas and blast-furnace gas. These gases, except liquefied petroleum gases, have specific gravities lower than that of air so that when released in an underground space they will tend to rise and diffuse rather rapidly above the point of leakage. These gases when mixed with air within certain limits produce flammable mixtures. Since the oxygen content of each of these gases when not mixed with air is usually below 1.0 percent, they may be classed as suffocating gases. With the exception of natural gas and liquefied petroleum gas, they are also highly toxic because of the high carbon monoxide content. Natural gas and other fuel gases as distributed by utility companies in underground pipes are an extensive source of potentially flammable gas. These pipes may be subject to damage caused by corrosion, electrolysis, structural failures and adjacent excavating. These causes are discussed in greater detail in later paragraphs of this section.

Refrigerant Gases: A number of the common refrigerants have varying degrees of flammability, for example, ammonia, methyl chloride, ethyl chloride, methyl bromide and ethyl bromide. With the exception of ammonia, all of these refrigerants in the vapor phase are heavier than air. Therefore, if they are released in large quantities in closed spaces, these heavy gases will flow downward into the lowest areas. Of these, only ammonia has a sufficiently strong odor in dilute concentrations to indicate its presence. Exposure to ammonia fumes may cause severe ammonia burns even at concentrations below the flammable limits. Liquid ammonia is often distributed through underground street pipes for refrigeration service in the business districts of many large cities. This system of pipes may be subject to the same exposure to physical damage as fuel gas pipes and petroleum pipelines.

Electric Cable and Other Insulating Material Gases: This source of flammable gas is practically limited to severely overloaded electric underground circuits. A breakdown of cable insulation will produce an electric arc. If the protective fuses do not operate promptly, this electric arc will continue. The heat of the arc may, by destructive distillation of cable insulation (varnished cambric, rubber or paper), produce flammable gases containing hydrogen, carbon monoxide and hydrocarbons.

Chemical Products: Accidental spillage in chemical processing plants and disposal of waste chemical products through sewers by industrial plants may be potential sources or contributing causes for explosive conditions. Examples of such products are carbon disulfide and ammonia. Calcium carbide will react with water to produce acetylene which is flammable.

Sewage Gases in Sewers and Drains: Sewage gas results from the fermentation or decomposition of organic matter. These gases

can be produced when organic matter has settled as a solid in sewer lines caused by flat grades, crevices, sumps or obstructions where consistent flow of sewage is lacking, or as the result of bacterial action on wood or other organic material immersed in water. These flammable gases are principally methane, hydrogen sulfide and hydrogen and, on the basis of present evidence, they seldom reach explosive concentrations in sewers and drains. However, when they are mixed with other flammable liquids and gases present in sewers, explosive conditions may occur.

Flammable and Combustible Liquids: Cleaning solvents and compounds washed down drains by industrial and domestic users may be the media from which flammable vapors originate. Hydrocarbon liquids such as gasoline and kerosene in industrial plants, service station and garage wash racks are often sent to sewers and drains either accidentally or because there is no easier method of disposal. Any leaking underground tank containing liquids such as a service station's underground gasoline tanks, may be a source of flammable vapors in underground structures.

Petroleum Pipeline Products: Liquid petroleum products and liquefied petroleum gases are conveyed by pipelines installed beneath public streets and rights-of-way. These pipelines may be exposed to the same sources of physical damage as fuel gas pipes and these sources of damage are discussed in detail later. If any of these pipelines should fail, the escaping liquids and gases may penetrate substructure walls or rise to the street surface. Liquids may be washed into drains or enter the ventilating openings in the manhole covers of underground structures. Escaping liquid petroleum products may evaporate in the ground, penetrate the surrounding ground, or may enter a confined space to produce a flammable mixture.

Penetration of Structures by Gases: Flammable gas products present in the subsoil enter conduits, sewers, drains or basements because underground structures constructed of cement, concrete, brick or vitreous tile generally are not built to be impervious to gas. If a flammable gas or liquid is present in the soil, there is some likelihood that it may penetrate an adjacent underground structure. Gas may frequently enter the subsurface sections of buildings through or around any underground conduits that penetrate the substructure walls, and through abandoned gas lines that have not been capped or sealed. The distance that gas can move through man-made underground structures, while theoretically unlimited, has in practice been found to be limited but unpredictable.

Electric Circuit Oil Switches and Oil Insulated Transformers: This equipment is frequently installed in a street vault and electrical failures will occasionally result in an explosion. The action

of protective devices in shutting off current is usually very fast, being of the order of two seconds or less. This has the effect of limiting the explosion, if one does occur, to the vault in which the failure occurs. However, when the vault is adjacent to or within a large structure, such an explosion may result in heavy damage.

Damage to Underground Lines.

Corrosion: One type of corrosion which occurs in gas lines and petroleum pipelines is where the soil composition and resistance is such that electric current from the development of local action cells can flow readily from anodic areas on the pipe surface through the soil to the cathodic areas on the same pipe. Such soil conditions may be due to acid or alkali content, organic matter, variations of water or oxygen content, soil type, or the presence of certain bacteria in the soil. Corrosion may also occur as a result of chemical reaction between the pipe and surrounding soil. Electrolysis is another cause of corrosion in utility gas pipe and petroleum pipelines. Stray direct-current electric currents originate from two sources: 1. Direct-current electric railways and trolley lines using rails to carry return currents. 2. Industrial plant direct-current machinery using the ground as a return conductor. Underground pipes may pick up stray currents from cross connections with other structures carrying current. These currents may not be destructive where they enter the piping system. However, drainage of these stray currents to the ground may cause corrosion at these points of discharge. Current drainage from these underground lines is controlled as effectively as possible by installation of drainage bonds and reverse-current switches, but the effect of these bonds and switches is mitigated by changes in railway traffic, alterations in underground structures, and damage to rail or drainage bonds. Under such situations the electric current may discharge from pipelines to ground, and if not detected and corrected, the pipe wall may be eventually penetrated.

Structural Failures: The allocation of insufficient space for the installation of underground structures may, in some situations, result in the encasing of gas and flammable and combustible liquid pipes in the walls of ducts and subsequent constructed masonry vaults. Such pipes from vaults under certain conditions may be fractured. Flood washouts, earthquakes and landslides may cause the dislocation and movement of ground and are often responsible for pipe fractures. Rupture of water mains due to corrosion, electrolysis or structural failure may in turn cause washout of soil that supports gas and flammable liquid pipes. Lacking support, these pipes may fracture.

Excavating: Contractors doing excavation work often encounter gas and flammable and combustible liquid pipes, and even though aware of their presence, workmen may unintentionally damage the pipe resulting either immediately or ultimately in a leak. Damage such as this is not always reported and often repairs are attempted by the party responsible for the physical damage which later may prove to be inadequate.

Fire Damage: Fires in underground structures can result in spalling of concrete, destruction of protective linings and deterioration of other interior surfaces. Such damage, if extensive, may result in weakening the structure.

Unsafe Practices.

Before washing spilled petroleum products from street surfaces into drains or sewers, which may be a potentially dangerous action and often is an unlawful practice, other disposal means should be considered such as mopping up with sand, rags or mops. If, in an emergency, no alternative is available, disposal into a drain or sewer should be done only on the decision of a qualified person, after the Chief of the Fire Department has been notified.

Disastrous consequences may result from the thoughtless or deliberate dumping into drains of waste products which are either directly flammable or which by reaction with organic matter in sewers may produce a flammable mixture. Though the presence of a flammable material may be detected, its source often is difficult to determine.

PROTECTIVE PRACTICES.

The adoption of protective measures which will detect the presence of flammable products in manholes and vaults, and provide the means to prevent the accumulations of gas within the explosive range, should reduce the incidence of explosions in underground structures. Such a defensive procedure is necessary because of the difficulty of eliminating the flammable material at its source.

Numerous sources of ignition may be found in underground structures. The operators of underground structures by eliminating the use of flames in suspected areas may materially reduce the number of ignitions. Experience has shown, though, that fire and explosion incidence can best be reduced by the elimination of flammable vapors from the atmosphere of the underground structure. It is all but impossible to remove all ignition sources.

Considering the diversity of contributory causes for flammable products in underground structures, protective practices should be designed to reduce to a minimum the quantity of flammable vapors. Where such vapors are found to be present, a complete purge of the manhole or vault atmosphere should be made and the source of the flammable vapors eliminated. Manholes and vaults should be ventilated by forced draft when necessary to prevent concentrations of these vapors within the explosive range. After complete ventilation of the underground structure, the atmosphere should be tested with a combustible gas indicator before entering and before any hot work is performed. A positive reading on the combustible gas indicator does not necessarily mean that the toxicity hazard has been eliminated. Adequate ventilation should be maintained and periodic gas analysis of the atmosphere during any such work should be made.

There are a number of instruments that can be used to detect unsafe atmospheres found in underground structures. They should be used to determine the characteristics of any questionable situation.

Oxygen: There are indicators that give a direct reading of oxygen concentration. Under no conditions should an area be entered, without self-contained breathing apparatus, unless it contains at least 16 percent oxygen.

Carbon Monoxide: This gas in concentrations greater than 0.10 percent by volume results in unconsciousness in little more than an hour and death in four hours. Further increases in concentration reduce this time element. Its effect is to displace oxygen in the blood stream. Several instruments have been developed for the quick detection of carbon monoxide. Those capable of detecting the smallest concentrations considered hazardous are the carbon monoxide tester (palladium-molybdate complex) and the carbon monoxide indicator.

Hydrogen Sulfide: This flammable and toxic gas is colorless and has an odor resembling rotten eggs. It is toxic in concentrations in excess of 0.002 percent by volume. Continued exposure will paralyze the olfactory nerves. The hydrogen sulfide detector will detect the low toxic concentrations of this gas.

Fuel Gases and Vapors from Flammable and Combustible Liquids: Combustible gas indicators are available in a number of different types to meet the requirements of the specific use to which they may be applied. The three most common types are (a) an "all-purpose" instrument suitable only for the detection of flammable gases such as natural gas, manufactured gas, hydrogen and acetylene and all vapor-air mixtures associated with fuel oils, gas-

oline including leaded gasoline, alcohols and acetones. This instrument indicates the presence of these gases and vapors only. (b) A specific instrument is available for use on the specific gas or vapor-air mixture for which it is calibrated, such as natural gas, manufactured gas, hydrogen or acetylene. Such an instrument is usually calibrated in the range of zero to slightly above the lower explosive limit of the specific gas or vapor. This instrument is not an all-purpose instrument and is designed for use only on the gas or vapor on which it is calibrated. (c) A specific instrument is utilized principally by gas utilities for use in pinpointing leaks in underground mains and services. This instrument must be calibrated on the specific gas being sampled, i.e., natural or manufactured gas and has a scale range of zero to 100 percent gas. A portable combustible gas indicator is also available for operation in explosive atmospheres.

Periodic surveys with instruments should be made of the atmosphere of all water, gas and electric underground structures for the presence of flammable vapors. The frequency of such surveys will depend upon the previous experience and the potential hazard.

Liquefied petroleum gases and utility gases are odorized to facilitate detection unless the odorant would serve no useful purpose as a warning agent. Such purposes are relatively rare and practically all such gases distributed by underground pipelines are odorized. Experience has shown that odorants can be absorbed in traveling through the soil.

Volatile flammable liquids may have accidentally entered a drainage system because of a spill or other emergency. Steps should be taken to minimize the hazard by exhausting the vapors with blowers or exhaust fans driven by explosionproof motors and by pumping out the liquid with pumps equipped with explosionproof motors. Floor drain openings into buildings in the area of the spill and for some distance downstream should be checked for escape of vapors. Water should be placed in any dry traps to seal them. Copious quantities of water should be used to flush any flammable or combustible liquid through the system quickly and to dilute it, if miscible with water.

Prior to laying a pipeline, a suspected electrolysis area should be examined rather than to explore for leakage after piping has been damaged. Where electrolysis or corrosive soil conditions are known, owners of pipelines that carry flammable products through such soil should take measures to arrest electrolysis or corrosion. Protective measures against corrosion should be taken in cooperation with other owners of nearby underground structures which would be adversely affected by unilateral action. If damage is suspected,

surveys may be made by testing all available underground structure street openings with combustible gas indicators, by noting the condition of vegetation, by pressure drop tests, by soapsuds testing on exposed pipe and fittings and by bar test surveys. The bar test survey requires extra care to prevent damage to underground structures.

Underground tanks of gasoline at service stations may be a source of leakage. When a service station tank is found to be leaking, its contents should be removed immediately. When such a tank is taken out of service, abandoned or removed, the procedures described in Appendix C of the Flammable and Combustible Liquids Code, NFPA No. 30, entitled Abandonment or Removal of Underground Tanks, should be followed.

The functional purpose of underground structures as well as the design require different procedures for the elimination of flammable gases, though the means of detection are similar. Where flammable products may have originated within the structure, as in sanitary sewers or electric vaults, the elimination of the cause is a distinctly different problem than if the flammable product entered the structure from the outside.

Sewers and drains should be periodically flushed and cleaned to prevent deposits of organic material and slime growth. Periodic inspections should be made of industrial plants to prevent the discharge into sewers of waste that might produce explosive gases due to physical or chemical impurities, high temperatures, alkalinities or acidities.

Periodic checks should be made of protective equipment in underground electric systems. Efforts should be made to prevent the overloading of cables and to avoid arcing conditions that may be causing the source of flammable gas by the breakdown of insulation. Fusing and arcing should be prevented, too, because they furnish a source of ignition. The efficiency of all rail bonds on tracks of electrified railway systems should be checked to insure that the potential gradient of the rail system is at a minimum.

SUMMARY.

A review of all the factors relating to the problem of explosive hazards in underground structures, together with an analysis of causes of explosions, indicates that flammable material may at some time be present during the life of an underground structure.

Control procedures and education are the proper approaches to the problem. Effective control cannot be maintained unless the various utilities involved, the administrative bodies of cities and others cooperate in an adequate safety program.

Utility companies should adopt a definite program to minimize the amount of lost and unaccounted for gas. It should be recognized that only part of "the lost and unaccounted for gas" is due to pipeline leakage.

Utility companies should maintain an adequate inspection program for the detection of leaks at street openings. This can best be accomplished by the use of combustible gas indicators, vegetation surveys, and other methods. Periodic inspection and testing of key equipment should be conducted with reasonable frequency as a part of regular maintenance operations. Such a distribution piping maintenance program could be carried out in accordance with the requirements of Federal and State Pipeline Regulations.

Inactive gas services and mains should be abandoned in accordance with Federal and State Regulations.

Automatic or manually operated drains in industrial piping should be designed so as not to discharge their product into underground structures.

Owners and operators of underground pipelines carrying flammable and combustible liquids should maintain an adequate inspection program for the detection of escaping liquids.

Bulletin 1621, Recommended Practice for Bulk Liquid Stock Control in Service Stations, published by the American Petroleum Institute, will be of value to operators of service stations.

An in-service training program for all employees whose occupation is associated with underground structures will teach them to recognize the presence of fire and toxic hazards and oxygen deficiencies and teach them how to take proper precautions against such possibilities.

Administrative bodies of some cities have established a program to control or prevent the discharge into sewers and drains of all products likely to result in flammable atmospheres in vaults and manholes.

Administrative bodies of cities should adopt an ordinance which would require a contractor before starting construction or excavation work (1) to obtain a permit, (2) to notify the owner of adjacent underground structures in writing of his intention to start work, and (3) to obtain from the owner the exact information on the location of the underground structures and pipes containing

flammable products. All agencies having underground structures should be prepared to furnish contractors with exact information on the location of such underground structures. This permit should prohibit the contractor from interference with the above-mentioned pipes without giving prior notice to the owner or operator.

All agencies having underground structures should be prepared to furnish contractors with the record of the locations of such adjacent structures or furnish a man who knows the location of these pipes. In the event the exact location of any underground structure is not known, the contractor should make a physical inspection of the entire right-of-way of the proposed trench by employing underground detecting devices and visual inspection of adjacent structures.

Apart from direct damage to piping, contractors should take extra precautions to avoid damage to corrosion protecting coatings, anodes, electrodes, bonding facilities and related devices. If these are disturbed or damaged, the owner of the structures should be notified before backfilling the excavation. Care should be taken in all excavations in which wire or metal is found, even though these are not immediately adjacent to a pipeline. They may be part of the protective system.

Administrative bodies of cities should require anyone conducting blasting operations to obtain a permit. The permit should not be granted until the owners of adjacent underground structures have been consulted. A model code, NFPA No. 495, Explosives and Blasting Agents, may be found in Volume 4, National Fire Protection Association's National Fire Codes or in Article 12 of the American Insurance Association's Fire Prevention Code.

Administrative bodies of cities should require anyone razing buildings to obtain a permit. The permit should not be granted until the owners of underground structures in the area have been consulted.

Administrative bodies of cities should prohibit the encasement of pipes containing flammable products within the constructed walls of new structures. This recommendation does not apply to piping entering buildings.

Administrative bodies of cities should establish a procedure for connecting direct current electrical equipment to ground on the premises of the user. This is to prevent the inclusion, directly or indirectly, of underground pipes carrying flammable products in the return electric circuit.

Administrative bodies of cities can promote cooperative efforts on the part of all organizations having underground facilities to reduce corrosion.

Sewers and drains should be designed to insure proper cleansing velocities, proper ventilation, to prevent infiltration and to avoid the settling of heavy solids. Sewers and drains should be designed to minimize the danger of settlement and failure which in turn might break other adjacent underground structures.

Where ventilation of a vault or manhole is necessary, and mechanical ventilation cannot be provided, the manhole or vault should be designed (depending upon local conditions) so that effective natural ventilation for vapors or gases lighter than air can be obtained. Manholes for sewers should be regularly spaced to provide effective ventilation and explosion relief.

Every effort should be made to establish standard practice for the design, construction and maintenance of all underground structures with respect to the elimination of explosive hazards and the contributory causes.

Close liaison can be established between the fire chief and industrial safety officials. Between these individuals mutually approved procedures should be developed to cope with emergencies so that the firemen can act more effectively in their line of duty.

APPENDIX A.

PROPERTIES OF FLAMMABLE AND COMBUSTIBLE LIQUIDS AND
GASES WHICH HAVE BEEN FOUND IN
UNDERGROUND STRUCTURES

	Flash Point Closed Cup Deg. F	Flammable Limits in Air % by Vol.		Specific Gravity of Liquid (Water = 1)	Specific Gravity of Vapor (Air = 1)
		Lower	Upper		
Acetone	0	2.6	12.8	0.8	2.00
Acetylene	Gas	2.5	100.0		0.90
Ammonia	Gas	16.0	25.0		0.6
Benzene	12	1.3	7.1	0.9	2.8
Butadiene	Gas	2.0	11.5		1.87
Butane	-76	1.9	8.5	0.60	2.01
Carbon Disulfide	-22	1.3	44.0	1.30	2.64
Carbon Monoxide	Gas	12.5	74.0		0.97
Ethane	Gas	3.0	12.5		1.0
Ethyl Chloride	-58	3.8	15.4	0.9	2.2
Gas Oil*	150	4.8	32.5	1.31	
Gasoline (Values may vary for different grades of gasoline)	-45	1.4	7.6	0.8	3.-4.0
Hydrogen	Gas	4.0	75.0		0.1
Hydrogen Sulfide	Gas	4.0	44.0		1.2
Kerosene	100-165	0.7	5.0	< 1	
Methane	Gas	5.0	15.0		0.6
Methyl Bromide	Gas	10.0	15.0		3.3
Methyl Chloride	Gas	10.7	17.4		1.8
Natural Gas*	Gas	3.8	13.0		0.65
Petroleum Naphtha*	< 0	1.1	5.9	0.75	3.75
Propane	Gas	2.2	9.5		1.6
Toluene	40	1.2	7.1	0.87	3.1

*These liquids and gases are mixtures and their properties may vary depending on the composition.

APPENDIX B.

Analysis of Causes of Explosions.

A review of a number of explosions in underground structures is of considerable interest and is indicative of the seriousness of the hazards involved.

Gas in Manhole — Savannah, Ga. — June 1973.

An unknown gas had accumulated in a manhole and was ignited by a welder's torch. All the circuits in the manhole were de-energized by the explosion and the ensuing fire was extinguished by CO₂ extinguishers.

LP Gas Leak in Cave — Walthill, New Brunswick, Canada — January 24, 1973.

A leak in an underground LP-Gas installation seeped through the ground and into a cave. When a light switch was thrown, an explosion occurred that seriously injured two boys. The minor fire that followed was extinguished by the boys' father.

Flammable Liquids in Sewer — Peabody, Mass. — May 23, 1972.

Flammable liquids from an unknown source leaked into the sewerage system and ignited from a welding torch at the sewerage treatment building. The ensuing fire completely damaged the building.

Gasoline in Sewer — Nashville, Tenn. — January 18, 1970.

Gasoline that had leaked from a bulk storage plant entered the sewer system and, eventually, the sewerage treatment plant resulting in two explosions. The piping for the roof drain of a floating roof tank, which goes down inside the tank, had frozen and ruptured. Since the valve at the discharge end had been left open, gasoline flowed from that drain valve into the diked area surrounding the tank. The dike drain had also been left open, allowing the gasoline to flow out of the diked area into an open sewer connection nearby. The gasoline eventually made its way to the treatment plant, where the explosions occurred. It was estimated that 46,000 gallons of gasoline entered the sewer system.

Gasoline in Sewer — Joliet, Ill. — July 2, 1969.

A series of sewer explosions in the downtown business district blew out manhole covers and many windows. Exposed buildings were also damaged by fires, and large chunks of concrete were torn from the wall of the Illinois Waterway. The explosions were caused by ignition of gasoline fumes in the sewer lines. The source of the gasoline was a storage tank on the premises of a bottling plant. Vandals had broken into the plant and stolen some motor oil and possibly some gasoline. The pump was found running, and it was estimated that 850 gallons had entered the sewer system through a catch basin in the yard.

Gas in Tunnel — Manhattan, N. Y. — January 3, 1969.

Explosion of gas leaking from a ruptured 100-foot section of a 16-inch main caused the roadbed of Delaney Street to buckle in many places over a three-block area. The ignition source was not determined. Escaping gas burned along the street, damaging parked cars and exposed buildings. All street and subway traffic was halted, including the Williamsburg Bridge. Occupants were evacuated from 35 five-story tenement buildings. An unknown or forgotten 5-foot-diameter tunnel, two blocks long and containing a narrow-gage railroad track, was discovered under Delaney Street. Apparently the leaking gas had accumulated in the tunnel.