

NFPA® 408

Standard for
Aircraft Hand
Portable Fire
Extinguishers

2010 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS
NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA® codes, standards, recommended practices, and guides (“NFPA Documents”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Documents.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Documents. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Documents available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Documents. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Document. The users of NFPA Documents bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Documents.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Document may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Documents are copyrighted by the NFPA. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Documents and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02169-7471; email: stds_admin@nfpa.org

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2009 National Fire Protection Association®. All Rights Reserved.

NFPA® 408

Standard for

Aircraft Hand Portable Fire Extinguishers

2010 Edition

This edition of NFPA 408, *Standard for Aircraft Hand Portable Fire Extinguishers*, was prepared by the Technical Committee on Aircraft Rescue and Fire Fighting. It was issued by the Standards Council on October 27, 2009, with an effective date of December 5, 2009, and supersedes all previous editions.

This edition of NFPA 408 was approved as an American National Standard on December 5, 2009.

Origin and Development of NFPA 408

Work on this standard started in 1947 after requests were received by the National Fire Protection Association for recommendations on aircraft hand fire extinguishers. During the intervening years, prior to the adoption of the first draft of this text in 1955 by the Association, a number of proposals were prepared and circulated for comment and criticism. In 1956, a revision was adopted incorporating an appendix on air crew training. Revisions were made in 1964, 1965, 1970, and 1973.

The 1984 document was completely revised to recognize state-of-the-art developments in extinguishing agents and to bring the document into conformance with the *Manual of Style for NFPA Technical Committee Documents*.

The 1989 edition was a reconfirmation of the 1984 edition. The 1994 edition was a partial revision. The 1999 edition was a reconfirmation of the 1994 edition.

Minimum requirements were added to the 2004 edition for halocarbon agent fire extinguishers as they are now acceptable for installation onboard aircraft, in lieu of halon extinguishers, per the U.S. Federal Aviation Administration (FAA).

In the 2010 edition, the technical committee enhanced crew and user safety by including requirements regarding the use of SCBA and PBE. The technical committee also addressed alternative extinguishing agents that could be used in training and onboard aircraft and still meet the set requirements. The requirements around the use and inclusion of halocarbons were reviewed extensively by the committee and many changes have been made to those requirements. The document also has been updated for compliance with the *Manual of Style for NFPA Technical Committee Documents*.

Technical Committee on Aircraft Rescue and Fire Fighting

Robert G. Lindstrom, *Chair*
Pro-Tec Fire Services Ltd., OK [U]
Rep. International Association of Fire Chiefs

Donald R. Austin, Los Angeles City Fire Department,
CA [U]

Keith W. Bagot, U.S. Federal Aviation Administration,
NJ [RT]

Charles Cinquemani, Dallas/Fort Worth International
Airport Board, TX [C]

Rep. Airports Council International – North America

Ralph Colet, JRI Inc., CA [M]

Robert L. Darwin, Hughes Associates, Inc., MD [SE]

Ross A. Davidson, U.S. Department of the Navy, CA [C]

John Demyan, Lehigh-Northampton Airport Authority,
PA [L]

Rep. International Association of Fire Fighters

Robert J. Donahue, Massport Fire Rescue, MA [L]

Fred B. Goodnight, Amerex Corporation, AL [M]

Rep. Fire Equipment Manufacturers' Association

David D. Harris, Lockheed Martin Aeronautics Company,
GA [U]

Owen Healey, United Kingdom Civil Aviation Authority,
United Kingdom [E]

Lawrence M. Krasner, FM Global, MA [I]

Randy J. Krause, The Boeing Company, WA [M]

Madhu Manikkam, Emergency One, Inc., FL [M]

John W. McDonald, U.S. General Services
Administration, VA [E]

Paul S. Meyer, Hartsfield-Jackson Atlanta International
Airport, GA [C]

Gary I. Moorshead, BAA Ltd., United Kingdom [C]

Kevin J. Petit, Akron Brass Company, OH [M]

Pam L. Phillips, Port Authority of New York & New Jersey,
NY [C]

Rep. American Association of Airport Executives

James E. Podolske, Jr., U.S. Air Force, FL [C]

Richard M. Radford, Department of Civil Aviation,
United Arab Emirates [U]

Gary T. Schott, Omaha Airport Authority, NE [L]

Rep. Aircraft Rescue & Fire Fighting Working Group

Terry Seaborn, Oshkosh Corporation, WI [M]

Marc S. Tonnacliff, U.S. Federal Aviation Administration,
DC [E]

Bernard Valois, Transport Canada Civil Aviation,
Canada [E]

Pierre Voisine, Department of National Defence,
Canada [C]

Joseph A. Wright, ARFF Technical Services, Inc., PA [SE]

Alternates

Abdulrahman A. Y. Alsaadi, Department of Civil Aviation,
United Arab Emirates [U]

(Alt. to R. M. Radford)

Alan Black, Dallas/Fort Worth International Airport
Board, TX [C]

(Alt. to C. Cinquemani)

Bradford Colton, American Pacific Corporation, NV [M]

(Alt. to F. B. Goodnight)

Graeme Day, BAA Ltd., United Kingdom [C]

(Alt. to G. I. Moorshead)

George F. Hall, International Fire Associates Consulting,
LLC, FL [C]

(Alt. to J. E. Podolske, Jr.)

Richard L. James, III, Hartsfield-Jackson Atlanta
International Airport, GA [C]

(Alt. to P. S. Meyer)

Jason McMillen, Emergency One, Inc., FL [M]

(Alt. to M. Manikkam)

James F. O'Regan, O'Regan Consulting/JRI, Inc., MA [M]

(Alt. to R. Colet)

Joseph L. Scheffey, Hughes Associates, Inc., MD [SE]

(Alt. to R. L. Darwin)

Nicholas M. Subbotin, U.S. Federal Aviation
Administration, NJ [RT]

(Alt. to K. W. Bagot)

Nonvoting

B. Victor Hewes, Airport Safety Services, GA [SE]
(Member Emeritus)

Thomas J. Lett, Albuquerque Fire & Safety Associates,
NM [SE]

(Member Emeritus)

Kendall Holland, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on aircraft rescue and fire-fighting services and equipment, for procedures for handling aircraft fire emergencies, and for specialized vehicles used to perform these functions at airports, with particular emphasis on saving lives and reducing injuries coincident with aircraft fires following impact or aircraft ground fires. This Committee also shall have responsibility for documents on aircraft hand fire extinguishers and accident prevention and the saving of lives in future aircraft accidents involving fire.

Contents

Chapter 1 Administration	408– 4	4.7 Other Agents	408– 7
1.1 Scope	408– 4	Chapter 5 Distribution of Extinguishers	408– 7
1.2 Purpose	408– 4	5.1 Passenger Aircraft	408– 7
Chapter 2 Referenced Publications	408– 4	5.2 Cargo Aircraft	408– 7
2.1 General	408– 4	5.3 COMBI Aircraft	408– 7
2.2 NFPA Publication	408– 4	Chapter 6 Inspection, Maintenance, and	
2.3 Other Publications	408– 4	Hydrostatic Testing	408– 8
2.4 References for Extracts in Mandatory		6.1 Preflight Inspection	408– 8
Sections	408– 5	6.2 Maintenance	408– 8
Chapter 3 Definitions	408– 5	6.3 Hydrostatic Testing	408– 8
3.1 General	408– 5	Chapter 7 Flight Crew Training	408– 8
3.2 NFPA Official Definitions	408– 5	7.1 General	408– 8
3.3 General Definitions	408– 5	7.2 Classroom/Fire Scenario Instruction	408– 9
Chapter 4 Types and Capacities	408– 6	7.3 Manipulative Skills Training	408– 9
4.1 General	408– 6	7.4 COMBI Aircraft	408– 9
4.2 Water	408– 6	7.5 Recurrent Training and Testing	408– 9
4.3 Halogenated Agents	408– 6	Annex A Explanatory Material	408– 9
4.4 Carbon Dioxide	408– 7	Annex B Informational References	408–11
4.5 Dry Chemical	408– 7	Index	408–13
4.6 Dry Powder	408– 7		

NFPA 408**Standard for****Aircraft Hand Portable Fire Extinguishers****2010 Edition**

IMPORTANT NOTE: *This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.*

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition. Where one or more complete paragraphs have been deleted, the deletion is indicated by a bullet (•) between the paragraphs that remain.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex B. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1 Scope. This standard specifies requirements for the type, capacity, rating, number, location, installation, and maintenance of aircraft hand portable fire extinguishers to be provided for the use of flight crew members or other occupants of an aircraft for the control of incipient fires in the areas of aircraft that are accessible during flight.

1.1.1 This standard also includes requirements for training flight crew members in the use of these extinguishers.

1.1.2 This standard does not cover fire detection and fixed fire-extinguishing systems installed in an aircraft or fire detection and fire-extinguishing systems for the protection of ground maintenance operations.

1.1.3 Specific protection for Class D fires and for fires in hazardous materials is beyond the scope of this standard.

1.2 Purpose. This standard is intended for use by those responsible for selecting, purchasing, installing, approving, and maintaining aircraft hand portable fire extinguishers and for those responsible for training personnel in their use.

1.2.1* The specific requirements established in this standard are intended for the particular environment of an aircraft where fire extinguishment must be the first priority.

1.2.2* Hand portable fire extinguishers have the general purpose of serving as first-aid fire-fighting appliances.

1.2.3 The requirements of Chapters 7 and 8 of NFPA 10, *Standard for Portable Fire Extinguishers*, are applicable to the aviation environment and are supplemental to the specific requirements of this standard.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publication. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2010 edition.

2.3 Other Publications.

2.3.1 FAA Publications. Federal Aviation Administration, 800 Independence Avenue SW, Washington, DC 20591.

DOT/FAA/AR-01/37, "Development of a Minimum Performance Standard for Hand-Held Fire Extinguishers as a Replacement for Halon 1211 on Civilian Transport Category Aircraft," August, 2002.

2.3.2 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096

ANSI/UL 8, *Water Based Agent Fire Extinguishers*, 2005, Revised 2007.

ANSI/UL 154, *Carbon Dioxide Fire Extinguishers*, 2005, Revised 2007.

ANSI/UL 299, *Dry Chemical Fire Extinguishers*, 2007.

ANSI/UL 626, *Water Fire Extinguishers*, 2005, Revised 2007.

ANSI/UL 711, *Rating and Fire Testing of Fire Extinguishers*, 2004, Revised 2007.

UL 1093, *Standard for Halogenated Agent Fire Extinguishers*, 1995, Revised 2008.

UL 1803, *Standard for Factory Follow-up on Third Party Certified Portable Fire Extinguishers*, 2006, Revised 2008.

ANSI/UL 2129, *Standard for Safety Halocarbon Clean Agent Fire Extinguishers*, 2007.

2.3.3 ULC Publications. Underwriters' Laboratories of Canada, 7 Underwriters Road, Toronto, Ontario M1R 3B4, Canada.

CAN/ULC-S503, *Standard for Carbon Dioxide Fire Extinguishers*, 2005, Revised 2007.

CAN/ULC-S504, *Standard for Dry Chemical Fire Extinguishers*, 2005, Revised 2007.

CAN/ULC-S507, *Standard for Water Fire Extinguishers*, 2005, Revised 2007.

CAN/ULC-S508, *Standard for Rating and Fire Testing of Fire Extinguishers*, 2004, Revised 2007.

CAN/ULC-S512, *Standard for Halogenated Agent Hand and Wheeled Fire Extinguishers*, 2007, Reaffirmed 2007.



2.3.4 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Meriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 402, *Guide for Aircraft Rescue and Fire-Fighting Operations*, 2008 edition.

NFPA 410, *Standard on Aircraft Maintenance*, 2010 edition.

NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services*, 2007 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.4* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.5 Shall. Indicates a mandatory requirement.

3.2.6 Should. Indicates a recommendation or that which is advised but not required.

3.2.7 Standard. A document, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an appendix or annex, footnote, or fine-print note and are not to be considered a part of the requirements of a standard.

3.3 General Definitions.

3.3.1 Aircraft.

3.3.1.1 Cargo Aircraft. An aircraft that is configured solely to carry cargo and no personnel other than the flight crew and any additional crew required for the care of the cargo.

3.3.1.2 COMBI. An aircraft designed to transport both passengers and cargo on the same level within the fuselage. [402, 2008]

3.3.1.3 Passenger Aircraft. An aircraft designed for the primary function of carrying passengers.

3.3.2 Aircraft Hand Portable Fire Extinguisher. An approved, portable device that is carried and operated by hand and contains an extinguishing agent that can be expelled under pressure for the purpose of suppressing or extinguishing fire.

3.3.3 Bar. See 3.3.11, Galley.

3.3.4 Buffet. See 3.3.11, Galley.

3.3.5 Cargo/Baggage Compartment. An enclosed compartment within, or attached to, an aircraft fuselage that is separate from the passenger and flight crew areas and that is almost always accessible only from the exterior of the fuselage.

3.3.6 Cockpit. See 3.3.10, Flight Deck.

3.3.7 Extinguisher. See 3.3.2, Aircraft Hand Portable Fire Extinguisher.

3.3.8 Fire Classifications.

3.3.8.1* Class A Fire. A fire in ordinary combustible materials, such as wood, cloth, paper, rubber, and many plastics.

3.3.8.2 Class B Fire. A fire in flammable liquids, combustible liquids, petroleum greases, tars, oils, oil-based paints, solvents, lacquers, alcohols, and flammable gases.

3.3.8.3* Class C Fire. A fire that involves energized electrical equipment where the electrical nonconductivity of the extinguishing media is of importance.

3.3.8.4 Class D Fire. A fire in combustible metals, such as magnesium, titanium, zirconium, sodium, lithium, and potassium.

3.3.9 Flight Crew. Members of the aircraft crew whose responsibilities include the operation and management of the aircraft flight controls, engine(s), and systems, including, but not limited to, pilot in command (captain), first officer (copilot), second officer (flight engineer).

3.3.10* Flight Deck. The area of the aircraft arranged for use of the pilot and flight crew operating the aircraft.

3.3.11* Galley. An area of an aircraft used for storing, refrigerating, heating, and dispensing food and beverages. [410, 2010]

3.3.12* Halogenated Agents. Halogenated agents referenced in this standard are either halons [i.e., bromotrifluoromethane (Halon 1301), bromochlorodifluoromethane (Halon 1211), and mixtures of Halon 1211 and Halon 1301 (Halon 1211/1301)] or halocarbon agents [i.e., hydrochlorofluorocarbon (HCFC), HFC (hydrofluorocarbon), or perfluorocarbon (PFC) based halogenated agents].

3.3.12.1* Halocarbon. A halogenated agent whose chemical name is inclusive of one or more of the following: hydrochlorofluorocarbons (HCFC), hydrofluorocarbon (HFC), or perfluorocarbon (PFC).

3.3.12.2* Halon 1211. A halogenated agent whose chemical name is bromochlorodifluoromethane (CBrClF₂) and that is a multipurpose, Class ABC-rated agent effective against flammable liquid fires.

3.3.12.3* Halon 1301. A halogenated agent whose chemical name is bromotrifluoromethane (CBrF_3) that is recognized as an agent having Class ABC capability in total flooding systems.

3.3.13 Hand Fire Extinguisher. See 3.3.2, Aircraft Hand Portable Fire Extinguisher.

3.3.14* Maximum Certificated Occupant Capacity. The maximum number of persons that can be carried for each specific aircraft model as certified by the authority having jurisdiction.

3.3.15 Protective Breathing Equipment (PBE). Equipment designed to cover the eyes, nose, and mouth of the wearer, or the nose and mouth where accessory equipment is provided to protect the eyes, and to protect the wearer from the effects of smoke, carbon dioxide, or other harmful gases.

3.3.16* Rated/Rating. A numerical value assigned to an extinguisher based on its fire-extinguishing capability.

3.3.17* Self-Contained Breathing Apparatus (SCBA). An atmosphere-supplying respirator that supplies a respirable air atmosphere to the user from a breathing air source that is independent of the ambient environment and designed to be carried by the user. [1981, 2007]

Chapter 4 Types and Capacities

4.1 General.

4.1.1 Hand portable fire extinguishers shall meet or exceed all of the requirements of one of the fire test standards and one of the appropriate performance standards in 4.1.2.

4.1.2 Hand portable fire extinguishers used to comply with this standard shall be listed and labeled and meet or exceed all the requirements of one or more of the applicable fire test standards and one of the applicable performance standards as follows:

- (1) Fire test standards as follows:
 - (a) For halons, halocarbons, carbon dioxide, dry chemical, water, and film-forming foam, use ANSI/UL 711 and CAN/ULC-S508.
 - (b) For halocarbon types for civilian transport category aircraft, use DOT/FAA/AR-01/37.
- (2) Performance standards as follows:
 - (a) For carbon dioxide types, use ANSI/UL 154 and CAN/ULC-S503.
 - (b) For dry chemical types, use ANSI/UL 299 and CAN/ULC-S504.
 - (c) For water types, use ANSI/UL 626 and CAN/ULC-S507.
 - (d) For halon types, use UL 1093 and CAN/ULC-S512.
 - (e) For film-forming foam types, use ANSI/UL 8.
 - (f) For halocarbon types, use ANSI/UL 2129.

4.1.3 Listing and Labeling Organization.

4.1.3.1 Identification of the listing and labeling organization, with ratings and classifications, including the performance standard that the extinguisher meets or exceeds, shall be marked on each extinguisher.

4.1.3.2 An organization that lists, labels, and marks extinguishers used to comply with the requirements of this standard shall utilize a third-party certification program for hand

portable fire extinguishers that meets or exceeds the requirements of UL 1803.

4.1.3.3 The requirement of 4.1.3.2 shall not apply to the following:

- (1) Extinguishers manufactured prior to January 1, 1989
- (2) Certification organizations accredited by the Standards Council of Canada

4.1.4* All aircraft hand portable fire extinguishers shall function as designed by the manufacturer at temperature ranges from -40°C to 49°C (-40°F to 120°F).

4.1.5* Water extinguishers that have a capacity of 2 L (0.53 gal) and that have approval of the authority having jurisdiction shall not be required to be labeled and shall comply with 4.1.1, 4.1.2, 4.1.3, and 4.1.4.

4.2 Water.

4.2.1 Water-based extinguishers shall have a minimum rating of 1-A and shall be equipped with either a spray or straight stream nozzle.

4.2.2 Water-based extinguishers shall not be used on Class B, Class C, or Class D fires.

4.2.3 Cargo compartments shall have one or more water-based extinguishers with a minimum rating of 2-A.

4.2.4 Halogenated agent extinguishers with a minimum rating of 5-B:C can be used in place of required TSO C19 water extinguishers if it can be shown that the halogenated agent extinguisher has comparable or better Class A performance.

4.3 Halogenated Agents.

4.3.1* General.

4.3.1.1 Halogenated agents specified in this standard shall be used in hand portable fire extinguishers in aircraft.

4.3.1.2 Halocarbon extinguishers shall be not less than the quantity required to achieve a 5-B:C rating and conform with the requirements specified in DOT/FAA/AR-01/37 (see 4.1.2).

4.3.2* Halon 1211 and Halocarbon Agent Extinguishers.

4.3.2.1 Occupied Spaces.

4.3.2.1.1* For occupied spaces on aircraft, Halon 1211 extinguishers shall be not less than 1.2 kg (2.5 lb) capacity nor more than 2.3 kg (5 lb) capacity.

4.3.2.1.1.1 The extinguishers specified in 4.3.2.1.1 shall have a minimum rating of 5-B:C, shall have not less than an 8-second discharge time, shall have not less than a 3 m (10 ft) liquid range, and shall be permitted to be equipped with a discharge hose.

4.3.2.1.2* For occupied spaces on small aircraft only, with a maximum certificated occupant capacity of one to four persons including the pilot, a Halon 1211 or halocarbon extinguisher with a minimum rating of 2-B:C shall be permitted to be used.

4.3.2.2 For accessible cargo compartments of COMBI aircraft and cargo aircraft, Halon 1211 extinguishers shall be not less than 5.9 kg (13 lb) capacity and shall have a minimum rating of 2-A:40-B:C.



4.3.2.2.1 Halocarbon extinguishers with a comparable minimum rating shall be permitted in the application outlined in 4.3.2.2.

4.3.2.3* The total Halon 1211 agent present in all extinguishers in any single compartment, if discharged simultaneously, shall be capable of producing a concentration not greater than 2 percent by volume at 49°C (120°F) in the compartment.

4.4 Carbon Dioxide.

4.4.1 For occupied spaces on aircraft, carbon dioxide (CO₂) extinguishers shall not be used.

4.4.2 For cargo compartments of COMBI aircraft and cargo aircraft, CO₂ extinguishers shall not be used.

4.5 Dry Chemical.

4.5.1* For occupied spaces on aircraft, dry chemical extinguishers shall not be used.

4.5.2 For cargo compartments of COMBI aircraft and cargo aircraft, dry chemical extinguishers shall be not less than 4.5 kg (10 lb) capacity and shall have a minimum rating of 2-A:40-B:C.

4.6 Dry Powder.

4.6.1* For occupied spaces on aircraft, dry powder extinguishers for Class D fires shall not be used.

4.6.2 For accessible cargo compartments of COMBI aircraft and cargo aircraft, dry powder extinguishers for Class D fires shall be permitted to be provided in addition to required extinguishers specified in 5.2.2.

4.7 Other Agents. Hand portable fire extinguishers carrying non-halogenated-type agents that were developed to replace halon shall be listed and labeled.

Chapter 5 Distribution of Extinguishers

5.1 Passenger Aircraft.

5.1.1 Aircraft hand portable fire extinguishers shall be placed in occupied spaces on aircraft as specified in Table 5.1.1.

5.1.2 Where an extinguisher other than a water extinguisher is located within 1.5 m (5 ft) of, and on the same floor level as, a galley opening, an additional extinguisher shall not be required for the galley.

5.1.3 Where distances between extinguishers, as measured by standard aisle travel, exceed 18 m (60 ft), extinguishers in addition to those required by Table 5.1.1 shall be provided so that no travel distance to an extinguisher exceeds 9 m (30 ft).

5.1.4 Where aircraft passenger compartments, galleys, or lounge areas are on a separate level, such compartments or areas shall have extinguishers in accordance with Table 5.1.1.

5.1.5 Extinguishers in passenger compartments shall be immediately accessible, mounted for quick removal, and installed on bulkheads wherever possible.

5.1.5.1 Where installation is necessary in overhead storage spaces, extinguishers shall be located so that carry-on luggage cannot interfere with extinguisher accessibility.

5.1.5.2 Extinguisher locations shall be marked and shall be visible to occupants of the compartment.

5.1.6 Personal Breathing Equipment.

5.1.6.1 Personal breathing equipment (PBE) approved and maintained as specified by the authority having jurisdiction shall be provided.

5.1.6.2 The PBE shall be provided within 0.9 m (3 ft) laterally of all hand portable fire extinguishers.

5.2 Cargo Aircraft.

5.2.1 Occupied Spaces on Aircraft. The flight deck of cargo aircraft shall be provided with one halogenated agent extinguisher.

5.2.2 Cargo Compartment.

5.2.2.1 Where fixed extinguishing systems provide protection for the entire cargo compartment(s), or where the cargo compartment(s) is not accessible during flight, hand portable fire extinguishers shall not be required for the cargo compartment(s).

5.2.2.2* Where fixed extinguishing systems do not provide protection for the entire cargo compartment(s), the number of extinguishers, quantity of extinguishing agent, and ratings shall be in accordance with 4.3.2.2.

5.2.2.2.1 The hand portable fire extinguisher specified in 5.2.2.2 shall be located and accessible inside the cargo compartment at the interior access entry.

5.2.2.2.2 Any additional hand portable fire extinguishers provided for cargo compartment use shall also be located in the cargo compartment.

5.2.2.3 Self-Contained Breathing Apparatus.

5.2.2.3.1 A self-contained breathing apparatus (SCBA), approved and maintained as specified by the authority having jurisdiction, with a minimum rated service life of 15 minutes and equipped with a full facepiece shall be provided.

5.2.2.3.2 The SCBA shall be accessible in a marked location outside the cargo compartment positioned adjacent to the access entry point.

5.3 COMBI Aircraft.

5.3.1 Aircraft hand portable fire extinguishers shall be placed in the flight deck, passenger cabin, and cargo compartment on aircraft as specified in Table 5.1.1.

5.3.2 Where an extinguisher other than a water extinguisher is located within 1.5 m (5 ft) of, and on the same floor level as, a galley opening, an additional extinguisher shall not be required for the galley.

5.3.3 The minimum number of hand portable fire extinguishers necessary for the cargo compartment shall be as specified in Table 5.1.1.

5.3.4 Hand portable fire extinguishers shall be placed adjacent to the entrance door of the passenger deck (cargo compartment) and adjacent to the rear exit door of the aircraft.

5.3.5 Hand portable fire extinguishers shall be provided in the flight crew rest facilities.

Table 5.1.1 Distribution of Extinguishers in Occupied Spaces on Aircraft

Maximum Certificated Occupant Capacity	Number of Extinguishers	Type of Extinguisher	Location
1–4 (including pilot)	1	Halogenated agent (<i>see 4.3.2.1.2, 4.3.2.3</i>)	Within reach of seated pilot
5–30	1	Halogenated agent	Within reach of seated pilot
	1	Halogenated agent	Cabin
31–60	1	Halogenated agent	Flight deck
	2	One water and one halogenated agent	Cabin
	1	Halogenated agent	Each galley*
61–120	1	Halogenated agent	Flight deck
	3	One water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
121–200	1	Halogenated agent	Flight deck
	4	Two water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
201–275	1	Halogenated agent	Flight deck
	5	Two water and three halogenated agents	Cabin
	1	Halogenated agent	Each galley*
276–400	1	Halogenated agent	Flight deck
	8	Four water and four halogenated agents	Cabin
	1	Halogenated agent	Each galley*
>400	1	Halogenated agent	Flight deck
	10	Five water and five halogenated agents	Cabin
	1	Halogenated agent	Each galley*
COMBI aircraft wide-body	1	Halogenated agent	Flight deck
	5	Two water and three halogenated agents	Cabin
	1	Halogenated agent	Each galley*
	6	Four halogenated agents and two water	Cargo (passenger level)
COMBI aircraft narrow-body	1	Halogenated agent	Flight deck
	4	Two water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
	4	Two halogenated agents and two water	Cargo (passenger level)

*See 5.1.2.

Chapter 6 Inspection, Maintenance, and Hydrostatic Testing

6.1 Preflight Inspection.

6.1.1 One or more members of the flight crew shall make a preflight inspection of all extinguishers.

6.1.2 The inspection shall determine that all required extinguishers are provided, prepared for use, in the assigned location, and secured.

6.1.3 Where provided, extinguisher pressure gauges shall indicate pressure, and seals and seal wires shall not be broken.

6.2 Maintenance.

6.2.1 Extinguishers shall be maintained in accordance with Chapter 7 of NFPA 10, *Standard for Portable Fire Extinguishers*, and records shall be kept in accordance with those requirements.

6.2.2 Recharging procedures shall follow the requirements of Chapter 7 of NFPA 10, *Standard for Portable Fire Extinguishers*.

6.2.3 Extinguishers that are out of service for maintenance or recharge shall be replaced with extinguishers having the same agent, rating, and operating procedure.

6.3 Hydrostatic Testing. Extinguisher shells and appurtenant devices such as nozzles, hoses, and pressure cartridges shall be hydrostatically tested in accordance with Chapter 8 of NFPA 10, *Standard for Portable Fire Extinguishers*.

Chapter 7 Flight Crew Training

7.1 General.

7.1.1 Initially, before assignment, and at least annually thereafter, flight crew members shall receive theoretical and practical training in the basics of fire extinguishment.



7.1.1.1 Instruction on location and use of hand portable fire extinguishers on the aircraft for which flight crew members will be qualified shall be provided.

7.1.2 Training shall be conducted by instructors who are knowledgeable of the aircraft environment and experienced in the extinguishment of fire using hand portable fire extinguishers.

7.1.3 Training shall include the following:

- (1) Classroom instruction
- (2) Practical use of hand portable fire extinguishers
- (3) Extinguishment of a hot fire
- (4) Movement in a smoke-filled environment
- (5) Wearing of PBE, within a replica of an aircraft cabin environment
- (6) Wearing of SCBA (where required), within a replica of an aircraft cargo cabin environment

7.1.3.1 Halon shall not be discharged during training, as per 7.3.3.3.

7.1.3.2* Halocarbon extinguishers shall be permitted to be discharged during training, unless restricted by the authority having jurisdiction.

7.2* Classroom/Fire Scenario Instruction.

7.2.1 Classroom instruction concerning all types of extinguishers discussed in this standard shall be given to flight crews and shall include the following topics as a minimum:

- (1) Chemistry of fire and fire extinguishment
- (2) Severity potential of aircraft fires
- (3) Types of combustibles present in aircraft
- (4) Identification and choice of correct extinguisher
- (5) Consequences of misapplication of extinguishers
- (6) Usefulness of extinguishers
- (7) Inspection requirements
- (8) Health and operational safety concerns

7.2.2 Practical Smoke Training. On aircraft types in which it is provided, training shall be given on the use of appropriate PBE and SCBA (where provided) when using an extinguisher in a simulated smoke-filled environment.

7.3 Manipulative Skills Training.

7.3.1 Training shall include each flight crew member demonstrating operation and use of hand portable extinguishers.

7.3.2 Training shall be representative of an interior aircraft fire, using the relevant type of hand portable fire extinguishers carried on the aircraft.

7.3.3* Each flight crew member shall demonstrate the knowledge and skill required to select the appropriate hand portable fire extinguisher for various fire scenarios and to properly apply the agent.

7.3.3.1 The overall training plan shall include representative aircraft fires of Class A, B, and C, as well as combined Class A and B fires.

7.3.3.2 Fire scenarios shall include galley, lavatory or closed compartment, flight deck, open cabins, and flammable liquid fires.

7.3.3.3 Extinguishers containing halon shall not be discharged during routine manipulative skills training.

7.3.3.4 Substitutes shall be permitted to be used for training with the approval of the authority having jurisdiction.

7.3.3.5 Any alternative agent approved by the authority having jurisdiction shall be listed and labeled.

7.4* COMBI Aircraft.

7.4.1 The following items shall form the basis of the required course of instruction for flight crew involving COMBI aircraft operations:

- (1) Explanation of fire risks with COMBI operations
- (2) Chemistry of fire
- (3) Theory of extinguishing agents
- (4) Aircraft layout
- (5) Cargo loading requirements
- (6) Hazardous cargo consignments
- (7) Scale of COMBI fire-fighting equipment (*see Table 5.1.1*)
- (8) Designated fire fighter duties including the following:
 - (a) Preflight audit
 - (b) Inflight inspection
 - (c) Fire control techniques
 - (d) Postfire information feedback
- (9) Practical demonstration and use of hand portable fire extinguishers
- (10) Practical exercises involving simulated fire situations

7.4.2 The facility used for training flight crews shall be representative of actual fire conditions and include the following:

- (1) An enclosed environment in which the trainee experiences the effects of fire and heat
- (2) A demonstration of the effectiveness of fire extinguishers when correctly applied to an actual fire
- (3) A facility in which to demonstrate an electrical fire
- (4) An exercise that includes dressing in the protective clothing and PBE provided onboard the aircraft and entering a simulated smoke-filled environment carrying a hand portable fire extinguisher as carried on the aircraft

7.5 Recurrent Training and Testing.

7.5.1* Recurrent training shall include discussions on recent onboard aircraft fire incidents.

7.5.2 Recurrent training shall be provided at intervals not exceeding 3 years.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.2.1 In an aircraft fire, the integrity of the aircraft must be preserved and the flight crew must retain their physiological ability to fly the airplane (e.g., vision and consciousness). The overall threat to life must be held at the lowest possible level.

A.1.2.2 Additional information on the effectiveness and suitability of various aircraft hand portable fire extinguishers can be found in DOT/FAA/CT-82/42. Information regarding halocarbon extinguishers can be found in both NFPA 10, *Standard for Portable Fire Extinguishers*, and DOT/FAA/AR-01/37.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having

jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.2.4 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

A.3.3.8.1 Class A Fire. European fire class designations are as follows:

- (1) Class A — Wood, paper, cloth, and so forth
- (2) Class B — Flammable liquids
- (3) Class C — Flammable gases
- (4) Class D — Metal fires
- (5) Class E — Electrical fires
- (6) Class F — Cooking appliances

The classification of fire extinguishers consists of one or more capital letters that indicate the classes of fire on which an extinguisher has been found to be effective. The letters (A and B only) are preceded by a rating number that indicates the relative extinguishing effectiveness.

European nations use European Standard EN 3-7 (2004:E) to classify types of fires and establish test methods to assign performance ratings to fire extinguishers. It should be noted that European fire extinguisher numerical ratings and fire configurations differ from those in ANSI/UL 711.

It should be noted that European fire extinguisher ratings are not comparable with U.S. or Canadian ratings. In the United Kingdom, the applicable standards are British Standard 5306, Part 3, and British Standard 5423.

A.3.3.8.3 Class C Fire. When electrical equipment is de-energized, fire extinguishers for Class A or B fires can be used safely.

A.3.3.10 Flight Deck. Berths, galleys, and lavatory facilities can be associated with the flight crew compartment but are not included in the term *flight deck*.

A.3.3.11 Galley. Such areas typically include areas for plastic trays, plastic dinnerware utensils, and paper napkins.

A.3.3.12 Halogenated Agents. Halon 1211 and Halon 1301 are included in the Montreal Protocol on Substances that Deplete the Ozone Layer signed September 16, 1987. The 1992 amendments to the protocol called for a cessation of production of Halon 1211 and Halon 1301 worldwide.

A.3.3.12.1 Halocarbon. These agents are multipurpose Class ABC-rated. The physical properties for these agents vary, and some will discharge as a mixed liquid and vapor stream while others will discharge primarily as a vapor.

Halocarbon agents that are approved for onboard aircraft use have various physical properties that impact throw range and fire-fighting technique, and are as follows:

- (1) HCFC Blend B is an extinguishing agent that is a tertiary blend comprised primarily of the chemical 2,2-dichloro-1,1,1-trifluoroethane HCFC-123 (CF_3CHCl_2). The boiling point of the blend is 80.6°F (27°C). Due to its high boiling point, HCFC Blend B discharges primarily as a liquid stream that readily evaporates.
- (2) HFC-227ea is an extinguishing agent that is comprised of the chemical 1,1,1,2,3,3,3-heptafluoropropane (CF_3CHCF_3). The boiling point of the agent is 2.5°F (-16.4°C). Due to this boiling point, HFC-227ea is discharged as a mixed liquid and vapor stream that readily evaporates.
- (3) HFC-236fa is an extinguishing agent that is comprised of the chemical 1,1,1,3,3,3-hexafluoropropane ($\text{CF}_3\text{CH}_2\text{CF}_3$). The boiling point of the agent is +29.5°F (-1.4°C). Due to its relatively high boiling point, HFC-236a discharges predominantly as a liquid stream that readily evaporates.

A.3.3.12.2 Halon 1211. Due to its relatively high boiling point of 4°C (25°F), Halon 1211 discharges as an 85 percent liquid stream, offering long agent throw range.

A.3.3.12.3 Halon 1301. Halon 1301 offers limited Class A capability when used in hand portable fire extinguishers.

A.3.3.14 Maximum Certificated Occupant Capacity. In the United States, the authority having jurisdiction is the Federal Aviation Administration.

A.3.3.16 Rated/Rating. The rating is required to be in accordance with ANSI/UL 711.

A.3.3.17 Self-Contained Breathing Apparatus (SCBA). This device provides protection for the face and eyes as well as has suitable strapping or ties for donning the devices and 15 minutes of air supply. [1981, 2007]

A.4.1.4 Aircraft hand portable fire extinguishers must perform in an environment substantially more varied and more critical than those approved for use in most land surface applications. Design considerations for extinguisher body, valves, fittings, and associated hardware, including mounting brackets, also should include pressure variations, positive and negative accelerations, vibration, corrosion, and ambient temperature variations.

A.4.1.5 In the United States, the authority having jurisdiction is the Federal Aviation Administration. The AHJ in Europe is the Joint Aviation Authority, and the AHJ in Canada is Transport Canada.

A.4.3.1 Exposure to decomposed halogenated agents could produce varied central nervous system effects, depending on exposure concentration and time. Halogenated agents also



decompose into products of greater toxicity when subjected to flame or to hot surfaces at approximately 482°C (900°F). See NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, for detailed information.

The expected potential exposure of decomposition products resulting from the application of approved halocarbon agent extinguishers to flames or hot surfaces was also addressed and found to be within acceptable limits in DOT/FAA/AR-01/37.

A.4.3.2 Halon 1211 extinguishers have their greatest effectiveness on Class B and Class C fires. Extinguishers with 4 kg (9 lb) or greater capacity also are rated for Class A fires. Extinguishers with capacity of less than 4 kg (9 lb), although not rated for use on Class A fires, have been shown to be effective in extinguishing surface Class A fires.

A.4.3.2.1.1 Halon 1211 extinguishers of less than 4 kg (9 lb) capacity are not always furnished with a discharge hose. However, for access to underseat, overhead, and other difficult-to-reach locations, consideration should be given to using extinguishers with a discharge hose of a minimum length of 304 mm (12 in.). Also, an extinguisher with a discharge hose is more likely to be properly held in an upright position during use.

A.4.3.2.1.2 For occupied spaces on small aircraft where natural state halon concentrations will be approaching allowable limits, Halon 1301 is preferred over Halon 1211 for the following reasons:

- (1) Halon 1211 decomposes when exposed to flame, producing some toxic products of decomposition that are not produced by Halon 1301 and is, therefore, also considered more toxic in the decomposed state.
- (2) The following health and safety advantages associated with similar-volume occupied spaces on larger aircraft (flight decks) do not usually exist for the smaller aircraft:
 - (a) Forced ventilation system
 - (b) Availability of oxygen masks
 - (c) Availability of a second individual capable of flying the aircraft

A.4.3.2.3 Halocarbon extinguisher toxicity has been demonstrated by Federal Aviation Administration (FAA) modeling and test procedures to be no greater than that of Halon 1211 based on agent quantities discharged to meet the requirements for fire test standards ANSI/UL 711 and DOT/FAA/AR-01/37 (see 4.1.2).

A.4.5.1 Dry chemical agent causes visibility problems in occupied spaces and potentially severe contamination of aircraft electrical components.

A.4.6.1 Dry powder agent causes visibility problems in occupied spaces and potentially severe contamination of aircraft electrical components.

A.5.2.2.2 The hose or wand provides effective reach of the contents of the extinguisher to any part of the cargo.

A.7.1.3.2 Since the ban on the use of Halon 1211 during training, many organizations have switched from teaching employees how to use the actual agent available to them onboard the aircraft. Approved halon alternatives can be discharged for training, which should improve the training being offered as well as the outcome of in-flight fire events. Additionally, the fire-fighting technique for each halocarbon agent is different due to the physical property differences, and it is important the employee understands these differences when fighting a fire.

A.7.2 Discussion of health and safety aspects should include hazards and warnings concerning toxicity of combustion products, as well as the effects of short-, intermediate-, and long-term exposure to the undecomposed agents.

A.7.3.3 Live fire training on representative aircraft fires is highly recommended for all flight crew members during both initial and recurrent training sessions. Live fire training provides flight crews with psychological conditioning, fire-fighting techniques, and knowledge of extinguishing agent capabilities and limitations under actual fire situations. The live fires used should be the scenarios required in 7.3.3.2.

Training should cover FAA Advisory Circular AC 120-80, which discusses the hazards of in-flight fires, including hidden fires, and how to effectively handle these events. While this advisory circular focuses on halon extinguishers, the information will also pertain to halocarbon agents.

A.7.4 On completion of the course, flight deck crews and flight attendants should be confident about the procedures and practical use of equipment while working under conditions of smoke and heat. Numbers of personnel receiving training at any one time should be limited in order to ensure that each individual receives adequate practical experience and that his or her performance can be assessed by instructional staff.

A.7.5.1 These discussions are particularly important when crews are assigned to more than one aircraft type.

Annex B Informational References

B.1 Referenced Publications. The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

B.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2010 edition.

NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 2009 edition.

B.1.2 Other Publications.

B.1.2.1 BSI Publications. British Standards Institute, 389 Chiswick High Road, London, W4 4AL, United Kingdom.

British Standard 5306, Part 3, *Code of Practice for Selection, Installation, and Maintenance of Portable Fire Extinguishers*.

British Standard 5423, *Specification for Portable Fire Extinguishers*.

B.1.2.2 European Publications. European Committee for Standardization, Management Centre, Rue de Stassart, 30 B-1050 Brussels.

European Standard EN 3-7 (2004 E), *Portable Fire Extinguishers — Part 7: Characteristics, Performance Requirements and Test Methods*.

B.1.2.3 FAA Publications. Federal Aviation Administration, 800 Independence Avenue SW, Washington, DC 20591.

FAA Advisory Circular AC 120-80, "In-Flight Fires," 2004.

DOT/FAA/AR-01/37, "Development of a Minimum Performance Standard for Hand-Held Fire Extinguishers as a Replacement for Halon 1211 on Civilian Transport Category Aircraft," August, 2002.

DOT/FAA/CT-82/42, "Study of Hand-Held Fire Extinguishers Aboard Civil Aviation Aircraft," L. M. Krasner, Final Report, June, 1982. Available from FM Global Research, 1301 Atwood Avenue, P.O. Box 7500, Johnston, RI 02919.

B.1.2.4 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 711, *Safety Rating and Testing of Fire Extinguishers*, 2007.

B.2 Informational References. The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

B.2.1 FAA Publications. Federal Aviation Administration, 800 Independence Avenue SW, Washington, DC 20591.

Advisory Circular 20-42C, "Hand Fire Extinguishers for Use in Aircraft," 1984.

DOT/FAA/CT-83/30, "Extinguisher Agent Behavior in a Ventilated Small Aircraft," 1984.

DOT/FAA/CT-86/5, "Halon Extinguisher Agent Behavior in a Ventilated Small Aircraft," 1986.

DOT/FAA/CT-86/26, "Halon Extinguishment of Small Aircraft Instrument Panel Fires," 1986.

DOT/FAA/CT-89/31, "Smoke and Extinguisher Agent Dissipation in a Small Pressurized Fuselage," 1990.

B.2.2 U.S. Government Publications. Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

Military Specification for Halon 1211, MIL-B-38741.

Military Specification for Halon 1301, MIL-M-12218C.

B.2.3 Other Publications. "The Development of a Hidden Fire Test for Aircraft Hand Extinguisher Applications," CAA Paper 95013, Kidde International.

"Modeling Cardiac Sensitization of Humans Exposed to Halon 1301 or Halon 1211 Aboard Aircraft," *Aviation, Space, and Environmental Medicine*, Vol. 72, No. 10, October 2001.

"Test and Evaluation of Halon 1211 Hand-Portable Fire Extinguishers for Use in Habitable and Cargo Compartments of USAF Aircraft," J. Walker and R. N. Vickers, Final Report, November, 1981, Engineering Services Laboratory, Air Force Engineering and Services Center, Tyndall Air Force Base; Report Number ESL-TR-81-22.

B.3 References for Extracts in Informational Sections. NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services*, 2007 edition.



Index

Copyright © 2009 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

-A-	
Administration	Chap. 1
Purpose	1.2
Scope.....	1.1
Aircraft	
Cargo Aircraft	
Definition.....	3.3.1.1
COMBI	
Definition.....	3.3.1.2
Definition.....	3.3.1
Passenger Aircraft	
Definition.....	3.3.1.3
Aircraft Hand Portable Fire Extinguisher	
Definition.....	3.3.2
Approved	
Definition	3.2.1, A.3.2.1
Authority Having Jurisdiction (AHJ)	
Definition	3.2.2, A.3.2.2
-B-	
Bar	
Definition.....	3.3.3
Buffet	
Definition.....	3.3.4
-C-	
Cargo/Baggage Compartment	
Definition.....	3.3.5
Cockpit	
Definition.....	3.3.6
-D-	
Definitions	Chap. 3
Distribution of Extinguishers	Chap. 5
Cargo Aircraft	5.2
Cargo Compartment	5.2.2
Self-Contained Breathing Apparatus.....	5.2.2.3
Occupied Spaces on Aircraft.....	5.2.1
COMBI Aircraft	5.3
Passenger Aircraft.....	5.1
Personal Breathing Equipment.....	5.1.6
-E-	
Explanatory Material	Annex A
Extinguisher	
Definition.....	3.3.7
-F-	
Fire Classifications	
Class A Fire	
Definition	3.3.8.1, A.3.3.8.1
Class B Fire	
Definition.....	3.3.8.2
Class C Fire	
Definition	3.3.8.3, A.3.3.8.3
Class D Fire	
Definition.....	3.3.8.4
Definition.....	3.3.8
Flight Crew	
Definition.....	3.3.9
Flight Crew Training	
Classroom/Fire Scenario Instruction	7.2, A.7.2
Practical Smoke Training	7.2.2
COMBI Aircraft	7.4, A.7.4
General	7.1
Manipulative Skills Training	7.3
Recurrent Training and Testing.....	7.5
Flight Deck	
Definition.....	3.3.10, A.3.3.10
-G-	
Galley	
Definition.....	3.3.11, A.3.3.11
-H-	
Halogenated Agents	
Definition.....	3.3.12, A.3.3.12
Halocarbon	
Definition	3.3.12.1, A.3.3.12.1
Halon 1211	
Definition	3.3.12.2, A.3.3.12.2
Halon 1301	
Definition	3.3.12.3, A.3.3.12.3
Hand Fire Extinguisher	
Definition	3.3.13
-I-	
Informational References	Annex B
Inspection, Maintenance, and Hydrostatic Testing	Chap. 6
Hydrostatic Testing	6.3
Maintenance	6.2
Preflight Inspection.....	6.1
-L-	
Labeled	
Definition.....	3.2.3
Listed	
Definition	3.2.4, A.3.2.4
-M-	
Maximum Certificated Occupant Capacity	
Definition.....	3.3.14, A.3.3.14
-P-	
Protective Breathing Equipment (PBE)	
Definition	3.3.15
-R-	
Rated/Rating	
Definition.....	3.3.16, A.3.3.16
Referenced Publications	
General	2.1
NFPA Publication	2.2
Other Publications.....	2.3
References for Extracts in Mandatory Sections	2.4