

**NFPA<sup>®</sup>**

# 601

---

Standard for  
Security Services in  
Fire Loss Prevention

---

**2020**



## IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

### REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

### REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at [www.nfpa.org](http://www.nfpa.org).

## **ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS**

### **Updating of NFPA Standards**

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at [www.nfpa.org](http://www.nfpa.org).

### **Interpretations of NFPA Standards**

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

### **Patents**

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

### **Law and Regulations**

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### **Copyrights**

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

### **For Further Information**

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: [stds\\_admin@nfpa.org](mailto:stds_admin@nfpa.org).

For more information about NFPA, visit the NFPA website at [www.nfpa.org](http://www.nfpa.org). All NFPA codes and standards can be viewed at no cost at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo).

Copyright © 2019 National Fire Protection Association®. All Rights Reserved.

## NFPA® 601

### Standard for

## Security Services in Fire Loss Prevention

### 2020 Edition

This edition of NFPA 601, *Standard for Security Services in Fire Loss Prevention*, was prepared by the Technical Committee on Loss Prevention Procedures and Practices. It was issued by the Standards Council on November 4, 2019, with an effective date of November 24, 2019, and supersedes all previous editions.

This edition of NFPA 601 was approved as an American National Standard on November 24, 2019.

### Origin and Development of NFPA 601

The text dates from 1925 when the NFPA Committee on Field Practice presented a set of advisory rules called *The Watchman*, which was adopted and published by the NFPA and reprinted in 1930, 1936, and 1949. Jurisdiction for the publication was transferred in 1948 to the Committee on Fire Brigades and Watchmen, which presented revisions under the title *The Watchman, Recommended Manual of Instruction and Duties for the Plant Watchman or Guard*, which was adopted in 1951. Further amendments were adopted in 1956. In 1968, NFPA 601 was revised under the title *Recommendations for Guard Service in Fire Loss Prevention*. It was at this time that NFPA 601A, *Standard for Guard Operations in Fire Loss Prevention*, was published as a separate standard.

In 1969, the committee was reorganized as the Technical Committee on Loss Prevention Procedures and Practices.

NFPA 601 was revised in 1969, 1975, 1981, and 1986, and NFPA 601A was revised in 1981. In 1986 NFPA 601A was reconfirmed and redesignated NFPA 602.

In 1992, NFPA 601 incorporated NFPA 602 for the benefit of the user.

In 1995, the standard was completely revised to reflect modern security methods, terminology, and techniques.

Changes for the 2000 edition were primarily editorial or were made for clarification.

The 2005 edition was updated to conform to the *Manual of Style for NFPA Technical Committee Documents*. Changes were primarily editorial, including revisions to several definitions for correlation with the Glossary of Terms.

The 2010 edition represented a reconfirmation of the technical requirements in the standard. Minor editorial changes were included for consistency with the *Manual of Style for NFPA Technical Committee Documents*.

The 2015 edition included some minor editorial changes and updates to the list of hazards that security personnel may have encountered, such as impairments to fire protection systems and hot work.

In the 2020 edition, new language was added to the definition for *fire loss prevention plan* that includes guidance for developing parameters for a site-specific plan.

New guidance was provided in Chapter 5 for security officers who observe hazardous areas remotely. The language was updated to reflect flexibility for stakeholders when they are setting security rounds for special or exceptional hazards that may exist on a premises. Electronic access control gates will be required to be in compliance with applicable standards in order to provide direction and ensure reliability. Security officers shall not report for duty under the influence of alcohol, drugs, or other impairing substances per the management's code of conduct.

Management will provide applicants with the necessary skills, abilities, and information they need to protect their facilities from fire hazards. Section 6.6, General Conduct of Security Officers, was expanded to include language prohibiting the use of illegal drugs while on duty, in order to clarify what is and what is not allowed during a work shift. In the event of an incident on the premises, security officers will not be allowed release information to the public regarding the incident in order to protect stakeholders from potential erroneous multimedia dissemination.

Chapter 8 was expanded to include language that requires security officers be provided with the contact information of vendors and contractors providing emergency response services for the premises, so that they can be contacted directly by security as needed.

## Technical Committee on Loss Prevention Procedures and Practices

**Joseph A. Cocciardi**, *Chair*

Cocciardi and Associates, Inc., PA [SE]  
Rep. Commonwealth of Pennsylvania

**Paul H. Aube**, Termont, Canada [SE]

**George J. Browne**, TUV SUD America Inc./Global Risk Consultants Corporation, NJ [SE]

**Thomas L. Caisse**, FM Global, RI [I]

**Gary L. Guenette**, Johnson Controls, WI [M]

**Edward M. Hawthorne**, Shell Oil Company, TX [U]

**Haruki Howell**, McKee Foods Corporation, TN [U]

**Jeff Kling**, Arconic Davenport Works, IA [M]

**Ryan Ludwick**, Hemlock Semiconductor Corporation, MI [U]

**John Richard Lussi**, Talen Energy, PA [U]

**Jeff Martin**, Elite Fire Protection, Canada [IM]

Rep. National Association of Fire Equipment Distributors

**Kevin Phelan**, Liberty Mutual Insurance, NH [I]

**Craig P. Remsburg**, Telgian Corporation, AZ [SE]

**Jeffrey L. Robinson**, Robinson Risk Consulting, LLC, SC [SE]

**Robert H. Stagg**, Guardsmark, LLC, NC [SE]

**Jason Steele**, Tennessee Valley Authority, AL [U]

**Dariusz Szwarc**, US Nuclear Regulatory Commission, IL [E]

**Jeff Thomas**, State Farm Insurance, IL [I]

**Paul Valentine**, TUV SUD America Inc./Global Risk Consultants, IL [M]

Rep. International Fire Service Training Association

**Randal Wakeman**, Nuclear Service Organization (NSO), DE [I]

### Alternates

**Warren Burns**, Telgian Corporation, AZ [SE]

(Alt. to Craig P. Remsburg)

**Michael M. Dillon**, JENSEN HUGHES, IL [M]

(Alt. to Paul Valentine)

**Jennifer E. Morris**, McKee Foods Corporation, TN [U]

(Alt. to Haruki Howell)

**Richard Philbrick**, Shell Oil Company, TX [U]

(Alt. to Edward M. Hawthorne)

**Theodore K. Pisciotta**, FM Global, CT [I]

(Alt. to Thomas L. Caisse)

**Atif Shaikh**, Nuclear Regulatory Commission, IL [E]

(Alt. to Dariusz Szwarc)

**Barry Lynn Snook**, Snook Consulting, OH [SE]

(Alt. to Jeffrey L. Robinson)

**Michael John Stanley**, Nuclear Service Organization (NSO), DE [I]

(Alt. to Randal Wakeman)

**Ray A. Webber**, The Procter & Gamble Company, OH [U]

(Voting Alt.)

**John A. Welling, III**, Bristol-Myers Squibb Company, NJ [U]

(Voting Alt.)

### Nonvoting

**William R. Hamilton**, US Department of Labor, DC [E]

**Stanford E. Davis**, Hunlock Creek, PA [SE]

(Member Emeritus)

**Debra M. Gursha**, NFPA Staff Liaison

*This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.*

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

**Committee Scope:** This Committee shall have primary responsibility for documents on fire brigades, guard services, and techniques for securing effective fire loss prevention programs in industrial, commercial, institutional, and similar properties.

## Contents

<b>Chapter 1 Administration</b> .....	<b>601- 5</b>	5.5 Fire Protection Function of Security. ....	<b>601- 7</b>
1.1 Scope. ....	<b>601- 5</b>	5.6 General Duty Requirements. ....	<b>601- 7</b>
1.2 Purpose. ....	<b>601- 5</b>	5.7 Reports. ....	<b>601- 7</b>
<b>Chapter 2 Referenced Publications</b> .....	<b>601- 5</b>	<b>Chapter 6 Selection and Conduct of Security Officers</b> .....	<b>601- 7</b>
2.1 General. ....	<b>601- 5</b>	6.1 Character Investigation. ....	<b>601- 7</b>
2.2 NFPA Publications. ....	<b>601- 5</b>	6.2 Skills and Ability. ....	<b>601- 7</b>
2.3 Other Publications. ....	<b>601- 5</b>	6.3 Criminal Convictions. ....	<b>601- 7</b>
2.4 References for Extracts in Mandatory Sections. ....	<b>601- 5</b>	6.4 Contract Service. ....	<b>601- 7</b>
<b>Chapter 3 Definitions</b> .....	<b>601- 5</b>	6.5 Medical Requirements. ....	<b>601- 7</b>
3.1 General. ....	<b>601- 5</b>	6.6 General Conduct of Security Officers. ....	<b>601- 8</b>
3.2 NFPA Official Definitions. ....	<b>601- 5</b>	<b>Chapter 7 Training and Education</b> .....	<b>601- 8</b>
3.3 General Definitions. ....	<b>601- 6</b>	7.1 General. ....	<b>601- 8</b>
<b>Chapter 4 Management Responsibilities</b> .....	<b>601- 6</b>	7.2 Site-Specific Knowledge. ....	<b>601- 8</b>
4.1 General Responsibilities. ....	<b>601- 6</b>	<b>Chapter 8 Communications</b> .....	<b>601- 8</b>
4.2 Procedures and Instructions. ....	<b>601- 6</b>	8.1 Communication Systems. ....	<b>601- 8</b>
4.3 Succession to Supervisory Responsibility. ....	<b>601- 6</b>	8.2 Protective Signaling Systems. ....	<b>601- 8</b>
4.4 Contract Security Service. ....	<b>601- 6</b>	8.3 Security Tour Supervision Systems. ....	<b>601- 8</b>
4.5 Maintenance of Equipment. ....	<b>601- 6</b>	8.4 Directory. ....	<b>601- 8</b>
4.6 Identification. ....	<b>601- 6</b>	<b>Annex A Explanatory Material</b> .....	<b>601- 8</b>
<b>Chapter 5 Security Functions and Duties</b> .....	<b>601- 6</b>	<b>Annex B Informational References</b> .....	<b>601- 12</b>
5.1 General. ....	<b>601- 6</b>	<b>Index</b> .....	<b>601- 13</b>
5.2 Other Duties of Security Officers. ....	<b>601- 6</b>		
5.3 Patrol Service. ....	<b>601- 6</b>		
5.4 Control of Pedestrian and Vehicular Movement. ....	<b>601- 7</b>		



**NFPA 601****Standard for****Security Services in Fire Loss Prevention**

2020 Edition

**IMPORTANT NOTE:** This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at [www.nfpa.org/disclaimers](http://www.nfpa.org/disclaimers) or obtained on request from NFPA.

**UPDATES, ALERTS, AND FUTURE EDITIONS:** New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

**NOTICE:** An asterisk (\*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [ ] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex B.

**Chapter 1 Administration****1.1 Scope.**

**1.1.1** This standard shall apply to the selection, requirements, duties, and training of security personnel who will perform fire loss prevention duties.

**1.1.2** This standard shall cover the following three categories of security services:

- (1) Protection of the property, including times when management is not present
- (2) Access and egress control into and within the confines of the protected property
- (3) Carrying out procedures for the orderly conduct of various operations at the property

**1.2 Purpose.**

**1.2.1** Protection of persons and property against hazards of fire shall be a management responsibility.

**1.2.2** The requirements of this standard shall be used to aid management in defining the requirements, duties, and training

for individuals to perform security services to protect a property against fire loss.

**Chapter 2 Referenced Publications**

**2.1 General.** The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

**2.2 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 70®, *National Electrical Code*®, 2020 edition.

NFPA 72®, *National Fire Alarm and Signaling Code*®, 2019 edition.

NFPA 731, *Standard for the Installation of Electronic Premises Security Systems*, 2020 edition.

**2.3 Other Publications.**

*Merriam-Webster's Collegiate Dictionary*, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

**2.4 References for Extracts in Mandatory Sections.**

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2019 edition.

**Chapter 3 Definitions**

**3.1 General.** The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

**3.2 NFPA Official Definitions.**

**3.2.1\* Approved.** Acceptable to the authority having jurisdiction.

**3.2.2\* Authority Having Jurisdiction (AHJ).** An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

**3.2.3 Labeled.** Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

**3.2.4\* Listed.** Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

**3.2.5 Shall.** Indicates a mandatory requirement.



**3.2.6 Should.** Indicates a recommendation or that which is advised but not required.

**3.2.7 Standard.** An NFPA Standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase "standards development process" or "standards development activities," the term "standards" includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

### 3.3 General Definitions.

**3.3.1 Drug.** Any substance, chemical, over-the-counter medication, or prescribed medication that can affect performance.

**3.3.2 Fire Loss Prevention Manager.** A person responsible for the preparation and implementation of a fire loss prevention plan and revisions to the plan as changes occur at the site.

**N 3.3.3 Fire Loss Prevention Plan.** Written policies, procedures, and business practices designed to address, control, mitigate, reduce, or prevent human behaviors, system malfunctions, or events that result in ignition or other detrimental incidents leading to a negative impact on life, property, and/or natural resources through fire or its effects.

**3.3.4 Hazardous Area.** An area that contains a hazardous atmosphere and those areas of the structures or buildings used for processes that involve quantities of flammable liquids, liquids processed at or above their flash point, flammable gases, or explosive materials that have the potential for catastrophic loss.

**3.3.5 Hot Work.** Work involving burning, welding, or a similar operation that is capable of initiating fires or explosions. [51B, 2019]

**3.3.6 Protective Signaling System.** Any alarm or system of alarms designed to give notification or warning, whether audible at the location or at a central receiving area, of the existence of a probable emergency or other unusual occurrence that might involve life safety or property protection.

**3.3.7\* Security.** The branch of an organization, public or private, charged with the responsibility of safeguarding the assets (people, physical plant, properties, and products and reputation) of an organization.

## Chapter 4 Management Responsibilities

### 4.1\* General Responsibilities.

**Δ 4.1.1** Management shall have the responsibility of providing protection for persons and property from the hazards of fire.

**4.1.2\*** The fire loss prevention manager shall be consulted in the design and implementation of the security policies and procedures affecting fire loss prevention.

**4.2\* Procedures and Instructions.** Procedures and instructions involving security shall be specific with respect to duty responsibilities and actions required.

**4.3 Succession to Supervisory Responsibility.** Management shall establish a clear line of succession in the event of absences.

**4.4\* Contract Security Service.** Supervision of security officers from outside firms shall be provided.

**4.5 Maintenance of Equipment.** Management shall establish and implement procedures for the maintenance and replacement of equipment provided for use by security personnel.

### 4.6\* Identification.

**4.6.1** Security officers shall be provided with a means of identifying themselves as authorized representatives of fire loss prevention management.

**4.6.2** The method of identification shall be acceptable to the authority having jurisdiction.

## Chapter 5 Security Functions and Duties

**5.1 General.** Where permitted by the authority having jurisdiction, security personnel shall be permitted to be supplemented or supplanted by an approved protective signaling or electronic monitoring system.

### 5.2 Other Duties of Security Officers.

**5.2.1** Security officers shall be permitted to perform other duties in addition to their security responsibilities.

**5.2.2** These other duties shall not compromise the security functions.

### 5.3 Patrol Service.

#### 5.3.1 Routes to Be Patrolled.

**5.3.1.1** Each route to be covered by a security officer shall be designated and approved by the fire loss prevention manager.

**5.3.1.2** The security officer assigned to each route shall be provided with instructions, all details regarding the route, and the functions to be carried out in covering the route.

**5.3.1.3** The route shall be explicitly defined to ensure that the security officer patrols the correct area.

**5.3.1.4\*** Security officers shall observe or monitor hazardous areas remotely through methods acceptable to the authority having jurisdiction to afford prompt detection of fire or conditions likely to cause fire or other loss.

**N 5.3.1.4.1** Where officers are required to observe hazardous areas remotely, video surveillance systems shall conform to NFPA 731.

#### 5.3.2\* Rounds.

**5.3.2.1** A security officer shall make rounds at intervals determined by management.

**5.3.2.1.1** When normal property operations are suspended, security officers shall make rounds hourly or as assigned by management.

**5.3.2.1.2** Management shall institute additional rounds where fire protection equipment is impaired or where exceptional hazards or other special conditions exist.

**5.4 Control of Pedestrian and Vehicular Movement.** Security shall be established to accomplish the following:

- (1) Prevent entry of unauthorized persons or vehicles
- (2) Control the activities of people authorized to be on the property, but who are not aware of procedures established for the prevention of fire
- (3) Control pedestrian and vehicular traffic as directed by management during exit drills and evacuation due to emergencies
- (4) Control gates and vehicular traffic to facilitate access to the property by the public fire department, members of private fire brigades, law enforcement, emergency medical services, and off-duty management personnel in the event of fire and other emergencies

**N 5.4.1\*** Electronic access control gates shall be in compliance with applicable standards.

#### **5.5\* Fire Protection Function of Security.**

**5.5.1** Where management assigns fire protection functions to security, procedures shall be established for orderly conduct of the operations at the property, including procedures for fire loss prevention both by employees of the property being protected and by outside contractors.

**Δ 5.5.2\*** Security shall be informed of fire protection system impairments, including the location and expected duration of the impairment and restoration.

**5.5.3\*** Security shall be notified of the location and duration of authorized hot work.

**5.5.4\*** Security shall be familiar with the response plans of the facility fire brigade or the fire department to ensure response routes are not blocked and to provide access when necessary.

**Δ 5.5.5** Procedures shall be established for the prompt reporting of any fires discovered by calling the public fire department and the fire brigade of the property (if available on the shift).

#### **5.6 General Duty Requirements.**

##### **5.6.1 Reporting for Duty.**

**5.6.1.1** Security officers shall report for duty at times specified by their supervisors.

**5.6.1.2** When security officers are unable to report for duty due to illness, injury, or other causes, they shall notify their supervisors at the earliest possible time prior to the beginning of the assigned shift.

##### **5.6.2\* Fitness for Duty.**

**5.6.2.1** An on-duty security officer shall not accept relief by another security officer who is not in a condition to work.

**N 5.6.2.2** A method of notifying management shall be stated in the security policy when a security officer has reason to believe the relief security officer is not in a condition to work.

**5.6.2.3** It shall be the responsibility of management to determine the fitness for duty of any security officer.

**N 5.6.2.4** Security officers shall not report for duty under the influence of alcoholic beverages, drugs, or other self-administered intoxicants per management's code of conduct.

##### **Δ 5.6.3 Emergencies on Duty.**

**N 5.6.3.1** Security officers shall not leave their assigned areas except in an emergency.

**N 5.6.3.2** In an emergency, security officers shall notify either their supervisors or another security officer as soon as practicable or send an appropriate signal to a constantly attended location, such as a control center or a police or fire station.

#### **5.7 Reports.**

##### **5.7.1 Report of Conditions Requiring Immediate Action.**

**5.7.1.1** Security officers shall promptly report the following conditions that require immediate attention:

- (1)\* Unauthorized impairments to fire protection systems
- (2) Unauthorized hot work operations
- (3) Potential damage to equipment caused by freezing or other environmental conditions
- (4) Process or service equipment that appears to be out of order or malfunctioning
- (5) Other site-specific matters that would affect the operation or security of the facility

**5.7.1.2** These reports shall be in accordance with written instructions that indicate persons to whom reports are to be distributed and any immediate verbal notifications that are to be made.

**Δ 5.7.2 Incident Reports.** As required, security officers shall make incident reports covering the following:

- (1) Where — the exact location
- (2) When — the exact time
- (3) What — the act or thing done
- (4) How — the method by which an act was done
- (5) Who — the identity of the person or persons

**5.7.3\* Daily Report.** Security officers shall complete daily reports as required.

### **Chapter 6 Selection and Conduct of Security Officers**

**6.1\* Character Investigation.** Management shall require individuals considered for a security officer position to satisfactorily pass a character investigation.

**6.2 Skills and Ability.** The applicant shall have the knowledge, skills, and ability to perform prescribed duties and to meet all job qualifications.

**N 6.2.1** Management shall determine the knowledge, skills, and abilities required for security officers to be assigned to their facility.

**6.3\* Criminal Convictions.** Applicants for a position as a security officer shall provide all information required by the authority having jurisdiction to complete a background check.

**6.4 Contract Service.** Contracts for security service shall include a provision stating that the service provider will replace any of its employees who, in the judgment of the company purchasing the service, are not qualified.

**6.5 Medical Requirements.** The employer shall establish medical and fitness requirements based on the risks and the functions associated with the individual's duties and responsibilities.

## 6.6 General Conduct of Security Officers.

**6.6.1** Security officers shall conduct themselves in such a way as to not interfere with the performance of their duties.

**6.6.2** While on duty, security officers shall not sleep, consume alcoholic beverages, consume illegal drugs, or conduct themselves in a manner that can affect the response to any emergency occurring on the protected property per management's code of conduct.

**6.6.3** Security officers shall not release any information without the approval of management.

**6.6.4** Security officers shall not release any details of their assignments except to authorized persons.

**N 6.6.4.1\*** Security officers shall not comment on or release any information concerning an event occurring on the property being protected, regardless of whether they are on or off duty and whether it is an emergency or not, without management's approval.

**6.6.5\*** Security officers shall follow and enforce rules adopted by the management of the property.

## Chapter 7 Training and Education

**7.1\* General.** Management shall establish an initial and ongoing performance-based training and education program for security officers to meet their assigned duties and functions.

**7.2\* Site-Specific Knowledge.** Management shall establish site-specific programs for security officers to ensure that they are knowledgeable about the property being protected, including the following:

- (1) All buildings, occupancies, and hazards
- (2)\* Hazardous materials and processes
- (3) Emergency shutdown procedures and equipment for which they are responsible
- (4) Fixed fire protection systems
- (5) Manual and automatic detection and alarm systems
- (6) Portable fire protection equipment
- (7)\* The facility's emergency action plan and procedures
- (8)\* Construction operations
- (9) Access control
- (10) Emergency response

## Chapter 8 Communications

**8.1\* Communication Systems.** Security officers shall be provided with a means for continuous communication with a constantly attended location.

**8.2 Protective Signaling Systems.** Protective signaling systems, where provided, shall be installed, designed, and operated in accordance with *NFPA 72* and *NFPA 731*.

### 8.3\* Security Tour Supervision Systems.

**Δ 8.3.1** Where security tour supervision systems are provided, they shall be listed or approved or shall conform with *NFPA 70*.

**8.3.2** Management shall ensure the following:

- (1) Security officers are not permitted to change the time record charts.

- (2) The changing and review of time record charts is done by the property manager or the manager's responsible designee, such as the fire loss prevention manager.
- (3) Time record charts of security officers are promptly reviewed.
- (4) Files are maintained for review by representatives of any authority having jurisdiction.
- (5) All irregularities are investigated and recorded, and corrective action is taken as required.

### 8.4\* Directory.

**Δ 8.4.1** A continuously updated directory of names and companies, including telephone numbers and other information to assist in making emergency calls notifications, shall be kept at the security control center or with the on-duty security officer(s) in situations where there is no continuously occupied security office.

**8.4.2** The directory shall include the contact information and telephone numbers of key management personnel to be notified in the event of an emergency.

**N 8.4.3** The directory shall include the contact information and telephone numbers of local law enforcement, fire, emergency medical or rescue services, and any other organization required to be notified and the circumstances directing their notification.

**8.4.4** This directory shall include the contact information and telephone numbers of key vendors and contractors whose response to an emergency situation is considered vital to business continuity.

## Annex A Explanatory Material

*Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.*

**N A.3.2.1 Approved.** The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

**N A.3.2.2 Authority Having Jurisdiction (AHJ).** The phrase "authority having jurisdiction," or its acronym AHJ, is used in NFPA documents in a broad manner; since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In

many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

**N A.3.2.4 Listed.** The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

**A.3.3.7 Security.** The process of security can be proprietary, contractual, or a combination of both. Proprietary security involves the use of company employees charged with the responsibility of protection. Contractual security makes use of an outside firm to supply individuals and equipment for the purpose of protection and loss prevention.

**A.4.1** Management of any property has a responsibility for fire loss prevention and for creating detailed plans for specific actions that are to be followed in the event of a fire. This responsibility can be delegated to an individual, such as the fire loss prevention manager.

Where there is a public fire department and that department has not already initiated a **prefire** plan for the property, the management should initiate such a plan, involving the appropriate officers of the public fire department to develop response plans for various situations on the property. The objective should be to anticipate, as far as possible, emergencies and types of hazards that are likely to confront security officers and other personnel.

**A.4.1.2** The term *fire loss prevention manager* is used to describe the function of the contact person in the property management. It is not necessarily intended to be a model title for all persons to whom the described responsibilities are assigned.

**A.4.2** General instructions or superficial training are of little value. Detailed, understandable instructions, which should be in written form, cannot be prepared without management's investment of time, thought, and expertise.

**A.4.4** The following are some of the important items to consider when management chooses a security company:

- (1) Does the company conduct a pre-employment investigation of all its employees, including a criminal history check confirmed with a check of fingerprints?
- (2) Does the company use psychological tests, such as the Minnesota Multiphasic Personality Inventory (MMPI) or other similar instrument, conducted by a person licensed to administer such tests for determination of applicant qualification?
- (3) Does the company have a continuous training program for its officers that deals with topics relevant to the duties expected of the officers at the facility being protected?
- (4) Does the company have an adequate supervisory system?
- (5) Does the company have a reporting system to keep the property management informed of occurrences on the protected property?
- (6) Does the company have sufficient insurance to cover any incident that can occur as a result of negligence or criminal activity on the part of one of the officers? (Ask to be made an additional insured under the policy of the company selected and get a copy of the insurance certificate to protect your company.)
- (7) What are the basic qualifications for employment as a security officer with the company?
- (8) Does the contracting security company have good references? (Check references whenever and wherever possible, including visitation of other installations protected by the security service.)

**Δ A.4.6** Identification is necessary for security officers from outside agencies and for internal personnel in larger facilities to rapidly identify who is authorized by the fire loss prevention manager to perform fire loss prevention duties. The form of identification should be communicated to all involved agencies during pre-planning and should be included in the facility's emergency action plan.

**A.5.3.1.4** Areas where hazardous processes or materials are located could require more frequent monitoring than other areas due to the potential for immediate catastrophic loss. In addition to the protection of property, the use of remote monitoring methods reduces or eliminates the exposure of the security officer to the hazard.

**Δ A.5.3.2** The first round should begin within 30 minutes after the end of activities of the preceding work shift. During this round, the security officer should make an inspection of all buildings or spaces.

The first round of a patrol is very important. Unless an emergency, such as fire, medical emergency, or perimeter breach, causes the security officer to divert efforts to another location or task, the first patrol round should be taken promptly. The purpose is to gain familiarization with the patrol site, to observe what is occurring, and to find events or conditions that might cause a fire or other loss to the property and report them as directed in the security procedures. The matters for specific attention in the first patrol round should be outlined in the security officer's instructions for the patrol and should include the monitoring of items such as the following:

- (1) Outside doors and gates should be closed and secured, and windows, skylights, fire doors, and fire shutters should be closed.
- (2) All oily waste, rags, paint residue, rubbish, and similar combustible items should be removed from the buildings or reported.
- (3) All fire protection equipment should be in place and not obstructed.
- (4) Aisles should be clear.
- (5) Motors or machines not required to run continuously should be monitored.
- (6) All unsecured offices, conference rooms, and smoking areas should be checked for carelessly discarded smoking materials.
- (7) All gas and electric heaters, coal and oil stoves, and other heating devices in open or unsecured areas on the premises should be checked.
- (8) The conditions of hazardous manufacturing processes should be noted as assigned. The temperature of dryers, annealing furnaces, and similar equipment that continue to operate during the night and on holidays and weekends should be noted on all rounds.
- (9) Flammable and combustible materials should be stored in approved containers or storage areas.
- (10) All sprinkler valves should be open and sealed with gauges indicating normal pressures. If not open, that fact should be reported immediately.



- (11) Areas should be checked to determine if heating or air-conditioning systems are working properly.
- (12) Water faucets and air valves should be examined for leaks. All water faucets and air valves found leaking should be reported and recorded.
- (13) Particular attention should be given to areas under construction or involved in alteration.

**N A.5.4.1** One example of such an applicable standard is ANSI/UL 294, *Standard for Access Control System Units*.

**Δ A.5.5** Examples of procedures for fire loss prevention include the following:

- (1) Checking permits for hot work, including cutting and welding, and standing by, where required, to operate fire-extinguishing equipment at the location of such work (*see NFPA 51B for information on fire watches*)
- (2) Detecting conditions likely to cause a fire, such as leaks or spills of flammable liquids and faulty equipment
- (3) Detecting conditions that reduce the effectiveness with which a fire can be controlled, such as closed sprinkler control valves, obstructed sprinkler heads, impaired water supplies, or misplaced or nonfunctioning portable fire extinguishers
- (4) Performing operations to ensure that fire equipment will function effectively (e.g., testing automatic sprinkler and other fixed fire protection systems; testing fire pumps and other equipment related to these systems; and assisting in maintenance service on this equipment; checking portable fire extinguishers and fire hose; and assisting with pressure tests and maintenance service on these items; testing fire alarm equipment; checking equipment provided on any motorized fire apparatus; and performing the periodic tests and maintenance operations required for it)
- (5) Operating equipment provided for control and extinguishment of incipient-stage fires after giving the alarm and before the response of other persons to the alarm
- (6) Monitoring receipt of signals due to the operation of protective signaling systems provided, including trouble signals
- (7) Making patrols along routes chosen to ensure surveillance of the entire property at appropriate intervals

**A.5.5.2** Knowledge about impairments is a fundamental aspect of fire loss prevention and should be taken into consideration in the processing of alarms and the security officer's awareness.

**A.5.5.3** Knowledge about authorized hot work is a fundamental aspect of fire loss prevention and should be taken into consideration in the processing of alarms and the security officer's awareness. Security officers should be assigned to provide surveillance of terminated hot work operations.

**Δ A.5.5.4** Facility fire brigade requirements are provided in NFPA 600.

**A.5.6.2** It is critical that security officers are in an appropriate physical and mental condition to conduct their assigned duties. In the event that the actions of the relieving security officer suggest that he or she is not fit for duty, the on-duty security officer should notify his or her supervisor. Examples of impaired physical condition include, but are not limited to, the following:

- (1) Physical injuries
- (2) Contagious illnesses

- (3) Slurred or incoherent speech
- (4) Odor of intoxicant on breath or person
- (5) Unsteady gait
- (6) Disheveled appearance

**A.5.7.1.1(1)** Examples of unauthorized impairments can include items such as fire pumps that are out of service, sprinkler system valves that have been closed, or alarm or other fire protection systems that are in trouble or supervisory.

**A.5.7.3** The daily report form should be a brief summary of the work done and the events encountered by the security officer during the shift. The format of the report form can be varied to fit either company or facility policy but should be designed to ensure that all relevant information is included. The format can consist, for example, of questions that can be responded to by either "yes," "no," or "N/A," with a space made available for remarks. Examples of typical questions are as follows:

- (1) Fires in progress or property damaged?
- (2) Stations missed?
- (3) Rule violations?
- (4) Fire hazards observed?
- (5) Exits obstructed?
- (6) Doors/windows open or broken?
- (7) Fire equipment missing or inoperative?
- (8) Sprinkler system defects found?
- (9) Areas unsecured?
- (10) Exits obstructed/blocked?
- (11) Fire door blocked or inoperative?
- (12) Smoking violations discovered?
- (13) Other events noted?

**A.6.1** Character background investigations involve more than taking the information provided on the application as fact. The employing agency should institute a procedure to confirm and clarify the information provided on the completed, signed application for employment. Information regarding employment, positions held, education, and residences should be confirmed. Information as to military service and discharge status (DD-214), if applicable, should be confirmed. Special attention should be given to periods of unemployment or self-employment, and confirmation should be obtained from an independent third party. Personal references listed by the applicant should be contacted, as well as any other individuals who might possess information on the suitability of the individual to be a security officer. A complete employment history is desirable, but a 10-year history from the date of the application is usually acceptable.

The employer should also consider drug screening of security officers. Examinations should be in compliance with directives established by the authority having jurisdiction. Where no directives are established or in place, testing should be in compliance with the Department of Transportation (DOT) standards for a five-panel test for illegal drug identification, administered through a National Institute for Drug Abuse (NIDA)-approved laboratory.

It should be noted that the DOT requirements are for illegal drugs only. Screenings are available that can determine the presence of prescription and certain over-the-counter drugs whose abuse could be counterproductive to a safe and productive work environment.

**A.6.3** Although conviction of a criminal offense should not automatically disqualify an individual for employment as a

security officer, the employing firm should make every effort to obtain the complete criminal conviction history of security officer applicants. States that license security officers could require a criminal history covering a specific period of time but, for nonregulated areas, a history of no fewer than 10 years should be undertaken. The criminal history checks should include all areas lived in for the 10 years preceding the application. Individual states that regulate security officers might not allow applicants with felony convictions or convictions involving moral turpitude to do security work. Companies in nonregulated states should use this direction as base hiring standards.

**N A.6.6.4.1** This restriction includes commenting on or releasing any information via social media, phone calls, emails, videos, and pictures.

**A.6.6.5** The security officer is the most visible representative of a company, whether that officer is an employee or contractor of the company. The security officer's actions are a direct reflection of the image of the company and the services afforded by the company. If security gives the appearance that they are "above the law," compliance with safety and security regulations could be minimal.

**A.7.1** The scope of the training and education program should be established by management or the fire protection manager acting for management.

Security officers can take advantage of job-related courses offered through vocational/technical colleges, community and junior colleges, universities, and private training agencies. Companies should schedule officers so that they can take advantage of job-related training and education opportunities. Tuition reimbursement, either complete or partial, should be considered.

Security officers should be made aware of meetings that could provide job-related knowledge. These meetings might involve groups that are dedicated to fire protection, safety, loss prevention, crime prevention, or other related areas.

Facility management should have available relevant professional publications and journals in the areas of fire and general loss prevention and safety for the security officers' information as well as for use in the training and education of security officers.

Membership with the National Fire Protection Association (NFPA), the American Society of Industrial Security (ASIS), and other comparable international associations is recommended for obtaining useful resources and publications.

All methodologies of training should be used in the training of security officers. Training bulletins, multimedia presentations, and classroom sessions should be used as means to further the knowledge, skills, and abilities of the security officer.

Training aids are available from various sources. Local fire departments, state fire marshals' offices, insurance organizations, and community/junior colleges and universities can be of invaluable assistance in the training of security personnel. Manuals from manufacturers of specific equipment can also be of use.

**A.7.2** The use of a training officer or mentor can prove to be more beneficial than the use of printed material for the initial site training of the security officer. The training officer should be an individual who best exemplifies the quality of security

desired. The training officer should be thoroughly familiar with the facility being protected.

**A.7.2(2)** Management should ensure that security officers are knowledgeable in site-specific hazardous materials and processes. Training for security officers about site-specific hazardous materials and processes should be done prior to his or her assignment to the hazardous area and whenever new hazardous materials and processes are introduced into the facility. Management should ensure that security officers are familiar with the location and interpretation of safety data sheets (SDS).

**A.7.2(7)** Management should ensure that security officers are familiar with the site-specific emergency plans for dealing with fires and other emergencies. Management should also ensure that security officers are familiar with the procedures to follow in the recognition and reporting of an emergency, including the following:

- (1) When and how to use radio equipment, telephones, and private or public alarm boxes to summon aid
- (2) How to notify the facility fire brigade, the municipal fire department, and other emergency response organizations
- (3) Personnel to be contacted

**Δ A.7.2(8)** Management should ensure that security officers are knowledgeable in the hazards associated with construction, demolition, alteration, and repair operations.

Construction, demolition, alteration, and repair operations create temporary conditions that could alter the fire hazards and fire protection within and near the facilities. Furthermore, depending on the type of project, conditions could be constantly changing. Security officers should be knowledgeable of items such as the following:

- (1) Maintenance of unobstructed fire department or fire brigade access routes throughout the facility
- (2) Clear access to fire protection equipment, such as fire hydrants, automatic sprinkler and standpipe connections, standpipe hose lines, and portable fire extinguishers
- (3) Locations where cutting, welding, and other hot work operations are being conducted or have been conducted within the last 4 hours of the start of the security officer's shift
- (4) Maintenance of unobstructed access to exits and changes in exits
- (5) Proper storage of combustible materials, including flammable and combustible liquids, combustible construction materials, and debris, away from heat sources
- (6) Location of temporary heating devices
- (7) Location of roofing operations that are being conducted or that have been conducted within 12 hours of the start of the security officer's shift
- (8) Locations with restricted access, such as asbestos abatement areas
- (9) Location of impaired fire protection systems

For additional information on fire loss prevention during construction operations, see NFPA 241.

**A.8.1** Communication systems can use telephones, cellular telephones, telegraph, radio, and other components. For security service communications, ordinary extension telephones and portable radios can be used if sufficient personnel are provided for and if a high degree of reliability of operation and maintenance of equipment exists. A constantly attended location is a

facility that receives signals or communications and that has personnel in attendance at all times to respond to these signals or communications.

**A.8.3** Supervisory services systems are designed to continually report the performance of a security officer in connection with the intervals determined by management. The following describes some of the common systems used to perform this function:

- (1) *Supervised tours.* In the first case, a series of patrol stations along the security officer's intended route are successively operated by the security officer with each station sounding a distinctive signal at a central headquarters. Customarily, the security officer is expected to reach each of these stations at a definite time, and failure to do so within a reasonable grace period prompts the central station to investigate the security officer's failure to signal. Frequently, manual fire alarm boxes that ordinarily transmit four or five rounds of signals for fire can also be actuated by a special watch key carried by the security officer to transmit only a single round to the central station, thus signaling that the box has been visited. Deliberate distribution of stations will compel a security officer to take a definite route through the premises, and variations from that route will appear as misplaced signals on the recording tape. A further advantage is that the order of station operation can be varied from time to time in the interests of security or to meet special conditions within the building.
- (2) *Compulsory tours.* In the second case, one or more stations are connected to the central station, and preliminary mechanical stations condition the security officer's key to operate the connected station after, and only after, the preliminary stations have been operated in a prearranged order. This second arrangement is somewhat less flexible than the first, but has the advantage of the absence of interconnection between the preliminary stations and, thus, the reduction of signal traffic. The usual arrangement is to have the security officer transmit only start and finish signals that must be received at the central point at programmed reception times.
- (3) *Delinquency indicators.* Delinquency indicator systems contain a series of connected stations that transmit a signal if the security officer does not reach the particular station within the anticipated preset period.

**Δ A.8.4** A security control center is a location at which security officers can monitor electronic systems, sensors, or video cameras in order to promptly detect problems or potential problems. The center should have the ability to communicate with and monitor points outside as well as within the protected property.

Where the communication equipment, including equipment used on patrol, requires that communications from security officers be monitored, the control center should be provided with an operator. Additional operators and around-the-clock operator service should be provided at the control center according to the character of the security service provided. Security officers who can be dispatched to investigate signals should also be provided as necessary. The control center should not go unstaffed while operational.

For additional information on control centers and their application in support of security and fire loss prevention, see NFPA 731. For additional information that needs to be present in a control center or provided in a pre-incident plan, see NFPA 1620.

## Annex B Informational References

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**B.1 Referenced Publications.** The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

**B.1.1 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2019 edition.

NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*, 2019 edition.

NFPA 600, *Standard for Facility Fire Brigades*, 2020 edition.

NFPA 731, *Standard for the Installation of Electronic Premises Security Systems*, 2020 edition.

NFPA 1620, *Standard for Pre-Incident Planning*, 2020 edition.

### **N B.1.2 Other Publications.**

**N B.1.2.1 UL Publications.** Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 294, *Standard for Access Control System Units*, 2018.

### **B.2 Informational References. (Reserved)**

### **B.3 References for Extracts in Informational Sections. (Reserved)**



## Index

Copyright © 2019 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

- A-**
- Administration**, Chap. 1
  - Purpose, 1.2
  - Scope, 1.1
- Approved**
  - Definition, 3.2.1, A.3.2.1
- Authority Having Jurisdiction (AHJ)**
  - Definition, 3.2.2, A.3.2.2
- C-**
- Communications**, Chap. 8
  - Communication Systems, 8.1, A.8.1
  - Directory, 8.4, A.8.4
  - Protective Signaling Systems, 8.2
  - Security Tour Supervision Systems, 8.3, A.8.3
- D-**
- Definitions**, Chap. 3
- Drug**
  - Definition, 3.3.1
- E-**
- Explanatory Material**, Annex A
- F-**
- Fire Loss Prevention Manager**
  - Definition, 3.3.2
- Fire Loss Prevention Plan**
  - Definition, 3.3.3
- H-**
- Hazardous Area**
  - Definition, 3.3.4
- Hot Work**
  - Definition, 3.3.5
- I-**
- Informational References**, Annex B
- L-**
- Labeled**
  - Definition, 3.2.3
- Listed**
  - Definition, 3.2.4, A.3.2.4
- M-**
- Management Responsibilities**, Chap. 4
  - Contract Security Service, 4.4, A.4.4
  - General Responsibilities, 4.1, A.4.1
  - Identification, 4.6, A.4.6
  - Maintenance of Equipment, 4.5
  - Procedures and Instructions, 4.2, A.4.2
  - Succession to Supervisory Responsibility, 4.3
- P-**
- Protective Signaling System**
  - Definition, 3.3.6
- R-**
- Referenced Publications**, Chap. 2
- S-**
- Security**
  - Definition, 3.3.7, A.3.3.7
- Security Functions and Duties**, Chap. 5
  - Control of Pedestrian and Vehicular Movement, 5.4
  - Fire Protection Function of Security, 5.5, A.5.5
  - General, 5.1
  - General Duty Requirements, 5.6
    - Emergencies on Duty, 5.6.3
    - Fitness for Duty, 5.6.2, A.5.6.2
    - Reporting for Duty, 5.6.1
  - Other Duties of Security Officers, 5.2
  - Patrol Service, 5.3
    - Rounds, 5.3.2, A.5.3.2
    - Routes to Be Patrolled, 5.3.1
  - Reports, 5.7
    - Daily Report, 5.7.3, A.5.7.3
    - Incident Reports, 5.7.2
    - Report of Conditions Requiring Immediate Action, 5.7.1
- Selection and Conduct of Security Officers**, Chap. 6
  - Character Investigation, 6.1, A.6.1
  - Contract Service, 6.4
  - Criminal Convictions, 6.3, A.6.3
  - General Conduct of Security Officers, 6.6
  - Medical Requirements, 6.5
  - Skills and Ability, 6.2
- Shall**
  - Definition, 3.2.5
- Should**
  - Definition, 3.2.6
- Standard**
  - Definition, 3.2.7
- T-**
- Training and Education**, Chap. 7
  - General, 7.1, A.7.1
  - Site-Specific Knowledge, 7.2, A.7.2