

NFPA

**70A**

1981

ELECTRICAL CODE FOR  
**ONE- AND TWO-FAMILY  
DWELLINGS**

**Excerpted from the  
1981 *National Electrical Code*®**

Copyright © 1981 and Sponsored by  
**National Fire Protection Association**

*All Rights Reserved*

Batterymarch Park

Quincy, MA 02269

## NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on obtaining Formal Interpretations of the document, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.

---

**Licensing Provision** — This document is copyrighted by the National Fire Protection Association (NFPA).

**1. Adoption by Reference** — Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

**2. Adoption by Transcription** — **A.** Public authorities with law-making or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's law-making or rule-making process. **B.** Public authorities with advisory functions and all others desiring permission to reproduce this document or its contents in whole or in part in any form shall consult the NFPA.

All other rights, including the right to vend, are retained by NFPA.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

### Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

# **Electrical Code for One- and Two-Family Dwellings**

**NFPA 70A - 1981**

**Excerpted from the 1981 *National Electrical Code*®**

**NFPA 70 - 1981**

## **Explanation of this Code**

This Electrical Code for One- and Two-Family Dwellings (NFPA 70A-1981) covers those wiring methods and materials most commonly encountered in the construction of new one- and two-family dwellings. Other wiring methods, materials and subject matter covered in the 1981 *National Electrical Code* (NFPA 70-1981) are also recognized by this Code. (See Preface for further information.)

The development of this Code was first undertaken in 1968 to meet the expressed need for an electrical code applicable only to dwellings as a convenience to those whose interests are so oriented. With the approval of the Correlating Committee of the National Electrical Code Committee, an Ad Hoc Committee was established of those primarily concerned to guide this project to completion. Those asked to serve on the Ad Hoc Committee included representatives of the following organizations: American Insurance Association, Building Officials and Code Administrators International, Inc., Department of Housing and Urban Development, Edison Electric Institute, International Association of Electrical Inspectors, International Brotherhood of Electrical Workers, International Conference of Building Officials, National Association of Home Builders, the National Electrical Contractors Association, and Underwriters Laboratories Inc.

It was decided that the Electrical Code for One- and Two-Family Dwellings should consist of excerpts from the complete current *National Electrical Code* without any modification of intent and with minimum editorial change. Article and Section numbers have been retained to permit close correlation.

Following decisions made by the Correlating Committee and by the Technical Subcommittee as to format and content, the excerpted material containing editorial revision was formally submitted to members of the Technical Subcommittee and the Correlating Committee for letter ballot to determine if the editorial changes accomplished had been achieved without altering the intent of the complete Code.



# Technical Subcommittee for Electrical Code for One- and Two-Family Dwellings

**Charles J. Hart, *Chairman***

National Electrical Contractors Association, 7513 Wisconsin Avenue, Washington, DC 20014

**Peter J. Schram, *Secretary***

National Fire Protection Association, 470 Atlantic Ave., Boston, MA 02210

**Rita L. Good, *Staff Liaison*, NFPA**

**Paul Heilstedt**, The Building Officials and Code Administration International, Inc., 17926 S. Halsted Street, Homewood, IL 60431

**Duane Keptinger**, Federal Housing Administration, Architecture & Engineering Div., Department of Housing and Urban Development, Washington, DC 20411

Alternate: **Richard P. Kuchnicki**, National Association of Home Builders, 15th and M. Streets, NW, Washington, DC 20036

**John Markey**, Edison Electric Institute, 1111-19th Street, NW, Washington, DC 20036

**J. M. Parker**, International Brotherhood of Electrical Workers, 1125-15th Street, NW, Washington, DC 20036

**Joseph C. Roohan**, International Conference of Building Officials, 5360 S. Workman Mill Road, Whittier, CA 90601

**Michael Slifka**, National Conference of States on Building Codes and Standards, 1970 Chain Bridge Road, McLean, VA 22102

**M. W. Smithman**, National Association of Home Builders, 15th and M. Streets, NW, Washington, DC 20036

**Kent P. Stiner**, Route 2, Box 60, Chadds Ford, PA 19317

**W. I. Summers**, International Association of Electrical Inspectors, 802 Busse Highway, Park Ridge, IL 60068

**William Taynge**, Southern Bldg. Code Contress, Int., 900 Montclair Road, Birmingham, AL

**B. S. Trant**, Council of American Building Officials, Suite 560, 2233 Wisconsin Avenue, NW, Washington, DC 20007

## TABLE OF CONTENTS

ARTICLE	PAGE
90 Introduction	70A-1
110 Requirements for Electrical Installations	70A-3
200 Use and Identification of Grounded Conductors	70A-7
210 Branch Circuits	70A-10
215 Feeders	70A-20
220 Branch Circuit and Feeder Calculations	70A-21
230 Services	70A-28
240 Overcurrent Protection	70A-38
250 Grounding	70A-41
280 Surge Arresters	70A-57
300 Wiring Methods	70A-58
305 Temporary Wiring	70A-65
310 Conductors for General Wiring	70A-67
333 Armored Cable	70A-72
336 Nonmetallic-Sheathed Cable	70A-74
338 Service-Entrance Cable	70A-77
339 Underground Feeder and Branch-Circuit Cable	70A-79
345 Intermediate Metal Conduit	70A-81
346 Rigid Metal Conduit	70A-83
347 Rigid Nonmetallic Conduit	70A-86
348 Electrical Metallic Tubing	70A-89
350 Flexible Metal Conduit	70A-91
353 Multioutlet Assembly	70A-93
370 Outlet, Switch and Junction Boxes, and Fittings	70A-94
373 Cabinets and Cutout Boxes	70A-100
380 Switches	70A-103
384 Panelboards	70A-105
400 Flexible Cords and Cables	70A-107
410 Lighting Fixtures, Lampholders, Lamps, and Receptacles	70A-108
422 Appliances	70A-116
424 Fixed Electric Space Heating Equipment	70A-122
440 Air-Conditioning and Refrigerating Equipment	70A-131
545 Manufactured Buildings	70A-132
680 Swimming Pools, Fountains and Similar Installations	70A-132
725 Class 1, Class 2, and Class 3 Remote-Control, Signaling, and Power Limited Circuits	70A-132
760 Fire Protective Signaling Systems	70A-132
Tables and Examples	70A-133
Index	70A-144

# **Electrical Code for One- and Two-Family Dwellings**

**Excerpted from the 1981 *National Electrical Code***

**NFPA 70A-1981**

(For rules covering wiring methods and equipment not included here, see the 1981 *National Electrical Code*.)

## **PREFACE**

This Code has been prepared under the guidance of a Technical Subcommittee (see page 70A-iii) for preparation of an Electrical Code for One- and Two-Family Dwellings, as authorized by the National Electrical Code Committee through its Correlating Committee.

Only those wiring methods and materials most commonly encountered in construction of new 1- and 2-family dwellings are included in this Code. Other wiring methods, materials, and subject matter covered in the 1981 *National Electrical Code* (NFPA 70-1981) are also recognized by this Code.

In like manner, only current ratings up to and including 225 amperes and voltages up to and including 600 volts are included in this Code. It is the intent that the rules covering any wiring methods, any materials, or any type of equipment, such as motors, not specifically included in this Code are to be covered by the applicable rules in the 1981 *National Electrical Code*.

Where a reference is made to an article or section not included in this Code, such as to Article 430 or to Section 430-52, the reference is to that article or section appearing in the 1981 *National Electrical Code*.

The rules in this Code have been excerpted from the 1981 *National Electrical Code*, but editorially revised where necessary to restrict their applicability to 1- and 2-family dwellings.

The section numbers assigned to these rules are the same as in the 1981 *National Electrical Code*. However, there are many paragraphs in the 1981

*National Electrical Code* that do not appear in this Code. Consequently, there are instances where gaps appear in the normal sequence of section numbers and alphabetical paragraph designations.

This Code has been formulated for the convenience of inspectors, contractors, builders, and others who are primarily interested in only those *NEC*® rules which apply to 1- and 2-family dwellings. A revised edition will be issued following each revised edition of the *National Electrical Code* to ensure that there is no divergence between the requirements of the Codes as they pertain to 1- and 2-family dwellings.



***Electrical Code for***  
**One- and Two-Family Dwellings**  
NFPA 70A-1981  
**ARTICLE 90 — INTRODUCTION**

**90-1. Purpose.**

(a) **Practical Safeguarding.** The purpose of this Code is the practical safeguarding of persons and property from hazards arising from the use of electricity.

(b) **Adequacy.** This Code contains provisions considered necessary for safety. Compliance therewith and proper maintenance will result in an installation essentially free from hazard, but not necessarily efficient, convenient, or adequate for good service or future expansion of electrical use.

Hazards often occur because of overloading of wiring systems by methods or usage not in conformity with this Code. This occurs because initial wiring did not provide for increases in the use of electricity. An initial adequate installation and reasonable provisions for system changes will provide for future increases in the use of electricity.

(c) **Intention.** This Code is not intended as a design specification nor an instruction manual for untrained persons.

**90-2. Scope.**

(a) **Covered.** This Code covers:

Only those wiring methods and materials most commonly encountered in construction of new 1- and 2-family dwellings\* are included in this Code. Other wiring methods, materials, and subject matter covered in the 1981 *National Electrical Code* (NFPA 70-1981) are also recognized by this Code.

(b) **Not Covered.** This Code does not cover:

(5) Installations under the exclusive control of electric utilities for the purpose of communication, or metering; or for the generation, control, transformation, transmission, and distribution of electric energy located in buildings used exclusively by utilities for such purposes or located outdoors on property owned or leased by the utility or on public highways, streets, roads, etc., or outdoors by established rights on private property.

It is the intent of this section that this Code covers all premises' wiring or wiring other than utility owned metering equipment, on the load side of the service point of buildings, structures, or any other premises not owned or leased by the utility. Also, it is the intent that this Code cover installations in buildings used by the utility for purposes other than listed in (b)(5) above, such as office buildings, warehouses, garages, machine shops, and recreational buildings which are not an integral part of a generating plant, substation, or control center.

\*As used in this code 1- and 2-family dwellings do not include mobile homes, recreational vehicles, floating dwelling units, buildings containing more than two dwelling units, or buildings used for other than dwelling purposes.

(c) **Special Permission.** The authority having jurisdiction for enforcing this Code may grant exception for the installation of conductors and equipment, not under the exclusive control of the electric utilities and used to connect the electric utility supply system to the service-entrance conductors of the premises served, provided such installations are outside a building or terminate immediately inside a building wall.

**90-4. Enforcement.** This Code is intended to be suitable for mandatory application by governmental bodies exercising legal jurisdiction over electrical installations and for use by insurance inspectors. The authority having jurisdiction of enforcement of the Code will have the responsibility for making interpretations of the rules, for deciding upon the approval of equipment and materials, and for granting the special permission contemplated in a number of the rules.

The authority having jurisdiction may waive specific requirements in this Code or permit alternate methods, where it is assured that equivalent objectives can be achieved by establishing and maintaining effective safety.

**90-5. Formal Interpretations.** To promote uniformity of interpretation and application of the provisions of this Code, the National Electrical Code Committee has established interpretation procedures.

**90-6. Examination of Equipment for Safety.** For specific items of equipment and materials referred to in this Code, examinations for safety made under standard conditions will provide a basis for approval where the record is made generally available through promulgation by organizations properly equipped and qualified for experimental testing, inspections of the run of goods at factories, and service-value determination through field inspections. This avoids the necessity for repetition of examinations by different examiners, frequently with inadequate facilities for such work, and the confusion that would result from conflicting reports as to the suitability of devices and materials examined for a given purpose.

It is the intent of this Code that factory-installed internal wiring or the construction of equipment need not be inspected at the time of installation of the equipment, except to detect alterations or damage, if the equipment has been listed by a qualified electrical testing laboratory which is recognized as having the facilities described above and which requires suitability for installation in accordance with this Code.

See Examination of Equipment, Section 110-3.

**90-8. Metric Units of Measurement.** For the purpose of this Code metric units of measurement are in accordance with the modernized metric system known as the International System of Units (SI).

Values of measurement in the Code text will be followed by an approximate equivalent value in SI units. Tables will have a footnote for SI conversion units used in the table.

Conduit size, wire size, horsepower designation for motors, and trade sizes that do not reflect actual measurements, e.g., box sizes, will not be assigned dual designation SI units.

For metric conversion practices, see ANSI Z210.1-1976, Standard for Metric Practice.

## ARTICLE 110 — REQUIREMENTS FOR ELECTRICAL INSTALLATIONS

### A. General

**110-1. Mandatory Rules and Explanatory Material.** Mandatory rules of this Code are characterized by the use of the word "shall." Explanatory material is in the form of fine print notes.

### **110-3. Examination, Identification, Installation, and Use of Equipment.**

(a) **Examination.** In judging equipment, considerations such as the following shall be evaluated:

(1) Suitability for installation and use in conformity with the provisions of this Code. Suitability of equipment use may be identified by a description marked on or provided with a product to identify the suitability of the product for a specific purpose, environment, or application. Suitability of equipment may be evidenced by listing or labeling.

(2) Mechanical strength and durability, including, for parts designed to enclose and protect other equipment, the adequacy of the protection thus provided.

(3) Wire-bending and connection space.

(4) Electrical insulation.

(5) Heating effects under normal conditions of use and also under abnormal conditions likely to arise in service.

(6) Arcing effects.

(7) Classification by type, size, voltage, current capacity, specific use.

(8) Other factors which contribute to the practical safeguarding of persons using or likely to come in contact with the equipment.

(b) **Installation and Use.** Listed or labeled equipment shall be used or installed in accordance with any instructions included in the listing or labeling.

**110-4. Voltages.** Throughout this Code the voltage considered shall be that at which the circuit operates.

**110-5. Conductors.** Conductors normally used to carry current shall be of copper unless otherwise provided in this Code. Where the conductor material is not specified, the sizes given in this Code shall apply to copper conductors. Where other materials are used, the size shall be changed accordingly.

For aluminum and copper-clad aluminum conductors, see Tables 310-16 through 310-19.

**110-6. Conductor Sizes.** Conductor sizes are expressed in American Wire Gage (AWG) or in circular mils.

**110-7. Insulation Integrity.** All wiring shall be so installed that when completed the system will be free from short circuits and from grounds other than as permitted in Article 250.

**110-8 Wiring Methods.** Only those wiring methods most commonly encountered in 1- and 2-family dwellings are included in this Code. The recognized methods of wiring shall be permitted to be installed in 1- and 2-family dwellings. Other wiring methods recognized by the NEC for 1- and 2-family dwellings are also recognized under this Code.

**110-9. Interrupting Rating.** Equipment intended to break current at fault levels shall have an interrupting rating sufficient for the system voltage and the current which is available at the line terminals of the equipment.

Equipment intended to break current at other than fault levels shall have an interrupting rating at system voltage sufficient for the current that must be interrupted.

**110-10. Circuit Impedance and Other Characteristics.** The overcurrent protective devices, the total impedance, the component short-circuit withstand ratings, and other characteristics of the circuit to be protected shall be so selected and coordinated as to permit the circuit protective devices used to clear a fault without the occurrence of extensive damage to the electrical components of the circuit. This fault shall be assumed to be either between two or more of the circuit conductors, or between any circuit conductor and the grounding conductor or enclosing metal raceway.

**110-11. Deteriorating Agents.** Unless identified for use in the operating environment, no conductors or equipment shall be located in damp or wet locations; where exposed to gases, fumes, vapors, liquids, or other agents having a deteriorating effect on the conductors or equipment; nor where exposed to excessive temperatures.

See Section 300-6 for protection against corrosion.

Control equipment, utilization equipment, and busways approved for use in dry locations only shall be protected against permanent damage from the weather during building construction.

**110-12. Mechanical Execution of Work.** Electric equipment shall be installed in a neat and workmanlike manner.

Unused openings in boxes, raceways, auxiliary gutters, cabinets, equipment cases or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment.

**110-13. Mounting and Cooling of Equipment.**

(a) **Mounting.** Electric equipment shall be firmly secured to the surface on which it is mounted. Wooden plugs driven into holes in masonry, concrete, plaster, or similar materials shall not be used.

(b) **Cooling.** Electrical equipment which depends upon the natural circulation of air and convection principles for cooling of exposed surfaces shall be installed so that room air flow over such surfaces is not prevented by walls or by adjacent installed equipment. For equipment designed for floor mounting, clearance between top surfaces and adjacent surfaces shall be provided to dissipate rising warm air.

Electrical equipment provided with ventilating openings shall be installed so that walls or other obstructions do not prevent the free circulation of air through the equipment.

**110-14. Electrical Connections.** Because of different characteristics of copper and aluminum, devices such as pressure terminal or pressure splicing

connectors and soldering lugs shall be suitable for the material of the conductor and shall be properly installed and used. Conductors of dissimilar metals shall not be intermixed in a terminal or splicing connector where physical contact occurs between dissimilar conductors (such as copper and aluminum, copper and copper-clad aluminum, or aluminum and copper-clad aluminum), unless the device is suitable for the purpose and conditions of use. Materials such as solder, fluxes, inhibitors, and compounds, where employed, shall be suitable for the use and shall be of a type which will not adversely affect the conductors, installation, or equipment.

**(a) Terminals.** Connection of conductors to terminal parts shall ensure a thoroughly good connection without damaging the conductors and shall be made by means of pressure connectors (including set-screw type), solder lugs, or splices to flexible leads.

*Exception: Connection by means of wire binding screws or studs and nuts having upturned lugs or equivalent shall be permitted for No. 10 or smaller conductors.*

Terminals for more than one conductor and terminals used to connect aluminum shall be so identified.

**(b) Splices.** Conductors shall be spliced or joined with splicing devices suitable for the use or by brazing, welding, or soldering with a fusible metal or alloy. Soldered splices shall first be so spliced or joined as to be mechanically and electrically secure without solder and then soldered. All splices and joints and the free ends of conductors shall be covered with an insulation equivalent to that of the conductors or with an insulating device suitable for the purpose.

**110-16. Working Space About Electric Equipment (600 Volts, Nominal, or Less).** Sufficient access and working space shall be provided and maintained about all electric equipment to permit ready and safe operation and maintenance of such equipment.

**(a) Working Clearances.** Except as elsewhere required or permitted in this Code, the dimension of the working space in the direction of access to live parts operating at 600 volts, nominal, or less and likely to require examination, adjustment, servicing, or maintenance while alive shall not be less than indicated in Table 110-16(a). Distances shall be measured from the live parts if such are exposed or from the enclosure front or opening if such are enclosed. Concrete, brick, or tile walls shall be considered as grounded.

In addition to the dimensions shown in Table 110-16(a), the work space shall not be less than 30 inches (762 mm) wide in front of the electric equipment.

**Table 110-16(a). Working Clearances**

Voltage to Ground, Nominal	Condition:	Minimum Clear Distance (feet)		
		1	2	3
0-150		3	3	3
151-600		3	3½	4

For SI units: one inch = 25.4 millimeters; one foot = 0.3048 meter.

Where the "Conditions" are as follows:

1. Exposed live parts on one side and no live or grounded parts on the other side of the working space, or exposed live parts on both sides effectively guarded by suitable wood or other insulating materials. Insulated wire or insulated busbars operating at not over 300 volts shall not be considered live parts.

2. Exposed live parts on one side and grounded parts on the other side.

3. Exposed live parts on both sides of the work space (not guarded as provided in Condition 1) with the operator between.

*Exception No. 1: Working space shall not be required in back of assemblies such as dead-front switchboards, or motor control centers where there are no renewable or adjustable parts such as fuses or switches on the back and where all connections are accessible from locations other than the back.*

*Exception No. 2: By special permission smaller spaces may be permitted (1) where it is judged that the particular arrangement of the installation will provide adequate accessibility, or (2) where all uninsulated parts are at a voltage no greater than 30 volts RMS or 42V dc.*

**(b) Clear Spaces.** Working space required by this section shall not be used for storage. When normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.

**(c) Access and Entrance to Working Space.** At least one entrance of sufficient area shall be provided to give access to the working space about electric equipment.

#### **| 110-17. Guarding of Live Parts (600 Volts, Nominal, or Less).**

**(a)** Except as elsewhere required or permitted by this Code, live parts of electric equipment operating at 50 volts or more shall be guarded against accidental contact by approved enclosures.

**110-18. Arcing Parts.** Parts of electric equipment which in ordinary operation produce arcs, sparks, flames, or molten metal shall be enclosed or separated and isolated from all combustible material.

**110-21. Marking.** The manufacturer's name, trademark, or other descriptive marking by which the organization responsible for the product may be identified shall be placed on all electric equipment. Other markings shall be provided giving voltage, current, wattage, or other ratings as are specified elsewhere in this Code. The marking shall be of sufficient durability to withstand the environment involved.

**110-22. Identification of Disconnecting Means.** Each disconnecting means required by this Code for motors and appliances, and each service, feeder, or branch circuit at the point where it originates shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. The marking shall be of sufficient durability to withstand the environment involved.

## ARTICLE 200 — USE AND IDENTIFICATION OF GROUNDED CONDUCTORS

**200-1. Scope.** This article provides requirements for: (1) identification of terminals; (2) grounded conductors in premises wiring systems; and (3) identification of grounded conductors.

See Article 100 for definitions of "Grounded Conductor" and "Grounding Conductor."

**200-2. General.** All premises wiring systems shall have a grounded conductor that is identified in accordance with Section 200-6.

*Exception: Circuits and systems exempted or prohibited by Sections 210-10, 215-7, 250-3, 250-5, and 250-7 in the NEC.*

The grounded conductor, when insulated, shall have insulation which is suitable, other than color, for any ungrounded conductor of the same circuit on circuits of less than 1000 volts.

**200-3. Connection to Grounded System.** Premises wiring shall not be electrically connected to a supply system unless the latter contains, for any grounded conductor of the interior system, a corresponding conductor which is grounded.

For the purpose of this section, "electrically connected" shall mean connection capable of carrying current as distinguished from connection through electromagnetic induction.

### **200-6. Means of Identifying Grounded Conductors.**

**(a) Sizes No. 6 or Smaller.** An insulated grounded conductor of No. 6 or smaller shall be identified by a continuous white or natural gray outer finish along its entire length.

**(b) Sizes Larger than No. 6.** An insulated grounded conductor larger than No. 6 shall be identified either by a continuous white or natural gray outer finish along its entire length or at the time of installation by a distinctive white marking at its terminations.

**(c) Flexible Cords.** An insulated conductor intended for use as a grounded conductor, where contained within a flexible cord, shall be identified by a white or natural gray outer finish or by methods permitted by Section 400-22 in the NEC.

**200-7. Use of White or Natural Gray Color.** A continuous white or natural gray covering on a conductor or a termination marking of white or natural gray color shall be used only for the grounded conductor.

*Exception No. 1: An insulated conductor with a white or natural gray finish shall be permitted as an ungrounded conductor where permanently reidentified to indicate its use, by painting or other effective means at its termination, and at each outlet where the conductor is visible and accessible.*

*Exception No. 2: A cable containing an insulated conductor with a white or natural gray outer finish shall be permitted for single-pole, 3-way, or 4-way switch loops where the white or natural gray conductor is used for*

*the supply to the switch, but not as a return conductor from the switch to the switched outlet. In these applications, reidentification of the white or natural gray conductor shall not be required.*

*Exception No. 3: A flexible cord for connecting an appliance having one conductor identified with a white or natural gray outer finish, or by any other means permitted by Section 400-22 in the NEC, shall be permitted whether or not the outlet to which it is connected is supplied by a circuit having a grounded conductor.*

*Exception No. 4: A white or natural gray conductor of circuits of less than 50 volts shall be required to be grounded only as required by Section 250-5(a).*

**200-9. Means of Identification of Terminals.** The identification of terminals to which a grounded conductor is to be connected shall be substantially white in color. The identification of other terminals shall be of a readily distinguishable different color.

**200-10. Identification of Terminals.**

**(a) Device Terminals.** All devices provided with terminals for the attachment of conductors and intended for connection to more than one side of the circuit shall have terminals properly marked for identification.

*Exception No. 1: Where the electrical connection of a terminal intended to be connected to the grounded conductor is clearly evident.*

*Exception No. 2: Single-pole devices to which only one side of the line is connected.*

*Exception No. 3: The terminals of lighting and appliance branch-circuit panelboards.*

*Exception No. 4: Devices having a normal current rating of over 30 amperes other than polarized attachment plugs and polarized receptacles for attachment plugs as required in (b) below.*

**(b) Receptacles, Plugs, and Connectors.** Receptacles, polarized attachment plugs and cord connectors for plugs and polarized plugs shall have the terminal intended for connection to the grounded (white) conductor identified.

Identification shall be by a metal or metal coating substantially white in color or the word "white" located adjacent to the identified terminal.

If the terminal is not visible, the conductor entrance hole for the connection shall be colored white or marked with the word "white."

The terminal for the connection of the equipment grounding conductor shall be identified by: (1) a green-colored, not readily removable terminal screw with a hexagonal head; (2) a green-colored, hexagonal, not readily removable terminal nut; or (3) a green-colored pressure wire connector. If the terminal for the grounding conductor is not visible, the conductor entrance hole shall be marked with the word "green" or otherwise identified by a distinctive green color.

*Exception: Terminal identification shall not be required for 2-wire nonpolarized attachment plugs.*

**(c) Screw Shells.** For devices with screw shells, the terminal for the grounded conductor shall be the one connected to the screw shell.



**(d) Screw-Shell Devices with Leads.** For screw-shell devices with attached leads, the conductor attached to the screw shell shall have a white or natural gray finish. The outer finish of the other conductor shall be of a solid color that will not be confused with the white or natural gray finish used to identify the grounded conductor.

**(e) Appliances.** Appliances that have a single-pole switch or a single-pole overcurrent device in the line or any line-connected screw-shell lampholders, and that are to be connected (1) by permanent wiring methods or (2) by field-installed attachment plugs and cords with three or more wires (including the equipment grounding conductor) shall have means to identify the terminal for the grounded circuit conductor (if any).

**200-11. Polarity of Connections.** No grounded conductor shall be attached to any terminal or lead so as to reverse designated polarity.

## ARTICLE 210 — BRANCH CIRCUITS

### A. General Provisions

**210-1. Scope.** The provisions of this article apply to branch circuits supplying lighting or appliance loads or combinations of both. Where motors or motor-operated appliances are connected to any branch circuit that also supplies lighting or other appliance loads, the provisions of both this article and Article 430 in the NEC shall apply. Article 430 applies where a branch circuit supplies motor loads only.

**210-2. Other Articles for Specific-Purpose Branch Circuits.** Branch circuits shall comply with this article and also with the applicable provisions of other articles of this Code. The provisions for branch circuits supplying equipment in the following list amend or supplement the provisions in this article and shall apply to branch circuits referred to therein:

	Article	Section
Class 1, Class 2, and Class 3 Remote Control, Signaling, and Power-Limited Circuits .....	725	
Fixed Electric Space Heating Equipment .....		424-3

**210-3. Classifications.** Branch circuits recognized by this article shall be classified in accordance with the maximum permitted ampere rating or setting of the overcurrent device. The classification for other than individual branch circuits shall be: 15, 20, 30, 40, and 50 amperes. Where conductors of higher ampacity are used for any reason, the ampere rating or setting of the specified overcurrent device shall determine the circuit classification.

**210-4. Multiwire Branch Circuits.** Branch circuits recognized by this article shall be permitted as multiwire circuits. Multiwire branch circuits shall supply only line to neutral load.

*Exception No. 1: A multiwire branch circuit that supplies only one utilization equipment.*

*Exception No. 2: Where all ungrounded conductors of the multiwire branch circuit are opened simultaneously by the branch-circuit overcurrent device.*

All conductors shall originate from the same panelboard.

In dwelling units a multiwire branch circuit supplying more than one receptacle on the same yoke shall be provided with a means to disconnect simultaneously all ungrounded conductors at the panelboard where the branch circuit originated.

### 210-5. Color Code for Branch Circuits.

**(a) Grounded Conductor.** The grounded conductor of a branch circuit shall be identified by a continuous white or natural gray color. Where conductors of different systems are installed in the same raceway, box, auxiliary gutter, or other types of enclosures, one system neutral, if required, shall have an outer covering of white or natural gray. Each other system neutral, if required, shall have an outer covering of white with an

identifiable colored stripe (not green) running along the insulation or other and different means of identification.

**(b) Equipment Grounding Conductor.** The equipment grounding conductor of a branch circuit shall be identified by a continuous green color or a continuous green color with one or more yellow stripes unless it is bare.

*Exception No. 1: As permitted in Section 250-57(b), Exceptions No. 1 and 3 and Section 310-12(b), Exceptions No. 1 and 2 in the NEC.*

*Exception No. 2: The use of conductor insulation having a continuous green color or a continuous green color with one or more yellow stripes shall be permitted for internal wiring of equipment if such wiring does not serve as the lead wires for connection to branch-circuit conductors.*

#### **210-6. Maximum Voltage.**

**(a) Voltage to Ground.** Branch circuits supplying lampholders, fixtures, or standard receptacles rated 15 amperes or less shall not exceed 150 volts to ground.

#### **(c) Voltage Between Conductors.**

**(1)** The voltage shall not exceed 150 volts between conductors on branch circuits supplying screw-shell lampholder(s), receptacle(s), or appliance(s) in dwelling unit(s).

*Exception No. 1: Permanently connected appliances.*

*Exception No. 2: Cord- and plug-connected loads of more than 1380 watts or ¼ horsepower or greater rating.*

#### **210-7. Receptacles and Cord Connectors.**

**(a) Grounding Type.** Receptacles installed on 15- and 20-ampere branch circuits shall be of the grounding type. Grounding-type receptacles shall be installed only on circuits of the voltage class and current for which they are rated, except as provided in Tables 210-21(b) (2) and (b) (3).

*Exception No. 2: Nongrounding-type receptacles installed in accordance with Section 210-7(d), Exception.*

**(b) To Be Grounded.** Receptacles and cord connectors having grounding contacts shall have those contacts effectively grounded.

**(c) Methods of Grounding.** The grounding contacts of receptacles and cord connectors shall be grounded by connection to the equipment grounding conductor of the circuit supplying the receptacle or cord connector.

For installation requirements for the reduction of electrical noise; see Section 250-74, Exception No. 4.

The branch circuit or branch-circuit raceway shall include or provide a grounding conductor to which the grounding contacts of the receptacle or cord connector shall be connected.

Section 250-91(b) describes acceptable grounding means.

For extensions of existing branch circuits, see Section 250-50.

**(d) Replacements.** Grounding-type receptacles shall be used as replacements for existing nongrounding types and shall be connected to a grounding conductor installed in accordance with (c) above.

*Exception: Where a grounding means does not exist in the receptacle enclosure a nongrounding type of receptacle shall be used.*

**(e) Cord-and Plug-Connected Equipment.** The installation of grounding-type receptacles shall not be used as a requirement that all cord-and plug-connected equipment be of the grounded type.

See Section 250-45 for type of cord-and plug-connected equipment to be grounded.

**(f) Noninterchangeable Types.** Receptacles connected to circuits having different voltages, frequencies, or types of current (ac or dc) on the same premises shall be of such design that the attachment plugs used on these circuits are not interchangeable.

## **210-8. Ground-Fault Protection for Personnel.**

### **(a) Dwelling Units.**

**(1)** All 125-volt, single-phase, 15- and 20-ampere receptacles installed in bathrooms shall have ground-fault circuit-interrupter protection for personnel.

**(2)** All 125-volt, single-phase, 15- or 20-ampere receptacles installed in garages shall have ground-fault circuit-interrupter protection for personnel.

*Exception No. 1 to (a)(2): Receptacles which are not readily accessible.*

*Exception No. 2 to (a)(2): Receptacles for appliances occupying dedicated space which are cord- and plug-connected in accordance with Section 400-7(a)(6), (a)(7), or (a)(8).*

Receptacles installed under Exceptions to Section 210-8(a)(2) shall not be considered as meeting the requirements of Section 210-52(f).

**(3)** All 125-volt, single-phase, 15- and 20-ampere receptacles installed outdoors where there is direct grade level access to the dwelling unit and to the receptacles shall have ground-fault circuit-interrupter protection for personnel.

**Bathroom:** A bathroom is an area including a basin with one or more of the following: a toilet, a tub, or a shower.

Such ground-fault circuit-interrupter protection may be provided for other circuits, locations, and occupancies, and, where used, will provide additional protection against line-to-ground shock hazard.

See Section 215-9 for feeder protection.

**(b) Construction Sites.** All 125-volt single-phase, 15- and 20-ampere receptacle outlets which are not a part of the permanent wiring of the building or structure, and which are in use by employees shall have ground-fault circuit-interrupter protection for personnel.

*Exception No. 1: Receptacles on a portable or vehicle-mounted generator rated not more than 5 kW, where the circuit conductors are insulated from the generator frame as permitted in Section 250-6 in the NEC.*

*Exception No. 2: Where a written procedure, acceptable to the authority having jurisdiction, is continuously enforced by a designated individual at the construction site to indicate that equipment grounding conductors for 125-volt, single-phase, 15- and 20-ampere receptacles, flexible cord sets,*

*and equipment connected by cord and plug are installed and maintained in accordance with the applicable requirements of Sections 210-7(c), 250-45, 250-59, and 305-2(d). The procedure shall include electrical continuity tests of all required equipment, grounding conductors and their connections. These tests shall be conducted as follows:*

*a. Fixed receptacles shall be tested where there is evidence of damage.*

*b. Flexible cord sets (extension cords) shall be tested before first use on the construction site. All flexible cord sets shall be tested where there is evidence of damage, and after any repairs.*

*c. Equipment connected by cord and plug shall be tested: (1) before first use on the construction site; (2) where there is evidence of damage; (3) after any repairs; and (4) at intervals not exceeding 3 months.*

**210-10. Ungrounded Conductors Tapped from Grounded Systems.** Two-wire dc circuits and ac circuits of two or more ungrounded conductors shall be permitted to be tapped from the ungrounded conductors of circuits having a grounded neutral conductor. Switching devices in each tapped circuit shall have a pole in each ungrounded conductor. All poles of multipole switching devices shall manually switch together where such switching devices also serve as a disconnecting means as required by Section 422-21(b) for an appliance; Section 424-20 for a fixed electric space heating unit; Section 426-21 in the NEC for electric de-icing and snow-melting equipment; Section 430-85 in the NEC for a motor controller; and Section 430-103 in the NEC for a motor.

## **B. Branch-Circuit Ratings**

### **210-19. Conductors — Minimum Ampacity and Size.**

**(a) General.** Branch-circuit conductors shall have an ampacity of not less than the rating of the branch circuit and not less than the maximum load to be served. Cable assemblies with the neutral conductor smaller than the ungrounded conductors shall be so marked.

See Tables 310-16 through 310-19 for ampacity ratings of conductors.

See Part B of Article 430 in the NEC for minimum rating of motor branch-circuit conductors.

Conductors for branch circuits as defined in Article 100 in the NEC, sized to prevent a voltage drop exceeding 3 percent at the farthest outlet of power, heating, and lighting loads, or combinations of such loads and where the maximum total voltage drop on both feeders and branch circuits to the farthest outlet does not exceed 5 percent, will provide reasonable efficiency of operation. See Section 215-2 for voltage drop on feeder conductors.

**(b) Household Ranges and Cooking Appliances.** Branch-circuit conductors supplying household ranges, wall-mounted ovens, counter-mounted cooking units, and other household cooking appliances shall have an ampacity not less than the rating of the branch circuit and not less than the maximum load to be served. For ranges of 8 3/4 kW or more rating, the minimum branch-circuit rating shall be 40 amperes.

*Exception No. 1: The neutral conductor of a 3-wire branch circuit supplying a household electric range, a wall-mounted oven, or a counter-mounted cooking unit shall be permitted to be smaller than the ungrounded conductors where the maximum demand of a range of 8 3/4*

*kW or more rating has been computed according to Column A of Table 220-19, but shall have an ampacity of not less than 70 percent of the ampacity of the ungrounded conductors and shall not be smaller than No. 10.*

*Exception No. 2: Tap conductors supplying electric ranges, wall-mounted electric ovens, and counter-mounted electric cooking units from a 50-ampere branch circuit shall have an ampacity of not less than 20 and shall be sufficient for the load to be served. The taps shall be no longer than necessary for servicing the appliance.*

**(c) Other Loads.** Branch-circuit conductors supplying loads other than cooking appliances as covered in (b) above and as listed in Section 210-2 shall have an ampacity sufficient for the loads served and shall not be smaller than No. 14.

*Exception No. 1: Tap conductors for such loads shall have an ampacity not less than 15 for circuits rated less than 40 amperes and not less than 20 for circuits rated at 40 or 50 amperes and only where these tap conductors supply any of the following loads:*

*a. Individual lampholders or fixtures with taps extending not longer than 18 inches (457 mm) beyond any portion of the lampholder or fixture.*

*b. A fixture having tap conductors as provided in Section 410-67.*

*c. Individual outlets with taps not over 18 inches (457 mm) long.*

*d. Infrared lamp industrial heating appliances.*

*e. Nonheating leads of de-icing and snow-melting cables and mats.*

*Exception No. 2: Fixture wires and cords as permitted in Section 240-4.*

## **210-20. Overcurrent Protection.**

**(a) General.** Branch-circuit conductors and equipment shall be protected by overcurrent protective devices having a rating or setting (1) not exceeding that specified in Section 240-3 for conductors; (2) not exceeding that specified in the applicable articles referenced in Section 240-2 for equipment; and (3) as provided for outlet devices in Section 210-21.

*Exception: Tap conductors, fixture wire, and cords as permitted in Section 210-19(c) shall be considered as being protected by the circuit overcurrent device.*

See Section 240-1 for the purpose of overcurrent protection and Sections 210-22 and 220-2 for continuous loads.

**210-21. Outlet Devices.** Outlet devices shall have an ampere rating not less than the load to be served and shall comply with (a) and (b) below.

**(a) Lampholders.** Where connected to a branch circuit having a rating in excess of 20 amperes, lampholders shall be of the heavy-duty type. A heavy-duty lampholder shall have a rating of not less than 660 watts if of the admedium type and not less than 750 watts if of any other type.

### **(b) Receptacles.**

**(1)** A single receptacle installed on an individual branch circuit shall have an ampere rating of not less than that of the branch circuit.

See definition of Receptacle in Article 100 in the NEC.

(2) Where connected to a branch circuit supplying two or more receptacles or outlets, a receptacle shall not supply a total cord- and plug-connected load in excess of the maximum specified in Table 210-21(b) (2).

(3) Where connected to a branch circuit supplying two or more receptacles or outlets, receptacle ratings shall conform to the values listed in Table 210-21(b) (3).

(4) It shall be acceptable to base the ampere rating of a range receptacle on a single range demand load specified in Table 220-19.

**Table 210-21(b)(2)**  
**Maximum Cord- and Plug-Connected Load to Receptacle**

Circuit Rating Amperes	Receptacle Rating Amperes	Maximum Load Amperes
15 or 20	15	12
20	20	16
30	30	24

**Table 210-21(b)(3)**  
**Receptacle Ratings for Various Size Circuits**

Circuit Rating Amperes	Receptacle Rating Amperes
15	Not over 15
20	15 or 20
30	30
40	40 or 50
50	50

**210-22. Maximum Loads.** The total load shall not exceed the rating of the branch circuit, and it shall not exceed the maximum loads specified in (a) through (c) below under the conditions specified therein.

(a) **Motor-Operated and Combination Loads.** Where a circuit supplies only motor-operated loads, Article 430 in the NEC shall apply. Where a circuit supplies only air-conditioning and/or refrigerating equipment, Article 440 shall apply. For circuits supplying loads consisting of motor-operated utilization equipment that is fastened in place and that has a motor larger than  $\frac{1}{8}$  horsepower in combination with other loads, the total computed load shall be based on 125 percent of the largest motor load plus the sum of the other loads.

(b) **Inductive Lighting Loads.** For circuits supplying lighting units having ballasts, transformers, or autotransformers, the computed load shall be based on the total ampere ratings of such units and not on the total watts of the lamps.

**(c) Other Loads.** Continuous loads, such as store lighting and similar loads, shall not exceed 80 percent of the rating of the branch circuit.

*Exception No. 1: Motor loads having demand factors computed in accordance with Article 430 in the NEC.*

*Exception No. 2: Circuits that have been derated in accordance with Note 8 to Tables 310-16 through 310-19.*

*Exception No. 3: Circuits supplied by an assembly together with its overcurrent devices that is listed for continuous operation at 100 percent of its rating.*

It shall be acceptable to apply demand factors for range loads in accordance with Table 220-19, including Note 4.

**210-23. Permissible Loads.** In no case shall the load exceed the branch-circuit ampere rating. It shall be acceptable for an individual branch circuit to supply any load for which it is rated. A branch circuit supplying two or more outlets shall supply only the loads specified according to its size in (a) through (c) below and summarized in Section 210-24 and Table 210-24.

**(a) 15- and 20-Ampere Branch Circuits.** A 15- or 20-ampere branch circuit shall be permitted to supply lighting units, appliances, or a combination of both. The rating of any one cord- and plug-connected appliance shall not exceed 80 percent of the branch-circuit ampere rating. The total rating of appliances fastened in place shall not exceed 50 percent of the branch-circuit ampere rating where lighting units, cord- and plug-connected appliances not fastened in place, or both, are also supplied.

*Exception: The small appliance branch circuits required in a dwelling unit(s) by Section 220-3(b) shall supply only the receptacle outlets specified in that section.*

**(b) 30-Ampere Branch Circuits.** A 30-ampere branch circuit shall be permitted to supply fixed lighting units with heavy-duty lampholders in other than dwelling unit(s) or appliances in any occupancy. A rating of any one cord- and plug-connected appliance shall not exceed 80 percent of the branch-circuit ampere rating.

**(c) 40- and 50-Ampere Branch Circuits.** A 40- or 50-ampere branch circuit shall be permitted to supply fixed lighting units with heavy-duty lampholders or infrared heating units in other than dwelling units or cooking appliances that are fastened in place in any occupancy.

**210-24. Branch-Circuit Requirements — Summary.** The requirements for circuits having two or more outlets, other than the receptacle circuits of Section 220-3(b) as specifically provided for above, are summarized in Table 210-24.

### C. Required Outlets

**210-50. General.** Receptacle outlets shall be installed as specified in Section 210-52.

**(a) Cord Pendants.** A cord connector that is supported by a permanently installed cord pendant shall be considered a receptacle outlet.



**Table 210-24**  
**Summary of Branch-Circuit Requirements**

(Type FEP, FEPB, RUW, SA, T, TW, RH, RUH, RHW, RHH, THHN, THW, THWN, and XHHW conductors in raceway or cable.)

CIRCUIT RATING	15 Amp	20 Amp	30 Amp	40 Amp	50 Amp
<b>CONDUCTORS</b> (Min. Size)					
Circuit Wires*	14	12	10	8	6
Taps	14	14	14	12	12
Fixture Wires and Cords	Refer to Section 240-4				
<b>OVERCURRENT PROTECTION</b>	15 Amp	20 Amp	30 Amp	40 Amp	50 Amp
<b>OUTLET DEVICES:</b>					
Lampholders	Any	Any	Heavy	Heavy	Heavy
Permitted	Type	Type	Duty	Duty	Duty
Receptacle	15 Max.	15 or 20	30	40 or 50	50
Rating**	Amp	Amp	Amp	Amp	Amp
<b>MAXIMUM LOAD</b>	15 Amp	20 Amp	30 Amp	40 Amp	50 Amp
<b>PERMISSIBLE LOAD</b>	Refer to Section 210-23(a)	Refer to Section 210-23(a)	Refer to Section 210-23(b)	Refer to Section 210-23(c)	Refer to Section 210-23(c).

\* These ampacities are for copper conductors where derating is not required. See Tables 310-16 through 310-19.

\*\* For receptacle rating of cord-connected electric-discharge lighting fixtures, see Section 410-30(c).

**(b) Cord Connections.** A receptacle outlet shall be installed wherever flexible cords with attachment plugs are used. Where flexible cords are permitted to be permanently connected, it shall be permitted to omit receptacles for such cords.

**(c) Laundry Outlet.** Appliance outlets installed in a dwelling unit for specific appliances, such as laundry equipment, shall be installed within 6 feet (1.83 m) of the intended location of the appliance.

#### **210-52. Dwelling Unit Receptacle Outlets.**

**(a) General Provisions.** In every kitchen, family room, dining room, living room, parlor, library, den, sun room, bedroom, recreation room, or similar rooms of dwelling units, receptacle outlets shall be installed so that no point along the floor line in any wall space is more than 6 feet (1.83 m), measured horizontally, from an outlet in that space, including any wall space 2 feet (610 mm) or more in width and the wall space occupied by sliding panels in exterior walls. The wall space afforded by fixed room dividers, such as free-standing bar-type counters, shall be included in the 6-foot (1.83-m) measurement.

As used in this section a "wall space" shall be considered a wall unbroken along the floor line by doorways, fireplaces, and similar openings. Each wall space 2 or more feet (610 mm or more) wide shall be treated individually and separately from other wall spaces within the room. A wall space shall

be permitted to include two or more walls of a room (around corners) where unbroken at the floor line.

The purpose of this requirement is to minimize the use of cords across doorways, fireplaces, and similar openings.

Receptacle outlets shall, insofar as practicable, be spaced equal distances apart. Receptacle outlets in floors shall not be counted as part of the required number of receptacle outlets unless located close to the wall.

The receptacle outlets required by this section shall be in addition to any receptacle that is part of any lighting fixture or appliance, located within cabinets or cupboards, or located over 5½ feet (1.68 m) above the floor.

*Exception: Permanently installed electric baseboard heaters equipped with factory-installed receptacle outlets or outlets provided as a separate assembly by the manufacturer shall be permitted as the required outlet or outlets for the wall space utilized by such permanently installed heaters. Such receptacle outlets shall not be connected to the heater circuits.*

**(b) Counter Tops.** In kitchen and dining areas of dwelling units a receptacle outlet shall be installed at each counter space wider than 12 inches (305 mm). Counter top spaces separated by range tops, refrigerators, or sinks shall be considered as separate counter top spaces. Receptacles rendered inaccessible by appliances fastened in place or appliances occupying dedicated space shall not be considered as these required outlets.

**(c) Bathrooms.** In dwelling units at least one wall receptacle outlet shall be installed in the bathroom adjacent to the basin location. See Section 210-8(a)(1).

**(d) Outdoor Outlets.** For one-and two-family dwellings at least one receptacle outlet shall be installed outdoors. See Section 210-8(a)(3).

**(e) Laundry Areas.** In dwelling units at least one receptacle outlet shall be installed for the laundry.

*Exception No. 1: In a dwelling unit that is an apartment or living area in a multifamily building where laundry facilities are provided on the premises that are available to all building occupants, a laundry receptacle shall not be required.*

*Exception No. 2: In other than one-family dwellings where laundry facilities are not to be installed or permitted, a laundry receptacle shall not be required.*

**(f) Basements and Garages.** For a one-family dwelling at least one receptacle outlet in addition to any provided for laundry equipment shall be installed in each basement and in each attached garage. See Section 210-8(a)(2).

**210-70. Lighting Outlets Required.** Lighting outlets shall be installed where specified in (a) below.

**(a) Dwelling Unit(s).** At least one wall switch-controlled lighting outlet shall be installed in every habitable room; in bathrooms, hallways, stairways, and attached garages; and at outdoor entrances.

A vehicle door in an attached garage is not considered as an outdoor entrance.

At least one lighting outlet shall be installed in an attic, underfloor space, utility room and basement only where these spaces are used for storage or containing equipment requiring servicing.

*Exception No. 1: In habitable rooms, other than kitchens, one or more receptacles controlled by a wall switch shall be permitted in lieu of lighting outlets.*

*Exception No. 2: In hallways, stairways, and at outdoor entrances remote, central, or automatic control of lighting shall be permitted.*

## ARTICLE 215 — FEEDERS

**215-1. Scope.** This article covers the installation requirements and minimum size and ampacity of conductors for feeders supplying branch-circuit loads as computed in accordance with Article 220. The requirements of Section 215-8 in the NEC shall apply to feeders and other applications where identification is equally necessary.

**215-2. Minimum Rating and Size.** Feeder conductors shall have an ampacity not lower than required to supply the load as computed in Parts B, C, and D of Article 220. The minimum sizes shall be as specified in (a) and (b) below under the conditions stipulated. Feeder conductors for a dwelling unit or a mobile home need not be larger than service-entrance conductors. Note 3 of Table 310-16 shall be permitted to be used for conductor size.

**(a) For Specified Circuits.** The ampacity of feeder conductors shall not be less than 30 where the load supplied consists of the following number and types of circuits: (1) two or more 2-wire branch circuits supplied by a 2-wire feeder; (2) more than two 2-wire branch circuits supplied by a 3-wire feeder; and (3) two or more 3-wire branch circuits supplied by a 3-wire feeder.

**(b) Ampacity Relative to Service-Entrance Conductors.** The feeder conductor ampacity shall not be lower than that of the service-entrance conductors where the feeder conductors carry the total load supplied by service-entrance conductors with an ampacity of 55 or less.

See Examples 1, 1(a), 1(b), 1(c) and 1(d) in Tables and Examples.

**215-3. Overcurrent Protection.** Feeders shall be protected against overcurrent in accordance with the provisions of Part A of Article 240.

**215-5. Diagrams of Feeders.** If required by the authority having jurisdiction a diagram showing feeder details shall be provided prior to the installation of the feeders. Such a diagram shall show the area in square feet of the building or other structure supplied by each feeder, the total connected load before applying demand factors, the demand factors used, the computed load after applying demand factors, and the size type of conductors to be used.

**215-6. Feeder Conductor Grounding Means.** Where a feeder supplies branch circuits in which equipment grounding conductors are required, the feeder shall include or provide a grounding means in accordance with the provisions of Section 250-57 to which the equipment grounding conductors of the branch circuits shall be connected.

**215-7. Ungrounded Conductors Tapped from Grounded Systems.** Two-wire dc circuits and ac circuits of two or more ungrounded conductors may be tapped from the ungrounded conductors of circuits having a grounded neutral conductor. Switching devices in each tapped circuit shall have a pole in each ungrounded conductor.

**215-9. Ground-Fault Protection for Personnel.** Feeders supplying 15- and 20-ampere receptacle branch circuits shall be permitted to be protected by a ground-fault circuit-interrupter in lieu of the provisions for such interrupters as specified in Section 210-8.

## ARTICLE 220 — BRANCH-CIRCUIT AND FEEDER CALCULATIONS

### A. General

**220-1. Scope.** This article provides requirements for determining the number of branch circuits required and for computing branch-circuit and feeder loads.

**220-2. Computation of Branch Circuits.** Branch-circuit loads shall be computed as shown in (a) through (d) below.

**(a) Continuous Loads.** The continuous load supplied by a branch circuit shall not exceed 80 percent of the branch-circuit rating.

*Exception No. 1: Where branch-circuit conductors have been derated in accordance with Note 8 to Tables 310-16 through 310-19.*

*Exception No. 2: Where the assembly, including overcurrent devices, is listed for continuous operation of 100 percent of its rating.*

**(b) Lighting Load for Listed Occupancies.** A unit load of not less than that specified in Table 220-2(b) in the NEC for occupancies listed therein shall constitute the minimum lighting load for each square foot (0.093 sq m) of floor area. The floor area for each floor shall be computed from the outside dimensions of the building, apartment, or other area involved. For dwelling unit(s), the computed floor area shall not include open porches, garages, or unused or unfinished spaces not adaptable for future use.

The unit values herein are based on minimum load conditions and 100 percent power factor, and may not provide sufficient capacity for the installation contemplated.

**(c) Other Loads — All Occupancies.** In all occupancies the minimum load for each outlet for general-use receptacles and outlets not used for general illumination shall be not less than the following, the loads shown being based on nominal branch-circuit voltages.

(1) Outlet for a specific appliance or other load except for a motor load ..... ampere rating of appliance or load served.

(2) Outlet for motor load ..... See Sections 430-22 and 430-24 and Article 440 in the NEC.

(3) An outlet supplying recessed lighting fixture(s) shall be the maximum volt-ampere rating of the equipment and lamps for which the fixture(s) is rated.

(4) Outlet for heavy-duty lampholder ..... 600 volt-amperes.

(5) \*Other outlets ..... 180 volt-amperes per outlet.

For receptacle outlets, each single or multiple receptacle shall be considered at not less than 180 volt-amperes.

\* This provision shall not be applicable to receptacle outlets connected to the circuit specified in Section 220-3(b) nor to receptacle outlets provided for the connection of cord- and plug-connected equipment as provided for in Section 400-7.

**(d) Loads for Additions to Existing Installations.**

**(1) Dwelling Units.** Loads for structural additions to an existing dwelling unit or to a previously unwired portion of an existing dwelling unit, either of which exceeds 500 square feet (46.5 sq m), shall be computed in accordance with (b) above. Loads for new circuits or extended circuits in previously wired dwelling units shall be computed in accordance with either (b) or (c) above.

**220-3. Branch Circuits Required.** Branch circuits for lighting and for appliances, including motor-operated appliances, shall be provided to supply the loads computed in accordance with Section 220-2. In addition, branch circuits shall be provided for specific loads not covered by Section 220-2 where required elsewhere in this Code; for small appliance loads as specified in (b) below; and for laundry loads as specified in (c) below.

**(a) Number of Branch Circuits.** The minimum number of branch circuits shall be determined from the total computed load and the size or rating of the circuits used. In all installations the number of circuits shall be sufficient to supply the load served. In no case shall the load on any circuit exceed the maximum specified by Section 210-22.

**(b) Small Appliance Branch Circuits — Dwelling Unit.**

**(1)** In addition to the number of branch circuits determined in accordance with (a) above, two or more 20-ampere small appliance branch circuits shall be provided for all receptacle outlets specified by Section 210-52 for the small appliance loads, including refrigeration equipment, in the kitchen, pantry, breakfast room, and dining room of a dwelling unit. Such circuits, whether two or more are used, shall have no other outlets.

*Exception: A receptacle installed solely for the electric supply to and support of an electric clock in any of these stipulated rooms or outdoor receptacle outlets shall be supplied either by a small appliance branch circuit or by a general purpose branch circuit.*

**(2)** Receptacle outlets installed in the kitchen shall be supplied by not less than two small appliance branch circuits, either or both of which shall also be permitted to supply receptacle outlets in the other rooms specified in (b)(1) above. Additional small appliance branch circuits shall be permitted to supply receptacle outlets in such other rooms.

**(c) Laundry Branch Circuits — Dwelling Unit.** In addition to the number of branch circuits determined in accordance with (a) and (b) above, at least one additional 20-ampere branch circuit shall be provided to supply the laundry receptacle outlet(s) required by Section 210-52(e). This circuit shall have no other outlets.

**(d) Load Evenly Proportioned Among Branch Circuits.** Where the load is computed on a watts-per-square-foot (0.093 sq m) basis, the wiring system up to and including the branch-circuit panelboard(s) shall be provided to serve not less than the calculated load. This load shall be evenly proportioned among multioutlet branch circuits within the panelboard(s). Branch-circuit overcurrent devices and circuits need only be installed to serve the connected load.

See Examples 1, 1(a), 1(b), 1(c), and 1(d) in Tables and Examples.

**B. Feeders****220-10. General.**

(a) **Ampacity and Computed Loads.** Feeder conductors shall have sufficient ampacity to supply the load served. In no case shall the computed load of a feeder be less than the sum of the loads on the branch circuits supplied as determined by Part A of this article after any applicable demand factors permitted by Parts B, C, or D have been applied.

(b) **Continuous and Noncontinuous Loads.** Where a feeder supplies continuous loads or any combination of continuous and noncontinuous load, neither the ampere rating of the overcurrent device nor the ampacity of the feeder conductors shall be less than the noncontinuous load plus 125 percent of the continuous load.

*Exception: Where the assembly including the overcurrent devices protecting the feeder(s) are listed for operation at 100 percent of their rating, neither the ampere rating of the overcurrent device nor the ampacity of the feeder conductors shall be less than the sum of the continuous load plus the noncontinuous load.*

**220-11. General Lighting.** The demand factors listed in Table 220-11 shall apply to that portion of the total branch-circuit load computed for general illumination. They shall not be applied in determining the number of branch circuits for general illumination.

See Section 220-16 for application of demand factors to small appliance and laundry loads in dwellings.

**Table 220-11. Lighting Load Feeder Demand Factors**

Type of Occupancy	Portion of Lighting Load to Which Demand Factor Applies (wattage)	Demand Factor Percent
Dwelling Units	First 3000 or less at.....	100
	Next 3001 to 120,000 at .....	35
	Remainder over 120,000 at .....	25

**220-14. Motors.** Motor loads shall be computed in accordance with Sections 430-24, 430-25, and 430-26 in the NEC.

**220-15. Fixed Electric Space Heating.** Fixed electric space heating loads shall be computed at 100 percent of the total connected load.

*Exception No. 1: Where reduced loading of the conductors results from units operating on duty-cycle, intermittently, or from all units not operating at one time, the authority having jurisdiction may grant permission for feeder conductors to have an ampacity less than 100 percent, provided the conductors have an ampacity for the load so determined.*

*Exception No. 2: The use of the optional calculations in Sections 220-30 and 220-31 shall be permitted for fixed electric space heating loads in a dwelling unit.*

**220-16. Small Appliance and Laundry Loads — Dwelling Unit.**

**(a) Small Appliance Circuit Load.** In each dwelling unit the feeder load shall be computed at 1500 watts for each 2-wire small appliance branch circuit required by Section 220-3(b) for small appliances supplied by 15- or 20-ampere receptacles on 20-ampere branch circuits in the kitchen, pantry, dining room, and breakfast room. Where the load is subdivided through two or more feeders, the computed load for each shall include not less than 1500 watts for each 2-wire branch circuit for small appliances. These loads shall be permitted to be included with the general lighting load and subjected to the demand factors permitted in Table 220-11 for the general lighting load.

**(b) Laundry Circuit Load.** A feeder load of not less than 1500 watts shall be included for each 2-wire laundry branch circuit installed as required by Section 220-3(c). It shall be permissible to include this load with the general lighting load and subjected to the demand factors provided in Section 220-11.

**220-17. Fixed Appliance Load — Dwelling Unit(s).** It shall be permissible to apply a demand factor of 75 percent to the nameplate-rating load of four or more appliances fastened in place served by the same feeder in a one-family, two-family, or multifamily dwelling.

*Exception: This demand factor shall not be applied to electric ranges, clothes dryers, space heating equipment, or air-conditioning equipment.*

**220-18. Electric Clothes Dryers — Dwelling Unit(s).** The load for household electric clothes dryers in a dwelling unit(s) shall be 5000 watts or the nameplate rating, whichever is larger, for each dryer served. The use of the demand factors in Table 220-18 shall be permitted.

**Table 220-18**  
**Demand Factors for Household Electric Clothes Dryers**

<b>Number of Dryers</b>	<b>Demand Factor Percent</b>
1	100
2	100

**220-19. Electric Ranges and Other Cooking Appliances — Dwelling Unit(s).** The feeder demand load for household electric ranges, wall-mounted ovens, counter-mounted cooking units, and other household cooking appliances individually rated in excess of  $1\frac{1}{4}$  kW shall be permitted to be computed in accordance with Table 220-19. Where two or more single-phase ranges are supplied by a 3-phase, 4-wire feeder, the total load shall be computed on the basis of twice the maximum number connected between any two phases.



**Table 220-19. Demand Loads for Household Electric Ranges, Wall-Mounted Ovens, Counter-Mounted Cooking Units, and Other Household Cooking Appliances over 1½ kW Rating. Column A to be used in all cases except as otherwise permitted in Note 3 below.**

NUMBER OF APPLIANCES	Maximum Demand (See Notes)	Demand Factors Percent (See Note 3)	
	COLUMN A (Not over 12 kW Rating)	COLUMN B (Less than 3½ kW Rating)	COLUMN C (3½ kW to 8¾ kW Rating)
1	8 kW	80%	80%
2	11 kW	75%	65%
3	14 kW	70%	55%
4	17 kW	66%	50%
5	20 kW	62%	45%
6	21 kW	59%	43%

Note 1. Over 12 kW through 27 kW ranges all of same rating. For ranges individually rated more than 12 kW but not more than 27 kW, the maximum demand in Column A shall be increased 5 percent for each additional kW of rating or major fraction thereof by which the rating of individual ranges exceeds 12 kW.

Note 2. Over 12 kW through 27 kW ranges of unequal ratings. For ranges individually rated more than 12 kW and of different ratings but none exceeding 27 kW, an average value of rating shall be computed by adding together the ratings of all ranges to obtain the total connected load (using 12 kW for any range rated less than 12 kW) and dividing by the total number of ranges; and then the maximum demand in Column A shall be increased 5 percent for each kW or major fraction thereof by which this average value exceeds 12 kW.

Note 3. Over 1¾ kW through 8¾ kW. In lieu of the method provided in Column A, it shall be permissible to add the nameplate ratings of all ranges rated more than 1¾ kW but not more than 8¾ kW and multiply the sum by the demand factors specified in Column B or C for the given number of appliances.

Note 4. Branch-Circuit Load. It shall be permissible to compute the branch-circuit load for one range in accordance with Table 220-19. The branch-circuit load for one wall-mounted oven or one counter-mounted cooking unit shall be the nameplate rating of the appliance. The branch-circuit load for a counter-mounted cooking unit and not more than two wall-mounted ovens, all supplied from a single branch circuit and located in the same room, shall be computed by adding the nameplate rating of the individual appliances and treating this total as equivalent to one range.

**220-21. Noncoincident Loads.** Where it is unlikely that two dissimilar loads will be in use simultaneously, it shall be permissible to omit the smaller of the two in computing the total load of a feeder.

**220-22. Feeder Neutral Load.** The feeder neutral load shall be the maximum unbalance of the load determined by this article. The maximum unbalanced load shall be the maximum connected load between the neutral and any one ungrounded conductor, except that the load thus obtained shall be multiplied by 140 percent for 5-wire, 2-phase systems. For a feeder supplying household electric ranges, wall-mounted ovens, and counter-mounted cooking units, the maximum unbalanced load shall be considered as 70 percent of the load on the ungrounded conductors, as determined in accordance with Table 220-19. For 3-wire dc or single-phase ac, 4-wire, 3-phase, and 5-wire, 2-phase systems, a further demand factor of 70 percent shall be permitted for that portion of the unbalanced load in excess of 200 amperes. There shall be no reduction of the neutral capacity for that portion of the load which consists of electric-discharge lighting.

See Examples 1, 1(a), 1(b), 1(c), and 1(d) in Tables and Examples.

### C. Optional Calculations for Computing Feeder and Service Loads

#### 220-30. Optional Calculation — Dwelling Unit.

**(a) Feeder and Service Load.** For a dwelling unit having the total connected load served by a single 3-wire, 120/240-volt or 208Y/120-volt set of service-entrance or feeder conductors with an ampacity of 100 or greater, it shall be permissible to compute the feeder and service loads in accordance with Table 220-30 instead of the method specified in Part B of this article. Feeder and service-entrance conductors whose demand load is determined by this optional calculation shall be permitted to have the neutral load determined by Section 220-22.

**(b) Loads.** The loads identified in Table 220-30 as “other load” and as “remainder of other load” shall include the following:

(1) 1500 watts for each 2-wire, 20-ampere small appliance branch circuit and each laundry branch circuit specified in Section 220-16.

(2) 3 watts per square foot (0.093 sq m) for general lighting and general-use receptacles.

(3) The nameplate rating of all fixed appliances, ranges, wall-mounted ovens, counter-mounted cooking units, and including four or more separately controlled space heating units.

**Table 220-30**  
**Optional Calculation for Dwelling Unit**

Load (in kW or kVA)	Demand Factor Percent
Largest of [see Section 220-30(c)]	
Air conditioning and cooling, including heat pump compressors .....	100
Central electric space heating including integral supplemental heating in heat pumps .....	65
Less than four separately controlled electric space heating units. ....	65
Plus:	
First 10 kW of all other load .....	100
Remainder of other load .....	40

(4) The nameplate ampere or kVA rating of all motors and of all low-power-factor loads.

(c) **Largest Load.** When applying Section 220-21 to Table 220-30 use the largest of the following:

(1) Air-conditioning load.

(2) The 65 percent diversified demand of the central electric space heating load including integral supplemental heating in heat pumps.

(3) The 65 percent diversified demand of the load of less than four separately controlled electric space heating units.

(4) The connected load of four or more separately controlled electric space heating units.

**220-31. Optional Calculation for Additional Loads in Existing Dwelling Unit.** For an existing dwelling unit presently being served by an existing 120/240 volt or 208Y/120, 3-wire, 60-ampere service, it shall be permissible to compute load calculations as follows:

Load (in kW or kVA)	Percent of Load
First 8 kW of load at	100%
Remainder of load at	40%

Load calculation shall include lighting at 3 watts per square foot (0.093 sq m): 1500 watts for each 20-ampere appliance circuit, range or wall-mounted oven and counter-mounted cooking unit and other appliances that are permanently connected or fastened in place at nameplate rating.

If air-conditioning equipment or electric space heating equipment is to be installed the following formula shall be applied to determine if the existing service is of sufficient size.

Air-conditioning equipment*	100%
Central electric space heating*	100%
Less than four separately controlled space heating units*	100%
First 8 kW of all other load	100%
Remainder of all other load	40%

Other loads shall include:

1500 watts for each 20-ampere appliance circuit.

Lighting and portable appliances at 3 watts per square foot (0.093 sq m)

Household range or wall-mounted oven and counter-mounted cooking unit.

All other appliances fastened in place, including four or more separately controlled space heating units, at nameplate rating.

\* Use larger connected load of air conditioning and space heating, but not both.

## ARTICLE 230 — SERVICES

### A. General

**230-1. Scope.** This article covers service conductors and equipment for control and protection of services; the number, types, and sizes of services and service equipment; and the installation requirements.

**230-2. Number of Services.** A building or other structure served shall be supplied by only one service.

Where more than one service is permitted by any of the following exceptions, a permanent plaque or directory shall be installed at each service drop or lateral or at each service-equipment location denoting all other services on or in that building or structure and the area served by each.

*Exception No. 3: Two-Family Dwellings.*

*b. A two-family dwelling shall be permitted to have two or more separate sets of service-entrance conductors which are tapped from one service drop or lateral.*

*Exception No. 6: For different characteristics, such as for different voltagages, frequencies, or phases, or for different uses, such as for different rate schedules.*

**230-3. One Building or Other Structure Not to Be Supplied Through Another.** Service conductors supplying a building or other structure shall not pass through the interior of another building or other structure.

*Exception: Where the buildings or other structures served are under single occupancy or management.*

See Section 230-44 for masonry-encased conductors considered outside of a building.

### B. Insulation and Size of Service Conductors

**230-4. Insulation of Service Conductors.** Service conductors shall normally withstand exposure to atmospheric and other conditions of use without detrimental leakage of current.

For Service Drops — See Section 230-22.

For Underground Services — See Section 230-30.

For Service-Entrance Conductors — See Section 230-40.

**230-5. Size of Service Conductors.** Service conductors shall have adequate ampacity to conduct safely the current for the loads supplied without a temperature rise detrimental to the insulation or covering of the conductors, and shall have adequate mechanical strength.

Minimum sizes are given in the following references:

For Service Drops — See Section 230-23.

For Underground Service Conductors — See Section 230-31.

For Service-Entrance Conductors — See Section 230-41.

For Farmstead Service Conductors — See Part D of Article 220.

### C. Overhead Services

**230-21. Overhead Supply.** Overhead conductors to a building or other structure from another building or other structure (such as a pole) on which

a meter or disconnecting means is installed shall be considered as a service drop and installed accordingly.

Example: Farm loads in Part D of Article 220.

**230-22. Insulation or Covering.** Individual conductors shall be insulated or covered with an extruded thermoplastic or thermosetting insulating material.

*Exception: The grounded conductor of a multiconductor cable shall be permitted to be bare.*

**230-23. Size and Rating.** Conductors shall have sufficient ampacity to carry the load. They shall have adequate mechanical strength and shall not be smaller than No. 8 copper, No. 6 aluminum or copper-clad aluminum.

*Exception: For installations to supply only limited loads of a single branch circuit such as small polyphase power, controlled water heaters and the like, they shall not be smaller than No. 12 hard-drawn copper or equivalent.*

The grounded conductor shall not be less than the minimum size required by Section 250-23(b).

**230-24. Clearances.** The vertical clearances of all service-drop conductors shall be based on conductor temperature of 60°F, no wind, with final unloaded sag in the wire, conductor, or cable.

Service-drop conductors shall not be readily accessible and shall comply with (a) through (d) below for services not over 600 volts, nominal.

**(a) Above Roofs.** Conductors shall have a vertical clearance of not less than 8 feet (2.44 m) from all points of roofs above which they pass.

*Exception No. 1: Where the voltage between conductors does not exceed 300 and the roof has a slope of not less than 4 inches (102 mm) in 12 inches (305 mm), a reduction in clearance to 3 feet (914 mm) shall be permitted.*

*Exception No. 2: Where the voltage between conductors does not exceed 300, a reduction in clearance above only the overhanging portion of the roof to not less than 18 inches (457 mm) shall be permitted if (1) not more than 4 feet (1.22 m) of service-drop conductors pass above the roof overhang, and (2) they are terminated at a through-the-roof raceway or approved support.*

See Section 230-28 for mast supports.

**(b) Vertical Clearance from Ground.** Service-drop conductors where not in excess of 600 volts, nominal, shall have the following minimum clearance from final grade.

10 feet (3.05 m) — at the electric service entrance to buildings, or at the drip loop of the building electric entrance, measured from final grade or other accessible surface only for service-drop cables supported on and cabled together with a grounded bare messenger and limited to 150 volts to ground.

12 feet (3.66 m) — for those areas listed in the 15 foot (4.57 m) classification when the voltage is limited to 300 volts to ground.

15 feet (4.57 m) — over residential property and driveways, and those commercial areas not subject to truck traffic.

18 feet (5.49 m) — over public streets, alleys, roads, and parking areas subject to truck traffic.

**(c) Clearance from Building Openings.** Service conductors shall have a clearance of not less than 3 feet (914 mm) from windows, doors, porches, fire escapes, or similar locations.

Conductors run above the top level of a window shall be considered out of reach from that window.

**(d) Clearance from Swimming Pools.** See Section 680-8 in the NEC.

**230-26. Point of Attachment.** The point of attachment of conductors to a building or other structure shall provide the minimum clearances as specified in Section 230-24. In no case shall this point of attachment be less than 10 feet (3.05 m) above finished grade.

**230-27. Means of Attachment.** Multiconductor cables used for service drops shall be attached to buildings or other structures by fittings identified for use with service conductors. Open conductors shall be attached to fittings identified for use with service conductors or to noncombustible, nonabsorbent insulators securely attached to the building or other structure.

**230-28. Service Masts as Supports.** Where a service mast is used for the support of service-drop conductors, it shall be of adequate strength or be supported by braces or guys to withstand safely the strain imposed by the service drop. Where raceway-type service masts are used, all raceway fittings shall be identified for use with service masts.

**230-29. Supports Over Buildings.** Service-drop conductors passing over a roof shall be securely supported by substantial structures. Where practicable, such supports shall be independent of the building.

#### **D. Underground Services**

**230-30. Insulation.** Service lateral conductors shall be insulated for the applied voltage.

*Exception: A grounded conductor shall be permitted to be uninsulated as follows:*

- a. Bare copper used in a raceway.*
- b. Bare copper for direct burial where bare copper is judged to be suitable for the soil conditions.*
- c. Bare copper for direct burial without regard to soil conditions when part of a cable assembly identified for underground use.*
- d. Aluminum or copper-clad aluminum without individual insulation or covering when part of a cable assembly identified for underground use in a raceway or for direct burial.*

**230-31. Size and Rating.** Conductors shall have sufficient ampacity to carry the load. They shall not be smaller than No. 8 copper or No. 6 aluminum or copper-clad aluminum. The grounded conductor shall not be less than the minimum size required by Section 250-23(b).

*Exception: For installations to supply only limited loads of a single branch circuit such as small polyphase power, controlled water heaters and the like, they shall not be smaller than No. 12 copper or No. 10 aluminum or copper-clad aluminum.*

### E. Service-Entrance Conductors

**230-40. Insulation of Service-Entrance Conductors.** Service-entrance conductors entering or on the exterior of buildings or other structures shall be insulated.

*Exception: A grounded conductor shall be permitted to be uninsulated as follows:*

*a. Bare copper used in a raceway or part of a service cable assembly.*

*b. Bare copper for direct burial where bare copper is judged to be suitable for the soil conditions.*

*c. Bare copper for direct burial without regard to soil conditions when part of a cable assembly identified for underground use.*

*d. Aluminum or copper-clad aluminum without individual insulation or covering when part of a cable assembly identified for underground use in a raceway or for direct burial.*

### 230-41. Size and Rating.

**(a) General.** Conductors shall be of sufficient size to carry the loads as computed in accordance with Article 220. Ampacity shall be determined from Tables 310-16 through 310-19 and all applicable notes to these tables.

**(b) Ungrounded Conductors.** Ungrounded conductors shall not be smaller than:

**(1)** 100-ampere, 3-wire, for a one-family dwelling with six or more 2-wire branch circuits.

**(2)** 100-ampere, 3-wire, for a one-family dwelling with an initial computed load of 10 kW or more.

**(3)** 60 amperes for other loads.

*Exception No. 1: For loads consisting of not more than two 2-wire branch circuits, No. 8 copper or No. 6 aluminum or copper-clad aluminum.*

*Exception No. 2: By special permission, for loads limited by demand or by the source of supply, No. 8 copper or No. 6 aluminum or copper-clad aluminum.*

*Exception No. 3: For limited loads of a single branch circuit, No. 12 copper or No. 10 aluminum or copper-clad aluminum, but in no case smaller than the branch-circuit conductors.*

**(c) Grounded Conductors.** The grounded (neutral) conductor shall not be less than the minimum size as required by Section 250-23(b).

### F. Installation of Service Conductors

**230-43. Wiring Methods for 600 Volts, Nominal, or Less.** Service-entrance conductors shall be installed in accordance with the applicable requirements of this Code covering the type of wiring method used and limited to the following methods: (1) open wiring on insulators; (2) rigid metal conduit; (3) intermediate metal conduit; (4) electrical metallic tubing; (5) service-entrance cables; (6) wireways; (7) busways; (8) auxiliary gutters; (9) rigid nonmetallic conduit; (10) cablebus; (11) Type MC cable; or (12) mineral-insulated, metal-sheathed cable.

**230-44. Conductors Considered Outside of Building.** Conductors shall be considered outside of a building or other structure under any of the following conditions: (1) where installed under not less than 2 inches (50.8 mm) of concrete beneath a building or other structure, or (2) where installed within a building or other structure in a raceway that is enclosed by concrete or brick not less than 2 inches (50.8 mm) thick.

**230-45. Separate Enclosures.** Where two to six service disconnecting means in separate enclosures supply separate loads from one service drop or lateral, one set of service-entrance conductors shall be permitted to supply each or several such service equipment enclosures.

**230-46. Unspliced Conductors.** Service-entrance conductors shall not be spliced.

*Exception No. 1: Clamped or bolted connections in metering equipment enclosures shall be permitted.*

*Exception No. 2: Where service-entrance conductors are tapped to supply two to six disconnecting means grouped at a common location.*

*Exception No. 3: At a properly enclosed junction point where an underground wiring method is changed to another type of wiring method.*

*Exception No. 4: A connection shall be permitted where service conductors are extended from a service drop to an outside meter location and returned to connect to the service-entrance conductors of an existing installation.*

**230-47. Other Conductors in Raceway or Cable.** Conductors other than service conductors shall not be installed in the same service raceway or service-entrance cable.

*Exception No. 1: Grounding conductors.*

*Exception No. 2: Time switch conductors having overcurrent protection.*

**230-48. Raceway Seal.** Where a service raceway enters from an underground distribution system, it shall be sealed in accordance with Section 300-5. Spare or unused raceways shall also be sealed. Sealants shall be identified for use with the cable insulation, shield, or other components.

**230-49. Protection Against Damage — Underground.** Underground service conductors shall be protected against physical damage in accordance with Section 300-5.

**230-50. Protection of Open Conductors and Cables Against Damage — Aboveground.** Service-entrance conductors installed aboveground shall be protected against physical damage as specified in (a) or (b) below.

**(a) Service-Entrance Cables.** Service-entrance cables, where subject to physical damage, such as where installed in exposed places near driveways or coal chutes, or where subject to contact with awnings, shutters, swinging signs, or similar objects, shall be protected in any of the following ways: (1) by rigid metal conduit; (2) by intermediate metal conduit; (3) by rigid nonmetallic conduit suitable for the location; (4) by electrical metallic tubing; (5) by Type MC cable; or (6) by other approved means.



**(b) Other than Service-Entrance Cable.** Individual open conductors and cables other than service-entrance cables shall not be installed within 10 feet (3.05 m) of grade level or where exposed to physical damage.

**230-51. Mounting Supports.** Cables or individual open service conductors shall be supported as specified in (a), (b), or (c) below.

**(a) Service-Entrance Cables.** Service-entrance cables shall be supported by straps or other approved means within 12 inches (305 mm) of every service head, gooseneck, or connection to a raceway or enclosure and at intervals not exceeding 4 ½ feet (1.37 m).

**(b) Other Cables.** Cables that are not approved for mounting in contact with a building or other structure shall be mounted on insulating supports installed at intervals not exceeding 15 feet (4.57 m) and in a manner that will maintain a clearance of not less than 2 inches (50.8 mm) from the surface over which they pass.

**230-53. Raceways to Drain.** Where exposed to the weather, raceways enclosing service-entrance conductors shall be raintight and arranged to drain. Where embedded in masonry, raceways shall be arranged to drain.

**230-54. Connections at Service Head.**

**(a) Raintight Service Head.** Service raceways shall be equipped with a raintight service head.

**(b) Service Cable Equipped with Raintight Service Head or Gooseneck.** Service cables, either (1) unless continuous from pole to service equipment or meter, shall be equipped with a raintight service head, or (2) formed in a gooseneck and taped and painted or taped with a self-sealing, weather-resistant thermoplastic.

**(c) Service Heads Above Service-Drop Attachment.** Service heads and goosenecks in service-entrance cables shall be located above the point of attachment of the service-drop conductors to the building or other structure.

*Exception: Where it is impracticable to locate the service head above the point of attachment, the service head location shall be permitted not farther than 24 inches (610 mm) from the point of attachment.*

**(d) Secured.** Service cables shall be held securely in place.

**(e) Opposite Polarity Through Separately Bushed Holes.** Service heads shall have conductors of opposite polarity brought out through separately bushed holes.

**(f) Drip Loops.** Drip loops shall be formed on individual conductors. To prevent the entrance of moisture, service-entrance conductors shall be connected to the service-drop conductors either (1) below the level of the service head, or (2) below the level of the termination of the service-entrance cable sheath.

**(g) Arranged that Water Will Not Enter Service Raceway or Equipment.** Service-drop conductors and service-entrance conductors shall be arranged so that water will not enter service raceway or equipment.

**230-55. Termination at Service Equipment.** Any service raceway or cable shall terminate at the inner end in a box, cabinet, or equivalent fitting that effectively encloses all live metal parts.

*Exception: Where the service disconnecting means is mounted on a switchboard having exposed busbars on the back, a raceway shall be permitted to terminate at a bushing.*

#### **G. Service Equipment — Guarding and Grounding**

**230-62. Service Equipment — Enclosed or Guarded.** Live parts of service equipment shall be enclosed as specified in (a) below, or guarded as specified in (b) below.

(a) **Enclosed.** Live parts shall be enclosed so that they will not be exposed to accidental contact or guarded as in (b) below.

(b) **Guarded.** Live parts that are not enclosed shall be installed on a switchboard, panelboard, or control board and guarded in accordance with Sections 110-17 and 110-18. Such an enclosure shall be provided with means for locking or sealing doors giving access to live parts.

**230-63. Grounding and Bonding.** Service equipment, raceways, cable armor, cable sheaths, etc., and any service conductor that is to be grounded shall be grounded in accordance with the following parts of Article 250.

Part B. Circuit and System Grounding.

Part C. Location of System Grounding Connections.

Part D. Enclosure Grounding.

Part F. Methods of Grounding.

Part G. Bonding.

Part H. Grounding Electrode Systems.

Part J. Grounding Conductors.

#### **H. Service Equipment — Disconnecting Means**

**230-70. General.** Means shall be provided to disconnect all conductors in a building or other structure from the service-entrance conductors. Each service disconnecting means shall be permanently marked to identify it as a service disconnecting means and shall be of the type that is suitable for use as service equipment. Each service disconnecting means shall be suitable for the prevailing conditions.

#### **230-71. Maximum Number of Disconnects.**

(a) **General.** The service disconnecting means for each service or for each set of service-entrance conductors permitted by Section 230-2, Exception No. 3b, shall consist of not more than six switches or six circuit breakers mounted in a single enclosure, in a group of separate enclosures, or in or on a switchboard.

(b) **Single-Pole Units.** Two or three single-pole switches or breakers, capable of individual operation, shall be permitted on multiwire circuits, one pole for each ungrounded conductor, as one multipole disconnect provided they are equipped with "handle ties" or a "master handle" to disconnect all conductors of the service with no more than six operations of the hand.

See Section 384-16(a) for service equipment in panelboards.

#### **230-72. Grouping of Disconnects.**

(a) **General.** The two to six disconnects for each service as permitted in Section 230-71 shall be grouped. Each disconnect shall be marked to indicate the load served.

*Exception No. 2: One of the two to six service disconnecting means permitted in Section 230-71, when used only for a water pump also intended to provide fire protection, shall be permitted to be located remote from the other disconnecting means.*

**(c) Location.** The service disconnecting means shall be installed either inside or outside of a building or other structure at a readily accessible location nearest the point of entrance of the service-entrance conductors.

**(d) Access to Occupants.** In a two-family building, each occupant shall have access to his disconnecting means.

**230-73. Working Space.** Sufficient working space shall be provided in the vicinity of the service disconnecting means to permit safe operation, inspection, and repairs. In no case shall this be less than that specified by Section 110-16.

**230-74. Simultaneous Opening of Poles.** Each disconnecting means shall simultaneously disconnect all ungrounded conductors.

**230-75. Disconnection of Grounded Conductor.** Where the service disconnecting means does not disconnect the grounded conductor from the premises wiring, other means shall be provided for this purpose in the service equipment. A terminal or bus to which all grounded conductors can be attached by means of pressure connectors shall be permitted for this purpose.

**230-76. Manually or Power Operable.** The disconnecting means for ungrounded conductors shall consist of either (1) a manually operable switch or circuit breaker equipped with a handle or other suitable operating means, or (2) a power-operated switch or circuit breaker provided the switch or circuit breaker can be opened by hand in the event of a power supply failure.

**230-77. Indicating.** The disconnecting means shall plainly indicate whether it is in the open or closed position.

**230-78. Externally Operable.** An enclosed service disconnecting means shall be externally operable without exposing the operator to contact with live parts.

*Exception: A power-operated switch or circuit breaker shall not be required to be externally operable by hand to a closed position.*

**230-79. Rating of Disconnect.** The service disconnecting means shall have a rating not less than the load to be carried, determined in accordance with Article 220. In no case shall the rating be lower than specified in (c) or (d) below.

**(c) One-Family Dwelling.** For a one-family dwelling, the service disconnecting means shall have a rating of not less than 100 amperes, 3-wire under either of the following conditions: (1) where the initial computed load is 10 kW or more, or (2) where the initial installation consists of six or more 2-wire branch circuits.

**(d) All Others.** For all other installations the service disconnecting means shall have a rating of not less than 60 amperes.

**230-80. Combined Rating of Disconnects.** Where the service disconnecting means consists of more than one switch or circuit breaker, as

permitted by Section 230-71, the combined ratings of all the switches or circuit breakers used shall not be less than the rating required for a single switch or circuit breaker.

**230-81. Connection to Terminals.** The service conductors shall be connected to the service disconnecting means by pressure connectors, clamps, or other approved means. Connections that depend upon solder shall not be used.

**230-82. Equipment Connected to the Supply Side of Service Disconnect.** Equipment shall not be connected to the supply side of the service disconnecting means.

*Exception No. 1: Cable limiters or other current-limiting devices.*

*Exception No. 2: Fuses and disconnecting means or circuit breakers suitable for use as service equipment, in meter pedestals or otherwise provided and connected in series with the ungrounded service conductors and located away from the building supplied.*

*Exception No. 3: Meters nominally rated not in excess of 600 volts, provided all metal housings and service enclosures are grounded in accordance with Article 250.*

*Exception No. 4: Instrument transformers (current and potential), high-impedance shunts, surge-protective devices identified for use on the supply side of the service disconnect, time switches, and surge arresters.*

*Exception No. 5: Taps used only to supply time switches, circuits for emergency systems, stand-by power systems, fire pump equipment, and fire and sprinkler alarms if provided with service equipment and installed in accordance with requirements for service-entrance conductors.*

**230-84. More than One Building or Other Structure.**

**(a) Disconnect Required for Each.** Where more than one building or other structure is on the same property and under single management, each building or other structure served shall be provided with means for disconnecting all ungrounded conductors.

Location shall be in accordance with Section 230-72(c) and (d).

**(b) Suitable for Service Equipment.** The disconnecting means specified in (a) above shall be suitable for use as service equipment.

*Exception: For garages and outbuildings on residential property, a snap switch or a set of 3-way or 4-way snap switches suitable for use on branch circuits shall be permitted as the disconnecting means.*

## **J. Service Equipment — Overcurrent Protection**

**230-90. Where Required.** Each ungrounded service-entrance conductor shall have overcurrent protection.

**(a) Ungrounded Conductor.** Such protection shall be provided by an overcurrent device in series with each ungrounded service conductor having a rating or setting not higher than the allowable ampacity of the conductor.

*Exception No. 2: Fuses and circuit breakers with a rating or setting in conformity with Section 240-3, Exception No. 1, and Section 240-6 (in the NEC).*

*Exception No. 3: Not more than six circuit breakers or six sets of fuses shall be considered as the overcurrent device.*

*Exception No. 4: In a multiple-occupancy building each occupant shall have access to his overcurrent protection devices.*

A set of fuses shall be considered all the fuses required to protect all the ungrounded conductors of a circuit. Single-pole circuit breakers, grouped in accordance with Section 230-71(b), shall be considered as one protective device.

**(b) Not in Grounded Conductor.** No overcurrent device shall be inserted in a grounded service conductor except a circuit breaker which simultaneously opens all conductors of the circuit.

**(c) More than One Building.** In a property comprising more than one building under single management, the ungrounded conductors supplying each building served shall be protected by overcurrent devices, which may be located in the building served or in another building on the same property, provided they are accessible to the occupants of the building served.

**230-91. Location.** The service overcurrent device shall be an integral part of the service disconnecting means or shall be located immediately adjacent thereto.

**230-92. Location of Branch-Circuit Overcurrent Devices.** Where the service overcurrent devices are locked or sealed, or otherwise not readily accessible, branch-circuit overcurrent devices shall be installed on the load side, shall be mounted in an accessible location, and shall be of lower rating than the service overcurrent device.

**230-94. Relative Location of Overcurrent Device and Other Service Equipment.** The overcurrent device shall protect all circuits and devices.

*Exception No. 1: The service switch shall be permitted on the supply side.*

*Exception No. 2: High-impedance shunt circuits, lightning arresters, surge protective capacitors, and instrument transformers (current and potential) shall be permitted to be connected and installed on the supply side of the service disconnecting means as permitted in Section 230-82.*

*Exception No. 3: Circuits for emergency supply and time switches shall be permitted to be connected on the supply side of the service overcurrent device where separately provided with overcurrent protection.*

*Exception No. 4: Circuits used only for the operation of fire alarm, other protective signaling systems, or the supply to fire pump equipment shall be permitted to be connected on the supply side of the service overcurrent device where separately provided with overcurrent protection.*

*Exception No. 5: Meters nominally rated not in excess of 600 volts, provided all metal housings and service enclosures are grounded in accordance with Article 250.*

**230-96. Working Space.** Sufficient working space shall be provided in the vicinity of the service overcurrent devices to permit safe operation, replacements, inspection, and repairs. In no case shall this be less than that specified by Section 110-16.

**230-98. Available Short-Circuit Current.** Service equipment shall be suitable for the short-circuit current available at its supply terminals.

## ARTICLE 240 — OVERCURRENT PROTECTION

**240-1. Scope.** Parts A through E of this article provide the general requirements for overcurrent protection and overcurrent protective devices not more than 600 volts, nominal.

Overcurrent protection for conductors and equipment is provided to open the circuit if the current reaches a value that will cause an excessive or dangerous temperature in conductors or conductor insulation. See also Sections 110-9 and 110-10 for requirements for interrupting capacity and protection against fault currents.

### A. General

**240-2. Protection of Equipment.** Equipment shall be protected against overcurrent in accordance with the article in this Code covering the type of equipment as specified in the following list.

	Article
Appliances .....	422
Class 1, Class 2, and Class 3 Remote Control, Signaling, and Power-Limited Circuits .....	725
Fixed Electric Space Heating Equipment .....	424
Services .....	230
Transformers and Transformer Vaults .....	450

**240-3. Protection of Conductors — Other than Flexible Cords and Fixture Wires.** Conductors, other than flexible cords and fixture wires, shall be protected against overcurrent in accordance with their ampacities as specified in Tables 310-16 through 310-19 and all applicable notes to these tables.

*Exception No. 1: Next Higher Overcurrent Protective Device Rating.* Where the ampacity of the conductor does not correspond with the standard ampere rating of a fuse or a circuit breaker without overload trip adjustment above its rating (but which may have other trip or rating adjustments), the next higher standard device rating shall be permitted only if this rating does not exceed 800 amperes.

*Exception No. 2: Tap Conductors.* Tap conductors as permitted in Sections 210-19(c); 240-21, Exceptions No. 2, 3, 5, and 8; 364-10 and 364-11; and Part D of Article 430 in the NEC.

**240-4. Protection of Fixture Wires and Cords.** Fixture wire or flexible cord, size No. 16 or No. 18, and tinsel cord shall be considered as protected by 20-ampere overcurrent devices.

Flexible cord approved for use with specific appliances shall be considered as protected by the overcurrent device of the branch circuit of Article 210 when conforming to the following:

- 20-ampere circuits, No. 18 cord and larger.
- 30-ampere circuits, cord of 10-ampere capacity and over.
- 40-ampere circuits, cord of 20-ampere capacity and over.
- 50-ampere circuits, cord of 20-ampere capacity and over.

Fixture wire shall be considered as protected by the overcurrent device of the branch circuit of Article 210 when conforming to the following:

- 20-ampere circuits, No. 18 and larger.
- 30-ampere circuits, No. 14 and larger.
- 40-ampere circuits, No. 12 and larger.
- 50-ampere circuits, No. 12 and larger.

**240-8. Fuses or Circuit Breakers in Parallel.** Fuses, circuit breakers, or combinations thereof shall not be connected in parallel.

*Exception: Circuit breakers or fuses, factory assembled in parallel, and approved as a unit.*

## B. Location

### 240-20. Ungrounded Conductors.

**(a) Overcurrent Device Required.** A fuse or an overcurrent trip unit of a circuit breaker shall be connected in series with each ungrounded conductor. A combination of a current transformer and overcurrent relay shall be considered equivalent to an overcurrent trip unit.

For motor circuits, see Parts C, D, F, and J of Article 430 in the NEC.

**(b) Circuit Breaker as Overcurrent Device.** Circuit breakers shall open all ungrounded conductors of the circuit.

*Exception: Individual single-pole circuit breakers shall be acceptable as the protection for each conductor of ungrounded 2-wire circuits, each ungrounded conductor of 3-wire direct-current or single-phase circuits, or for each ungrounded conductor of lighting or appliance branch circuits connected to 4-wire, 3-phase systems or 5-wire, 2-phase systems, provided such lighting or appliance circuits are supplied from a system having a grounded neutral and no conductor in such circuits operates at a voltage greater than permitted in Section 210-6.*

**240-22. Grounded Conductors.** No overcurrent device shall be connected in series with any conductor that is intentionally grounded.

*Exception No. 1: Where the overcurrent device opens all conductors of the circuit, including the grounded conductor, and is so designed that no pole can operate independently.*

**240-23. Change in Size of Grounded Conductor.** Where a change occurs in the size of the ungrounded conductor, a similar change may be made in the size of the grounded conductor.

### 240-24. Location in or on Premises.

**(a) Readily Accessible.** Overcurrent devices shall be readily accessible.

*Exception No. 1: For services.*

**(b) Occupant to Have Ready Access.** Each occupant shall have ready access to all overcurrent devices protecting the conductors supplying his occupancy.

**(c) Not Exposed to Physical Damage.** Overcurrent devices shall be located where they will not be exposed to physical damage.

**(d) Not in Vicinity of Easily Ignitable Material.** Overcurrent devices shall not be located in the vicinity of easily ignitable material such as in clothes closets.

### C. Enclosures

**240-30. General.** Overcurrent devices shall be enclosed in cabinets or cutout boxes.

*Exception No. 1: Where a part of an assembly that provides equivalent protection.*

*Exception No. 3: The operating handle of a circuit breaker shall be permitted to be accessible without opening a door or cover.*

**240-32. Damp or Wet Locations.** Enclosures for overcurrent devices in damp or wet locations shall be identified for use in such locations and shall be mounted so there is at least ¼-inch (6.35-mm) air space between the enclosure and the wall or other supporting surface.

**240-33. Vertical Position.** Enclosures for overcurrent devices shall be mounted in a vertical position unless in individual instances this is shown to be impracticable.

### E. Plug Fuses, Fuseholders, and Adapters

**240-50. General.**

**(a) Maximum Voltage.** Plug fuses and fuseholders shall not be used in circuits exceeding 125 volts between conductors.

*Exception: In circuits supplied by a system having a grounded neutral and having no conductor at over 150 volts to ground.*

**(e) Screw Shell.** The screw shell of a plug-type fuseholder shall be connected to the load side of the circuit.



## ARTICLE 250 — GROUNDING

### A. General

**250-1. Scope.** This article covers general requirements for grounding and bonding of electrical installations, and specific requirements in (a) through (f) below.

(a) Systems, circuits, and equipment required, permitted, or not permitted to be grounded.

(b) Circuit conductor to be grounded on grounded systems.

(c) Location of grounding connections.

(d) Types and sizes of grounding and bonding conductors and electrodes.

(e) Methods of grounding and bonding.

(f) Conditions under which guards, isolation, or insulation may be substituted for grounding.

Systems and circuit conductors are grounded to limit voltages due to lightning, line surges, or unintentional contact with higher voltage lines, and to stabilize the voltage to ground during normal operation. Systems and circuit conductors are solidly grounded to facilitate overcurrent device operation in case of ground faults.

Conductive materials enclosing electrical conductors or equipment, or forming part of such equipment, are grounded to limit the voltage to ground on these materials and to facilitate overcurrent device operation in case of ground faults. See Section 110-10.

**250-2. Application of Other Articles.** In other articles applying to particular cases of installation of conductors and equipment, there are requirements that are in addition to those of this article or are modifications of them:

	Article	Section
Appliances .....		422-16
Branch Circuits .....		210-5
		210-6
		210-7
Circuits and Equipment Operating at Less Than 50 Volts .....	720	
Class 1, Class 2, and Class 3 Circuits .....		725-20
		725-42
Conductors (Grounded) .....	200	
Fire Protective Signaling Systems .....		760-6
Fixed Electric Space Heating Equipment .....		424-14
Fixtures and Lighting Equipment .....		410-17
		410-18
		410-21
Lighting Fixtures, Lampholders, Lamps, and Receptacles .....	410	

	Article	Section
Outlet, Switch and Junction Boxes, and Fittings ...		370-4
		370-15
Panelboards .....		384-27
Receptacles and Attachment Plugs .....		410-58
Services .....	230	
Service Equipment .....		230-63
Swimming Pools, Fountains and Similar Instal- lations .....	680	
Switches .....		380-1
		380-12

**250-5. Alternating-Current Circuits and Systems to Be Grounded.** AC circuits and systems shall be grounded as provided for in (a) or (b) below. Other circuits and systems shall be permitted to be grounded.

(a) **Alternating-Current Circuits of Less than 50 Volts.** AC circuits of less than 50 volts shall be grounded under any of the following conditions:

(1) Where supplied by transformers if the transformer supply system exceeds 150 volts to ground.

(2) Where supplied by transformers if the transformer supply system is ungrounded.

(3) Where installed as overhead conductors outside of buildings.

(b) **Alternating-Current Systems of 50 Volts to 1000 Volts.** AC systems of 50 volts to 1000 volts supplying premises wiring and premises wiring systems shall be grounded under any of the following conditions:

(1) Where the system can be so grounded that the maximum voltage to ground on the ungrounded conductors does not exceed 150 volts.

(4) Where a service conductor is uninsulated in accordance with Section 230-4.

### C. Location of System Grounding Connections

#### 250-21. Objectionable Current over Grounding Conductors.

(a) **Arrangement to Prevent Objectionable Current.** The grounding of electric systems, circuit conductors, surge arresters, and conductive noncurrent-carrying materials and equipment shall be installed and arranged in a manner that will prevent an objectionable flow of current over the grounding conductors or grounding paths.

(b) **Alterations to Stop Objectionable Current.** If the use of multiple grounding connections results in an objectionable flow of current, one or more of the following alterations shall be made:

(1) Discontinue one or more such grounding connections.

(2) Change the locations of the grounding connections.

(3) Interrupt the continuity of the conductor or conductive path interconnecting the grounding connections.

(4) Take other suitable remedial action satisfactory to the authority having jurisdiction.

**(c) Temporary Currents Not Classified as Objectionable Currents.** Temporary currents resulting from accidental conditions, such as ground-fault currents, that occur only while the grounding conductors are performing their intended protective functions shall not be classified as objectionable current for the purposes specified in (a) and (b) above.

**250-23. Grounding Service-Supplied Alternating-Current Systems.**

**(a) System Grounding Connections.** A premises wiring system that is supplied by an ac service and is required to be grounded by Section 250-5 shall have at each service a grounding electrode conductor connected to a grounding electrode which complies with Part H of Article 250. The grounding electrode conductor shall be connected to the grounded service conductor at any accessible point from the load end of the service drop or service lateral to and including the terminal or bus to which the grounded service conductor is connected at the service disconnecting means. Where the transformer supplying the service is located outside the building, at least one additional grounding connection shall be made from the grounded service conductor to a grounding electrode, either at the transformer or elsewhere outside the building. A grounding connection shall not be made to any grounded circuit conductor on the load side of the service disconnecting means.

See definition of Service Drop and Service Lateral; also Section 230-21.

*Exception No. 2: A grounding conductor connection shall be made at each separate building where required by Section 250-24.*

*Exception No. 3: For ranges, counter-mounted cooking units, wall-mounted ovens, clothes dryers, and meter enclosures as permitted by Section 250-61.*

**(b) Grounded Conductor Brought to Service Equipment.** Where an ac system operating at less than 1000 volts is grounded at any point, the grounded conductor shall be run to each service. This conductor shall be routed with the phase conductors and shall not be smaller than the required grounding electrode conductor specified in Table 250-94 and, in addition, for service phase conductors larger than 1100 MCM copper or 1750 MCM aluminum, the grounded conductor shall not be smaller than 12½ percent of the area of the largest phase conductor.

*Exception: The grounded conductor shall not be required to be larger than the largest ungrounded service conductor.*

**250-24. Two or More Buildings Supplied from Single Service Equipment.**

**(a) Grounded Systems.** Where two or more buildings are supplied by a grounded system from a single service equipment, each building shall have a grounding electrode connected to the ac system grounded circuit conductor on the supply side of the building disconnecting means.

**(b) Ungrounded Systems.** Where two or more buildings are supplied by an ungrounded system from a single service equipment, each building shall have a grounding electrode connected to the metal enclosure of the building disconnecting means.

*Exception for (a) and (b) above: A grounding electrode at a separate building shall not be required where the conditions of either a. or b. below are met:*

*a. Only one branch circuit is supplied and there is no equipment in the building that requires grounding.*

*b. No livestock is housed in the building, an equipment grounding conductor is run with the circuit conductors for grounding any noncurrent-carrying equipment, interior metal piping systems or building metal frames and the equipment grounding conductor is bonded to grounding electrodes described in Sections 250-81 and 250-83 which exist at the building.*

**250-25. Conductor to Be Grounded — Alternating-Current Systems.** For ac premises wiring systems, the conductor to be grounded shall be as specified in (1) through (5) below.

- (1) Single-phase, 2-wire: one conductor.
- (2) Single-phase, 3-wire: the neutral conductor.
- (3) Multiphase systems having one wire common to all phases: the common conductor.
- (4) Multiphase systems requiring one grounded phase: one phase conductor.
- (5) Multiphase systems in which one phase is used as in (2) above: the neutral conductor.

Grounded conductors shall be identified by the means specified in Article 200.

#### **D. Enclosure Grounding**

**250-32. Service Raceways and Enclosures.** Metal enclosures for service conductors and equipment shall be grounded.

**250-33. Other Conductor Enclosures.** Metal enclosures for other than service conductors shall be grounded.

*Exception No. 1: Metal enclosures for conductors added to existing installations of open wire, knob-and-tube wiring, and nonmetallic-sheathed cable, if in runs of less than 25 feet (7.62 m), if free from probable contact with ground, grounded metal, metal lath, or other conductive material, and if guarded against contact by persons shall not be required to be grounded.*

*Exception No. 2: Metal enclosures used to protect cable assemblies from physical damage shall not be required to be grounded.*

#### **E. Equipment Grounding**

**250-42. Equipment Fastened in Place or Connected by Permanent Wiring Methods (Fixed).** Exposed noncurrent-carrying metal parts of fixed equipment likely to become energized shall be grounded under any of the conditions in (a) through (f) below.

- (a) **Vertical and Horizontal Distances.** Where within 8 feet (2.44 m) vertically or 5 feet (1.52 m) horizontally of ground or grounded metal objects and subject to contact by persons.
- (b) **Wet or Damp Locations.** Where located in a wet or damp location and not isolated.
- (c) **Electrical Contact.** Where in electrical contact with metal.
- (e) **Metallic Wiring Methods.** Where supplied by a metal-clad, metal-sheathed, or metal-raceway wiring method, except as permitted by Section 250-33 for short sections of raceway.

**(f) Over 150 Volts to Ground.** Where equipment operates with any terminal at over 150 volts to ground.

*Exception No. 2: Metal frames of electrically heated appliances, exempted by special permission, in which case the frames shall be permanently and effectively insulated from ground.*

**250-43. Fastened in Place or Connected by Permanent Wiring Methods (Fixed) — Specific.** Exposed, noncurrent-carrying metal parts of the kinds of equipment described in (a) through (j) below, regardless of voltage, shall be grounded.

**(i) Class 1, Class 2, and Class 3 Circuits.** Equipment supplied by Class 1, Class 2, and Class 3 remote-control and signaling circuits where required to be grounded by Part B of this article.

**250-44. Nonelectric Equipment.**

Where extensive metal in or on buildings may become energized and is subject to personal contact, adequate bonding and grounding will provide additional safety.

**250-45. Equipment Connected by Cord and Plug.** Under any of the conditions described in (b) and (c) below, exposed noncurrent-carrying metal parts of cord- and plug-connected equipment likely to become energized shall be grounded.

**(b) Over 150 Volts to Ground.** Where operated at over 150 volts to ground.

*Exception No. 1: Motors, where guarded.*

*Exception No. 2: Metal frames of electrically heated appliances, exempted by special permission, in which case the frames shall be permanently and effectively insulated from ground.*

**(c) In Residential Occupancies.** In residential occupancies: (1) refrigerators, freezers, and air conditioners; (2) clothes-washing, clothes-drying, dish-washing machines, sump pumps, electrical aquarium equipment; (3) hand-held motor-operated tools; (4) motor-operated appliances of the following types: hedge clippers, lawn mowers, snow blowers, and wet scrubbers; (5) portable handlamps.

*Exception: Listed tools and listed appliances protected by a system of double insulation, or its equivalent, shall not be required to be grounded. Where such a system is employed, the equipment shall be distinctively marked.*

## F. Methods of Grounding

**250-50. Equipment Grounding Conductor Connections.** Equipment grounding conductor connections at the source of separately derived systems shall be made in accordance with Section 250-26(a) in the NEC. Equipment grounding conductor connections at service equipment shall be made as indicated in (a) or (b) below.

**(a) For Grounded System.** The connection shall be made by bonding the equipment grounding conductor to the grounded service conductor and the grounding electrode conductor.

*Exception: For branch-circuit extensions only in existing installations that do not have an equipment grounding conductor in the branch circuit, the grounding conductor of a grounding-type receptacle outlet shall be permitted to be grounded to a grounded cold water pipe near the equipment.*

**250-51. Effective Grounding Path.** The path to ground from circuits, equipment, and conductor enclosures shall: (1) be permanent and continuous; (2) have capacity to conduct safely any fault current likely to be imposed on it; and (3) have sufficiently low impedance to limit the voltage to ground and to facilitate the operation of the circuit protective devices in the circuit.

**250-53. Grounding Path to Grounding Electrode at Services.**

(a) **Grounding Electrode Conductor.** A grounding electrode conductor shall be used to connect the equipment grounding conductors, the service-equipment enclosures and, where the system is grounded, the grounded service conductor to the grounding electrode.

| See Section 250-23(a).

(b) **Main Bonding Jumper.** For a grounded system, an unspliced main bonding jumper shall be used to connect the equipment grounding conductor and the service-equipment enclosure to the grounded conductor of the system within the service equipment or within the service conductor enclosure. A main bonding jumper shall be a wire, bus, screw, or similar suitable conductor.

**250-54. Common Grounding Electrode.** Where an ac system is connected to a grounding electrode in or at a building as specified in Sections 250-23 and 250-24, the same electrode shall be used to ground conductor enclosures and equipment in or on that building.

Two or more electrodes that are effectively bonded together shall be considered as a single electrode in this sense.

**250-55. Underground Service Cable.** Where served from a continuous underground metal-sheathed cable system, the sheath or armor of underground service cable metallically connected to the underground system, or underground service conduit containing a metal-sheathed cable bonded to the underground system, shall not be required to be grounded at the building and shall be permitted to be insulated from the interior conduit or piping.

**250-56. Short Sections of Raceway.** Isolated sections of metal raceway or cable armor, where required to be grounded, shall be grounded in accordance with Section 250-57.

**250-57. Equipment Fastened in Place or Connected by Permanent Wiring Methods (Fixed) — Grounding.** Noncurrent-carrying metal parts of equipment, raceways, and other enclosures, where required to be grounded, shall be grounded by one of the methods indicated in (a) or (b) below.

| *Exception: Where equipment, raceways, and enclosures are grounded by connection to the grounded circuit conductor as permitted by Sections 250-24, 250-60, and 250-61.*

| (a) **Equipment Grounding Conductor Types.** By any of the equipment grounding conductors permitted by Section 250-91(b).

| (b) **With Circuit Conductors.** By an equipment grounding conductor contained within the same raceway, cable, or cord or otherwise run with the circuit conductors. Bare, covered or insulated equipment grounding conductors shall be permitted. Individually covered or insulated equipment

grounding conductors shall have a continuous outer finish that is either green, or green with one or more yellow stripes.

*Exception No. 1: An insulated conductor larger than No. 6 copper or aluminum shall, at the time of installation, be permitted to be permanently identified as an equipment grounding conductor at each end and at every point where the conductor is accessible. Identification shall be accomplished by one of the following:*

- a. Stripping the insulation from the entire exposed length,*
- b. Coloring the exposed insulation green, or*
- c. Marking the exposed insulation with green colored tape or green colored adhesive labels.*

*Exception No. 2: For direct-current circuits only, the equipment grounding conductor shall be permitted to be run separately from the circuit conductors.*

See Section 400-7 for use of cords for fixed equipment.

**250-58. Equipment Considered Effectively Grounded.** Under the conditions specified in (a) and (b) below, the noncurrent-carrying metal parts of the equipment shall be considered effectively grounded.

**(a) Equipment Secured to Grounded Metal Supports.** Electric equipment secured to and in electrical contact with a metal rack or structure provided for its support and grounded by one of the means indicated in Section 250-57. The structural metal frame of a building shall not be used as the required equipment grounding conductor for ac equipment.

**250-59. Cord- and Plug-Connected Equipment.** Noncurrent-carrying metal parts of cord- and plug-connected equipment, where required to be grounded, shall be grounded by one of the methods indicated in (a), (b), or (c) below.

**(a) By Means of the Metal Enclosure.** By means of the metal enclosure of the conductors supplying such equipment if a grounding-type attachment plug with one fixed grounding contact is used for grounding the metal enclosure, and if the metal enclosure of the conductors is secured to the attachment plug and to equipment by approved connectors.

**(b) By Means of a Grounding Conductor.** By means of an equipment grounding conductor run with the power supply conductors in a cable assembly or flexible cord properly terminated in grounding-type attachment plug with one fixed grounding contact. An uninsulated equipment grounding conductor shall be permitted but, if individually covered, the covering shall have a continuous outer finish that is either green or green with one or more yellow stripes.

*Exception: A self-restoring grounding contact shall be permitted on grounding-type attachment plugs used on the power supply cord of portable hand-held, hand-guided, or hand-supported tools or appliances.*

**(c) Separate Flexible Wire or Strap.** By means of a separate flexible wire or strap, insulated or bare, protected as well as practicable against physical damage, where part of equipment.

**250-60. Frames of Ranges and Clothes Dryers.** Frames of electric ranges, wall-mounted ovens, counter-mounted cooking units, clothes dryers, and outlet or junction boxes which are part of the circuit for these

appliances shall be grounded in the manner specified by Section 250-57 or 250-59; or except for mobile homes or recreation vehicles shall be permitted to be grounded to the grounded circuit conductor if all of the conditions indicated in (a) through (d) below are met.

(a) The supply circuit is 120/240-volt, single-phase, 3-wire; or 208Y/120-volt derived from a 3-phase, 4-wire, wye-connected system.

(b) The grounded conductor is not smaller than No. 10 copper or No. 8 aluminum.

(c) The grounded conductor is insulated; or the grounded conductor is uninsulated and part of a service-entrance cable and the branch circuit originates at the service equipment.

(d) Grounding contacts of receptacles furnished as part of the equipment are bonded to the equipment.

#### **250-61. Use of Grounded Circuit Conductor for Grounding Equipment.**

(a) **Supply-Side Equipment.** A grounded circuit conductor shall be permitted to ground noncurrent-carrying metal parts of equipment, raceways, and other enclosures on the supply side of the service disconnecting means, and on the supply side of the main disconnecting means for separate buildings as provided in Section 250-24.

(b) **Load-Side Equipment.** A grounded circuit conductor shall not be used for grounding noncurrent-carrying metal parts of equipment on the load side of the service disconnecting means or on the load side of a separately derived system disconnecting means or the overcurrent devices for a separately derived system not having a main disconnecting means.

*Exception No. 1: The frames of ranges, wall-mounted ovens, counter-mounted cooking units, and clothes dryers under the conditions specified by Section 250-60.*

*Exception No. 2: As permitted in Section 250-24 for separate buildings.*

### **G. Bonding**

**250-70. General.** Bonding shall be provided where necessary to assure electrical continuity and the capacity to conduct safely any fault current likely to be imposed.

#### **250-71. Service Equipment.**

(a) **Bonding of Service Equipment.** The noncurrent-carrying metal parts of equipment indicated in (1), (2) and (3) below shall be effectively bonded together.

(1) Except as permitted in Section 250-55, the service raceways, cable trays, or service cable armor or sheath.

(2) All service equipment enclosures containing service-entrance conductors, including meter fittings, boxes, or the like, interposed in the service raceway or armor.

(3) Any conduit or armor enclosing a grounding electrode conductor.

(b) **Bonding to Other Systems.** At dwellings, an accessible means external to enclosures for connecting intersystem bonding and grounding conductors shall be provided at the service by at least one of the following means:



- (1) Exposed metallic service conduit.
- (2) Exposed grounding electrode conductor.

(3) Approved means for the external connection of a bonding, or grounding conductor to the service raceway or equipment.

Section 250-71(b) shall become effective August 1, 1981.

See Sections 800-31 and 820-22 in the NEC for bonding and grounding requirements for communication and CATV circuits.

**250-72. Method of Bonding Service Equipment.** Electrical continuity at service equipment shall be assured by one of the methods specified in (a) through (e) below.

(a) **Pressure Connectors, Clamps, etc.** Bonding equipment to the grounded service conductor in a manner provided in Section 250-113.

(b) **Threaded Couplings.** Threaded couplings and threaded bosses on enclosures with joints shall be made up wrenchtight where rigid metal conduit and intermediate metal conduit are involved.

(c) **Threadless Couplings.** Threadless couplings made up tight for rigid metal conduit, intermediate metal conduit and electrical metallic tubing.

(d) **Bonding Jumpers.** Bonding jumpers meeting the other requirements of this article. Bonding jumpers shall be used around concentric or eccentric knockouts that are punched or otherwise formed so as to impair the electrical connection to ground.

(e) **Other Devices.** Other approved devices, such as bonding-type locknuts and bushings.

**250-73. Metal Armor or Tape of Service Cable.** The metal covering of service cable having an uninsulated grounded service conductor in continuous electrical contact with its metallic armor or tape shall be considered to be grounded.

**250-74. Connecting Receptacle Grounding Terminal to Box.** An equipment bonding jumper shall be used to connect the grounding terminal of a grounding-type receptacle to a grounded box.

*Exception No. 1: Where the box is surface mounted, direct metal-to-metal contact between the device yoke and the box shall be permitted to ground the receptacle to the box.*

*Exception No. 2: Contact devices or yokes designed and listed for the purpose shall be permitted in conjunction with the supporting screws to establish the grounding circuit between the device yoke and flush-type boxes.*

*Exception No. 3: Floor boxes designed for and listed as providing satisfactory ground continuity between the box and the device.*

**250-75. Bonding Other Enclosures.** Metal raceways, cable trays, cable armor, cable sheath, enclosures, frames, fittings, and other metal noncurrent-carrying parts that are to serve as grounding conductors shall be effectively bonded where necessary to assure electrical continuity and the capacity to conduct safely any fault current likely to be imposed on them. Any nonconductive paint, enamel, or similar coating shall be removed at threads, contact points, and contact surfaces or be connected by means of fittings so designed as to make such removal unnecessary.

**250-79. Main and Equipment Bonding Jumpers.**

(a) **Material.** Main and equipment bonding jumpers shall be of copper or other corrosion-resistant material.

(b) **Attachment.** Main and equipment bonding jumpers shall be attached in the manner specified by the applicable provisions of Section 250-113 for circuits and equipment and by Section 250-115 for grounding electrodes.

(c) **Size — Equipment Bonding Jumper on Supply Side of Service and Main Bonding Jumper.** The bonding jumper shall not be smaller than the sizes given in Table 250-94 for grounding electrode conductors.

(d) **Size — Equipment Bonding Jumper on Load Side of Service.** The equipment bonding jumper on the load side of the service overcurrent devices shall not be smaller than the sizes listed by Table 250-95 for equipment grounding conductors.

(e) **Installation — Equipment Bonding Jumper.** The equipment bonding jumper shall be permitted to be installed inside or outside of a raceway or enclosure. Where installed on the outside, the length of the equipment bonding jumper shall not exceed 6 feet (1.83 m) and shall be routed with the raceway or enclosure.

**250-80. Bonding of Piping Systems.**

(a) **Metal Water Piping.** The interior metal water piping system shall always be bonded to the service equipment enclosure, the grounded conductor at the service, the grounding electrode conductor where of sufficient size, or to the one or more grounding electrodes used. The bonding jumper shall be sized in accordance with Table 250-94.

(b) **Other Metal Piping.** Interior metal piping which may become energized shall be bonded to the service equipment enclosure, the grounded conductor at the service, the grounding electrode conductor where of sufficient size, or to the one or more grounding electrodes used. The bonding jumper shall be sized in accordance with Table 250-95 using the rating of the circuit which may energize the piping.

The equipment grounding conductor for the circuit which may energize the piping shall be permitted to serve as the bonding means.

Bonding all piping and metal air ducts within the premises will provide additional safety.

**H. Grounding Electrode System**

**250-81. Grounding Electrode System.** If available on the premises at each building or structure served, each item (a) through (d) below shall be bonded together to form the grounding electrode system. The bonding jumper shall be sized in accordance with Section 250-94 and shall be connected in the manner specified in Section 250-115. The unspliced grounding electrode conductor shall be permitted to run to any convenient grounding electrode available in the grounding electrode system. It shall be sized for the largest grounding electrode conductor required among all the available electrodes.

(a) **Metal Underground Water Pipe.** A metal underground water pipe in direct contact with the earth for 10 feet (3.05 m) or more (including any metal well casing effectively bonded to the pipe) and electrically continuous (or made electrically continuous by bonding around insulating joints or

sections or insulating pipe) to the points of connection of the grounding electrode conductor and the bonding conductors. Continuity of the grounding path or the bonding connection to interior piping shall not rely on water meters. A metal underground water pipe shall be supplemented by an additional electrode of a type specified in Section 250-81 or in Section 250-83. The supplemental electrode shall be permitted to be bonded to the grounding electrode conductor, the grounded service-entrance conductor, the grounded service raceway or the interior metal water piping at any convenient point.

**(b) Metal Frame of the Building.** The metal frame of the building, where effectively grounded.

**(c) Concrete-Encased Electrode.** An electrode encased by at least 2 inches (50.8 mm) of concrete, located within and near the bottom of a concrete foundation or footing that is in direct contact with the earth, consisting of at least 20 feet (6.1 m) of one or more steel reinforcing bars or rods of not less than ½ inch (12.7 mm) diameter, or consisting of at least 20 feet (6.1 m) of bare copper conductor not smaller than No. 4 AWG.

**(d) Ground Ring.** A ground ring encircling the building or structure, in direct contact with the earth at a depth below earth surface not less than 2½ feet (762 mm), consisting of at least 20 feet (6.1 m) of bare copper conductor not smaller than No. 2 AWG.

**250-83. Made and Other Electrodes.** Where none of the electrodes specified in Section 250-81 is available, one or more of the electrodes specified in (a) through (d) below shall be used. Where practicable, made electrodes shall be embedded below permanent moisture level. Made electrodes shall be free from nonconductive coatings, such as paint or enamel. Where more than one electrode system is used (including those used for lightning rods), each electrode of one system shall not be less than 6 feet (1.83 m) from any other electrode of another system.

Two or more electrodes that are effectively bonded together are to be treated as a single electrode system in this sense.

**(a) Metal Underground Gas Piping System.** An electrically continuous metal underground gas piping system that is uninterrupted with insulating sections or joints and without an outer nonconductive coating, and then only if acceptable to and expressly permitted by both the serving gas supplier and the authority having jurisdiction.

**(b) Other Local Metal Underground Systems or Structures.** Other local metal underground systems or structures, such as piping systems and underground tanks.

**(c) Rod and Pipe Electrodes.** Rod and pipe electrodes shall not be less than 8 feet (2.44 m) in length and shall consist of the following materials, and shall be installed in the following manner:

**(1)** Electrodes of pipe or conduit shall not be smaller than ¾-inch trade size and, where of iron or steel, shall have the outer surface galvanized or otherwise metal-coated for corrosion protection.

**(2)** Electrodes of rods of steel or iron shall be at least ⅝ inch (15.87 mm) in diameter. Nonferrous rods or their equivalent shall be listed and shall be not less than ½ inch (12.7 mm) in diameter.

(3) The electrode shall be installed such that at least 8 feet (2.44 m) of length is in contact with the soil. It shall be driven to a depth of not less than 8 feet (2.44 m) except that where rock bottom is encountered, the electrode shall be driven at an oblique angle not to exceed 45 degrees from the vertical or shall be buried in a trench that is at least 2½ feet (762 mm) deep. The upper end of the electrode shall be flush with or below ground level unless the aboveground end and the grounding electrode conductor attachment are protected against physical damage as specified in Section 250-117.

(d) **Plate Electrodes.** Each plate electrode shall expose not less than 2 square feet (0.186 sq m) of surface to exterior soil. Electrodes of iron or steel plates shall be at least ¼ inch (6.35 mm) in thickness. Electrodes of nonferrous metal shall be at least 0.06 inch (1.52 mm) in thickness.

**250-84. Resistance of Made Electrodes.** A single electrode consisting of a rod, pipe, or plate which does not have a resistance to ground of 25 ohms or less shall be augmented by one additional electrode of any of the types specified in Section 250-81 or 250-83. Where multiple rod, pipe, or plate electrodes are installed to meet the requirements of this section, they shall be not less than 6 feet (1.83 m) apart.

The paralleling efficiency of rods longer than 8 feet (2.44 m) is improved by spacing greater than 6 feet (1.83 m).

**250-86. Use of Lightning Rods.** Lightning rod conductors and driven pipes, rods, or other made electrodes used for grounding lightning rods shall not be used in lieu of the made grounding electrodes required by Section 250-83 for grounding wiring systems and equipment. This provision shall not prohibit the required bonding together of grounding electrodes of different systems.

See Sections 250-46, 800-31(b)(7), and 820-22(h) in the NEC.

Bonding together of all separate grounding electrode systems will limit potential differences between them and between their associated wiring systems.

## J. Grounding Conductors

**250-91. Material.** The material for grounding conductors shall be as specified in (a) and (b) below.

(a) **Grounding Electrode Conductor.** The grounding electrode conductor shall be of copper, aluminum, or copper-clad aluminum. The material selected shall be resistant to any corrosive condition existing at the installation or shall be suitably protected against corrosion. The conductor shall be solid or stranded, insulated, covered, or bare and shall be installed in one continuous length without a splice or joint.

*Exception No. 1: Splices in busbars shall be permitted.*

*Exception No. 2: Where a service consists of more than a single enclosure as permitted in Section 230-45, it shall be permissible to connect taps to the grounding electrode conductor. Each such tap conductor shall extend to the inside of each such enclosure. The grounding electrode conductor shall be sized in accordance with Section 250-94, but the tap conductors shall be permitted to be sized in accordance with the grounding electrode conductors specified in Section 250-94 for the largest conductor serving the respective enclosures.*

**(b) Types of Equipment Grounding Conductors.** The equipment grounding conductor run with or enclosing the circuit conductors shall be one or more or a combination of the following: (1) a copper or other corrosion-resistant conductor. This conductor shall be solid or stranded; insulated, covered, or bare; and in the form of a wire or a busbar of any shape; (2) rigid metal conduit; (3) intermediate metal conduit; (4) electrical metallic tubing; (5) flexible metal conduit where both the conduit and fittings are approved for grounding; (6) armor of Type AC cable; (7) the sheath of mineral-insulated, metal-sheathed cable; (8) the metallic sheath or the combined metallic sheath and grounding conductors of Type MC cable; (9) cable trays as permitted in Sections 318-2(c) and 318-6; (10) other electrically continuous metal raceways approved for grounding.

*Exception No. 1: Flexible metal conduit and flexible metallic tubing shall be permitted for grounding if all the following conditions are met:*

*a. The length in any ground return path does not exceed 6 feet (1.83 m).*

*b. The circuit conductors contained therein are protected by overcurrent devices rated at 20 amperes or less.*

*c. The conduit or tubing is terminated in fittings approved for grounding.*

*Exception No. 2: Liquidtight flexible metal conduit shall be permitted for grounding in the 1¼-inch and smaller trade sizes if the total length in any ground return path does not exceed 6 feet (1.83 m) and the conduit is terminated in fittings approved for grounding.*

**(c) Supplementary Grounding.** Supplementary grounding electrodes shall be permitted to augment the equipment grounding conductors specified in Section 250-91(b), but the earth shall not be used as the sole equipment grounding conductor.

**250-92. Installation.** Grounding conductors shall be installed as specified in (a) and (b) below.

**(a) Grounding Electrode Conductor.** A grounding electrode conductor or its enclosure shall be securely fastened to the surface on which it is carried. A No. 4, copper or aluminum, or larger conductor shall be protected if exposed to severe physical damage. A No. 6 grounding conductor that is free from exposure to physical damage shall be permitted to be run along the surface of the building construction without metal covering or protection where it is rigidly stapled to the construction; otherwise, it shall be in rigid metal conduit, intermediate metal conduit, rigid nonmetallic conduit, electrical metallic tubing, or cable armor. Grounding conductors smaller than No. 6 shall be in rigid metal conduit, intermediate metal conduit, rigid nonmetallic conduit, electrical metallic tubing, or cable armor.

Metal enclosures for grounding conductors shall be electrically continuous from the point of attachment to cabinets or equipment to the grounding electrode, and shall be securely fastened to the ground clamp or fitting. Metal enclosures that are not physically continuous from cabinet or equipment to the grounding electrode shall be made electrically continuous by bonding each end to the grounding conductor. Where intermediate metal conduit is used for protection for a grounding conductor, the installation shall comply with the requirements of Article 345. Where rigid metal

conduit is used as protection for a grounding conductor, the installation shall comply with the requirements of Article 346. Where rigid nonmetallic conduit is used as protection for a grounding conductor, the installation shall comply with the requirements of Article 347. Where electrical metallic tubing is used, the installation shall comply with the requirements of Article 348.

Aluminum or copper-clad aluminum grounding conductors shall not be used where in direct contact with masonry or the earth or where subject to corrosive conditions. Where used outside, aluminum or copper-clad aluminum grounding conductors shall not be installed within 18 inches (457 mm) of the earth.

**(b) Equipment Grounding Conductor.** An equipment grounding conductor shall be installed as follows:

(1) Where it consists of a raceway, cable armor, or cable sheath or where it is a wire within a raceway or cable, it shall be installed in accordance with the applicable provisions in this Code using fittings for joints and terminations approved for use with the type raceway or cable used. All connections, joints, and fittings shall be made tight using suitable tools.

(2) Where it is a separate grounding conductor as provided in the Exception for Section 250-50(a) and (b), it shall be installed in accordance with (a) above in regard to restrictions for aluminum and also in regard to protection from physical damage.

*Exception: Sizes smaller than No. 6 shall not be required to be enclosed in a raceway or armor where run in the hollow spaces of a wall or partition or where otherwise installed so as not to be subject to physical damage.*

**250-94. Size of Alternating-Current Grounding Electrode Conductor.** The size of the grounding electrode conductor of a grounded or ungrounded ac system shall not be less than given in Table 250-94.

**Table 250-94**  
**Grounding Electrode Conductor for AC Systems**

Size of Largest Service-Entrance Conductor or Equivalent Area for Parallel Conductors		Size of Grounding Electrode Conductor	
Copper	Aluminum or Copper-Clad Aluminum	Copper	*Aluminum or Copper-Clad Aluminum
2 or smaller	0 or smaller	8	6
1 or 0	2/0 or 3/0	6	4
2/0 or 3/0	4/0 or 250 MCM	4	2

Where there are no service-entrance conductors, the grounding electrode conductor size shall be determined by the equivalent size of the largest service-entrance conductor required for the load to be served.

\* See installation restrictions in Section 250-92(a).

See Section 250-23(b).

*Exception No. 1: Grounded Systems.* Where connected to made electrodes as in Section 250-83 (c) or (d), that portion of the grounding electrode conductor which is the sole connection between the grounding electrode and the grounded system conductor shall not be required to be larger than No. 6 copper wire or No. 4 aluminum wire.

*Exception No. 2: Ungrounded Systems.* Where connected to made electrodes as in Section 250-83 (c) or (d), that portion of the grounding electrode conductor which is the sole connection between the grounding electrode and the service equipment shall not be required to be larger than No. 6 copper wire or No. 4 aluminum wire.

**250-95. Size of Equipment Grounding Conductors.** The size of copper, aluminum, or copper-clad aluminum equipment grounding conductors shall not be less than given in Table 250-95.

When conductors are adjusted in size to compensate for voltage drop, equipment grounding conductors, where required, shall be adjusted proportionately in size.

Where a single equipment grounding conductor is run with multiple circuits in the same raceway, it shall be sized for the largest overcurrent device protecting conductors in the raceway.

*Exception No. 1: An equipment grounding conductor not smaller than No. 18 copper and not smaller than the circuit conductors if an integral part of a listed flexible cord assembly shall be permitted for grounding cord-connected equipment where the equipment is protected by overcurrent devices not exceeding 20-ampere rating.*

*Exception No. 2: The equipment grounding conductor shall not be required to be larger than the circuit conductors supplying the equipment.*

*Exception No. 3: Where a raceway or a cable armor or sheath is used as the equipment grounding conductor, as provided in Sections 250-57(a) and 250-91(b).*

**Table 250-95. Minimum Size Equipment Grounding Conductors for Grounding Raceway and Equipment**

Rating or Setting of Automatic Overcurrent Device in Circuit Ahead of Equipment, Conduit, etc., Not Exceeding (Amperes)	Size	
	Copper Wire No.	Aluminum or Copper-Clad Aluminum Wire No.*
15	14	12
20	12	10
30	10	8
40	10	8
60	10	8
100	8	6
200	6	4

\* See installation restrictions in Section 250-92(a).

**250-99. Equipment Grounding Conductor Continuity.**

(a) **Separable Connections.** Separable connections such as those provided in draw-out equipment or attachment plugs and mating connectors and receptacles shall provide for first-make, last-break of the equipment grounding conductor.

*Exception: Interlocked equipment, plugs, receptacles and connectors which preclude energization without grounding continuity.*

(b) **Switches.** No automatic cutout or switch shall be placed in the equipment grounding conductor of a premises wiring system.

*Exception: Where the opening of the cutout or switch disconnects all sources of energy.*

**K. Grounding Conductor Connections**

**250-112. To Grounding Electrode.** The connection of a grounding electrode conductor to a grounding electrode shall be accessible and made in a manner that will assure a permanent and effective ground. Where necessary to assure this for a metal piping system used as a grounding electrode, effective bonding shall be provided around insulated joints and sections and around any equipment that is likely to be disconnected for repairs or replacement.

*Exception: A connection to a concrete-encased, driven, or buried grounding electrode shall not be required to be accessible.*

**250-113. To Conductors and Equipment.** Required grounding conductors and bonding jumpers shall be connected by pressure connectors, clamps, or other approved means. Connection devices or fittings that depend on solder shall not be used.

**250-114. Continuity and Attachment of Branch-Circuit Equipment Grounding Conductors to Boxes.** Where more than one equipment grounding conductor of a branch circuit enters a box, all such conductors shall be in good electrical contact with each other and the arrangement shall be such that the disconnection or removal of a receptacle, fixture, or other device fed from the box will not interfere with or interrupt the grounding continuity.

(a) **Metal Boxes.** A connection shall be made between the one or more equipment grounding conductors and a metal box by means of a grounding screw which shall be used for no other purpose, or an approved grounding device.

(b) **Nonmetallic Boxes.** One or more equipment grounding conductors brought into a nonmetallic outlet box shall be so arranged that a connection can be made to any fitting or device in that box requiring grounding.

**250-115. Connection to Electrodes.** The grounding conductor shall be connected to the grounding fitting by suitable lugs, pressure connectors, clamps, or other approved means. Connections depending on solder shall not be used. Ground clamps shall be suitable for the materials of the grounding electrode and the grounding electrode conductor and where used on pipe, rod or other buried electrodes shall also be suitable for direct soil burial. Not more than one conductor shall be connected to the grounding electrode by a single clamp or fitting unless the clamp or fitting is approved



for multiple conductors. One of the methods indicated in (a), (b), (c), or (d) below shall be used.

(a) **An Approved Bolted Clamp.** An approved bolted clamp of cast bronze or brass or plain or malleable iron.

(b) **Pipe Fitting, Pipe Plug, etc.** A pipe fitting, pipe plug, or other approved device screwed into a pipe or pipe fitting.

(c) **Sheet-Metal-Strap Type Ground Clamp.** A sheet-metal-strap type ground clamp having a rigid metal base that seats on the electrode and having a strap of such material and dimensions that it is not likely to stretch during or after installation.

(d) **An Equally Substantial Approved Means.** An equally substantial approved means.

**250-117. Protection of Attachment.** Ground clamps or other fittings shall be approved for general use without protection or shall be protected from ordinary physical damage as indicated in (a) or (b) below.

(a) **Not Likely to Be Damaged.** Installations where they are not likely to be damaged.

(b) **Protective Covering.** Enclosing in metal, wood, or equivalent protective covering.

**250-118. Clean Surfaces.** Nonconductive coatings (such as paint, lacquer, and enamel) on equipment to be grounded shall be removed from threads and other contact surfaces to assure good electrical continuity.

## ARTICLE 280 — SURGE ARRESTERS

Installations shall conform to the requirements of Article 280 of the 1981 *National Electrical Code* (NFPA 70-1981).

## ARTICLE 300 — WIRING METHODS

### A. General Requirements

#### 300-1. Scope.

(a) **All Wiring Installations.** The provisions of this article shall apply to all wiring installations.

*Exception No. 1: Only those sections referenced in Article 725 in the NEC shall apply to Class 1, Class 2, and Class 3 circuits.*

*Exception No. 2: Only those sections referenced in Article 760 in the NEC shall apply to fire protective signaling circuits.*

*Exception No. 3: Only those sections referenced in Article 800 in the NEC shall apply to communication systems.*

(b) **Integral Parts of Equipment.** The provisions of this article are not intended to apply to the conductors which form an integral part of equipment, such as motors, controllers, motor control centers, or factory-assembled control equipment.

**300-2. Voltage Limitations.** Wiring methods specified in Chapter 3 shall be used for voltages 600 volts, nominal, or less where not specifically limited in some section of Chapter 3. They shall be permitted for voltages over 600 volts, nominal, where specifically permitted elsewhere in this Code.

#### 300-3. Conductors of Different Systems.

(a) **600 Volts, Nominal, or Less.** Conductors of 600 volts, nominal, or less shall be permitted to occupy the same equipment wiring enclosure, cable, or raceway, without regard to whether the individual circuits are alternating current or direct current, where all conductors are insulated for the maximum voltage of any conductor within the enclosure, cable, or raceway.

(b) **Over 600 Volts, Nominal.** Conductors of over 600 volts, nominal, shall not occupy the same equipment wiring enclosure, cable, or raceway with conductors of 600 volts, nominal, or less.

See Section 300-32, Conductors of Different Systems — over 600 volts, nominal.

*Exception No. 1: Secondary wiring to electric-discharge lamps of 1000 volts or less, if insulated for the secondary voltage involved, shall be permitted to occupy the same fixture enclosure as the branch-circuit conductors.*

*Exception No. 2: Primary leads of electric-discharge lamp ballasts, insulated for the primary voltage of the ballast, when contained within the individual wiring enclosure, shall be permitted to occupy the same fixture enclosure as the branch-circuit conductors.*

*Exception No. 3: Excitation, control, relay, and ammeter conductors used in connection with any individual motor or starter shall be permitted to occupy the same enclosure as the motor circuit conductors.*

**300-4. Protection Against Physical Damage.** Where subject to physical damage, conductors shall be adequately protected.

**(a) Cables Through Wood Framing Members.**

**(1) Bored Holes.** In both exposed and concealed locations, where a cable or raceway-type wiring method is installed through bored holes in joists, rafters, or similar structural wood members, holes shall be bored at the approximate center of the face of the member. Holes in studs for cable-type wiring methods shall be bored so that the edge of the hole is not less than  $1\frac{1}{4}$  inches (31.8 mm) from the nearest edge of the stud or shall be protected from nails and screws by either a steel plate or bushing at least  $\frac{1}{16}$  inch (1.59 mm) thick and of appropriate length and width installed to cover the area through which nails or screws might penetrate the installed cable.

**(2) Notches in Wood.** Where there is no objection because of weakening the building structure, in both exposed and concealed locations, cables shall be permitted to be laid in notches in wood studs, joists, rafters, or other wood members where the cable at those points is protected against nails or screws by a steel plate at least  $\frac{1}{16}$  inch (1.59 mm) thick installed before the building finish is applied.

**(b) Cables Through Metal Framing Members.** In both exposed and concealed locations where nonmetallic-sheathed cables pass through either factory or field punched, cut or drilled slots or holes in metal members, the cable shall be protected by bushings or grommets securely fastened in the opening. Where nails or screws are likely to penetrate the cable, a steel sleeve, steel plate or steel clip not less than  $\frac{1}{16}$  inch (1.59 mm) in wall thickness shall be used to protect the nonmetallic cable.

*Exception: When the slots or holes are so formed that no metal edge can cut or tear cable insulation, bushings or grommets shall not be required.*

**300-5. Underground Installations.**

**(a) Minimum Cover Requirements.** Direct buried cable or conduit or other raceways shall be installed to meet the minimum cover requirements of Table 300-5.

*Exception No. 1: The minimum cover requirements shall be permitted to be reduced by 6 inches (152 mm) for installations where a 2-inch (50.8-mm) thick concrete pad or equivalent in physical protection is placed in the trench over the underground installation.*

*Exception No. 2: The minimum cover requirements shall not apply to conduits or other raceways which are located under a building or exterior concrete slab not less than 4 inches (102 mm) in thickness and extending not less than 6 inches (152 mm) beyond the underground installation.*

*Exception No. 4: Residential branch circuits rated 300 volts or less and provided with overcurrent protection of not more than 30 amperes shall be permitted with a cover requirement of 12 inches (305 mm).*

*Exception No. 5: Lesser depths are permitted where cables and conductors rise for terminations or splices or where access is otherwise required.*

*Exception No. 7: Raceways installed in solid rock shall be permitted to be buried at a lesser depth when covered by 2 inches (50.8 mm) or more of concrete over the installation and extending down to the rock surface.*

*Exception No. 8: Circuits for the control of irrigation and landscape lighting systems which are limited to not more than 30 volts and are installed with Type UF or other approved cable shall be permitted with a minimum cover of 6 inches (152 mm).*

**Table 300-5**  
**Minimum Cover Requirements, 0 to 600 Volts, Nominal**

(Cover is defined as the distance between the top surface of direct buried cable, conduit, or other raceways and the finished grade.)

Wiring Method	Minimum Burial (Inches)
Direct Buried Cables	24
Rigid Metal Conduit	6
Intermediate Metal Conduit	6
Rigid Nonmetallic Conduit	
Approved for Direct Burial	
without Concrete Encasement	18
Other Approved Raceways*	18

For SI units: one inch = 25.4 millimeters.

\* Note: Raceways approved for burial only when concrete encased shall require a concrete envelope not less than 2 inches (50.8 mm) thick.

**(b) Grounding.** Metallic shielding, sheath, or metallic conduit shall be effectively grounded at terminations and meet the requirements of Section 250-51.

**(c) Underground Cables Under Buildings.** Underground cable installed under a building shall be in a raceway that is extended beyond the outside walls of the building.

**(d) Protection from Damage.** Conductors emerging from the ground shall be protected by enclosures or raceways extending from below grade to a point 8 feet (2.44 m) above finished grade.

Conductors entering a building shall be protected to the point of entrance.

Where subject to physical damage, the conductors shall be installed in rigid metal conduit, intermediate metal conduit, Schedule 80 rigid nonmetallic conduit, or equivalent.

**(e) Splices and Taps.** Underground cables in trenches shall be permitted to be spliced or tapped without the use of splice boxes. The splices or taps shall be made by methods and with material identified for the purpose.

**(f) Backfill.** Backfill containing large rock, paving materials, cinders, large or sharply angular substance, or corrosive material shall not be placed in an excavation where materials may damage raceways, cables, or other substructures or prevent adequate compaction of fill or contribute to corrosion of raceways, cables or other substructures.

Where necessary to prevent physical damage to the raceway or cable, protection shall be provided in the form of granular or selected material, suitable running boards, suitable sleeves, or other approved means.

(g) **Raceway Seals.** Conduits or raceways through which moisture may contact energized live parts shall be sealed or plugged at either or both ends.

(h) **Bushing.** A bushing shall be used at the end of a conduit which terminates underground where cables leave the conduit as a direct burial wiring method. A seal incorporating the physical protection characteristics of a bushing shall be permitted to be used in lieu of a bushing.

(i) **Single Conductors.** All conductors of the same circuit including the grounding conductor where required shall be installed in the same raceway or shall be installed in close proximity in the same trench.

**300-6. Protection Against Corrosion.** Metal raceways, cable armor, boxes, cable sheathing, cabinets, elbows, couplings, fittings, supports, and support hardware shall be of materials suitable for the environment in which they are to be installed.

(a) **General.** Ferrous raceways, cable armor, boxes, cable sheathing, cabinets, metal elbows, couplings, fittings, supports, and support hardware shall be suitably protected against corrosion inside and outside (except threads at joints) by a coating of approved corrosion-resistant material such as zinc, cadmium, or enamel. Where protected from corrosion solely by enamel, they shall not be used out-of-doors or in wet locations as described in (c) below. When boxes or cabinets have an approved system of organic coatings and are marked "Raintight," "Rainproof" or "Outdoor Type," they shall be permitted out-of-doors.

(b) **In Concrete or in Direct Contact with the Earth.** Ferrous or nonferrous metal raceways, cable armor, boxes, cable sheathing, cabinets, elbows, couplings, fittings, supports, and support hardware shall be permitted to be installed in concrete or in direct contact with the earth, or in areas subject to severe corrosive influences when made of material judged suitable for the condition, or when provided with corrosion protection approved for the condition.

**300-9. Grounding Metal Enclosures.** Metal raceways, boxes, cabinets, cable armor, and fittings shall be grounded as required in Article 250.

**300-10. Electrical Continuity of Metal Raceways and Enclosures.** Metal raceways, cable armor, and other metal enclosures for conductors shall be metallically joined together into a continuous electric conductor, and shall be so connected to all boxes, fittings, and cabinets as to provide effective electrical continuity. Raceways and cable assemblies shall be mechanically secured to boxes, fittings, cabinets, and other enclosures, except as provided for nonmetallic boxes in Section 370-7(c).

**300-11. Secured in Place.** Raceways, cable assemblies, boxes, cabinets, and fittings shall be securely fastened in place, unless otherwise provided for specific purposes elsewhere in this Code.

**300-12. Mechanical Continuity — Raceways and Cables.** Metal or nonmetallic raceways, cable armors, and cable sheaths shall be continuous between cabinets, boxes, fittings, or other enclosures or outlets.

**300-13. Mechanical and Electrical Continuity — Conductors.**

(a) **General.** Conductors shall be continuous between outlets, devices, etc., and there shall be no splice or tap within a raceway itself.

*Exception No. 3: As provided in Section 300-15(a), Exception No. 1 for boxes or fittings.*

*Exception No. 4: As provided in Section 352-7 in the NEC for metal surface raceways.*

**(b) Device Removal.** In multiwire circuits the continuity of a grounded conductor shall not be dependent upon device connections, such as lampholders, receptacles, etc., where the removal of such devices would interrupt the continuity.

**300-14. Length of Free Conductors at Outlets and Switch Points.** At least 6 inches (152 mm) of free conductor shall be left at each outlet and switch point for splices or the connection of fixtures or devices.

*Exception: Conductors that are not spliced or terminated at the outlet or switch point.*

**300-15. Boxes or Fittings — Where Required.**

**(a) Box or Fitting.** A box or fitting shall be installed at each conductor splice connection point, outlet, switch point, junction point, or pull point for the connection of conduit, electrical metallic tubing, surface raceway, or other raceways.

*Exception No. 1: A box or fitting shall not be required for a conductor splice connection in surface raceways, wireways, header-ducts, multi-outlet assemblies, auxiliary gutters, cable trays, and conduit bodies having removable covers which are accessible after installation.*

*Exception No. 2: As permitted in Section 410-31 where a fixture is used as a raceway.*

**(b) Box Only.** A box shall be installed at each conductor splice connection point, outlet, switch point, junction point, or pull point for the connection of Type AC cable, Type MC cable, mineral-insulated, metal-sheathed cable, nonmetallic-sheathed cable, or other cables, at the connection point between any such cable system and a raceway system and at each outlet and switch point for concealed knob-and-tube wiring.

*Exception No. 1: As permitted by Section 336-11 for insulated outlet devices supplied by nonmetallic-sheathed cable.*

*Exception No. 4: Where cables enter or exit from conduit or tubing which is used to provide cable support or protection against physical damage.*

*Exception No. 5: A device having brackets that securely fasten the device to a structural member in walls or ceilings of conventional on-site frame construction for use with nonmetallic-sheathed cable shall be permitted without a separate box.*

See Sections 336-5, Exception No. 2; and 545-10; 550-8(j); and 551-14(e), Exception No. 1 in the NEC.

**300-17. Number and Size of Conductors in Raceway.** The number and size of conductors in any raceway shall not be more than will permit dissipation of the heat and ready installation or withdrawal of the conductors without damage to the conductors or to their insulation.

See the following sections of this Code: conduit, 345-7 and 346-6; electrical metallic tubing, 348-6; rigid nonmetallic conduit, 347-11; flexible metallic tubing,

349-12; flexible metal conduit, 350-3; liquidtight flexible metal conduit, 351-6; liquidtight nonmetallic flexible conduit, 351-25; Class 1, Class 2, and Class 3 circuits, Article 725; and fire protective signaling circuits, Article 760.

### **300-18. Inserting Conductors in Raceways.**

(a) **Installation.** Raceways shall first be installed as a complete raceway system without conductors.

*Exception: Exposed raceways having a removable cover or capping.*

(b) **Pull Wires.** Pull wires, if to be used, shall not be installed until the raceway system is in place.

(c) **Lubricants.** Cleaning agents or materials used as lubricants that have a deleterious effect on conductor coverings shall not be used.

### **300-20. Induced Currents in Metal Enclosures or Metal Raceways.**

(a) **Conductors Grouped Together.** Where conductors carrying alternating current are installed in metal enclosures or metal raceways, they shall be so arranged as to avoid heating the surrounding metal by induction. To accomplish this, all phase conductors and, where used, the neutral and all equipment grounding conductors shall be grouped together.

*Exception No. 1: As permitted in Section 250-50, Exception for equipment grounding connections.*

(b) **Individual Conductors.** When a single conductor of a circuit passes through metal with magnetic properties the inductive effect shall be minimized by: (1) cutting slots in the metal between the individual holes through which the individual conductors pass, or (2) passing all the conductors in the circuit through an insulating wall sufficiently large for all of the conductors of the circuit.

Because aluminum is not a magnetic metal, there will be no heating due to hysteresis; however, induced currents will be present. They will not be of sufficient magnitude to require grouping of conductors or special treatment in passing conductors through aluminum wall sections.

**300-21. Spread of Fire or Products of Combustion.** Electrical installations in hollow spaces, vertical shafts, and ventilation or air-handling ducts shall be so made that the possible spread of fire or products of combustion will not be substantially increased. Openings around electrical penetrations through fire resistance rated walls, partitions, floors, or ceilings shall be firestopped using approved methods.

**300-22. Wiring in Ducts, Plenums, and Other Air-Handling Spaces.** The provisions of this section apply to the installation and uses of electric wiring and equipment in ducts, plenums, and other air-handling spaces.

See Article 424, Part F for Electric Duct Heaters.

(b) **Ducts or Plenums Used for Environmental Air.** Only wiring methods consisting of mineral-insulated, metal-sheathed cable, Type MC cable employing a smooth or corrugated impervious metal sheath without an overall nonmetallic covering, electrical metallic tubing, flexible metallic tubing, intermediate metal conduit, or rigid metal conduit shall be installed in ducts or plenums used for environmental air. Flexible metal conduit and liquidtight flexible metal conduit shall be permitted, in lengths not to exceed 4 feet (1.22 m), to connect physically adjustable equipment and devices permitted to be in these ducts and plenum chambers. The

connectors used with flexible metal conduit shall effectively close any openings in the connection. Equipment and devices shall be permitted within such ducts or plenum chambers only if necessary for their direct action upon, or sensing of, the contained air. Where equipment or devices are installed and illumination is necessary to facilitate maintenance and repair, enclosed gasketed-type fixtures shall be permitted.

The above applies to ducts and plenums specifically fabricated to transport environmental air.

**(c) Other Space Used for Environmental Air.** Only mineral-insulated, metal-sheathed cable, Type MC cable without an overall nonmetallic covering, and Type AC cable, and other factory-assembled multiconductor control or power cable which is specifically listed for the use shall be used for wiring in systems installed in other space used for environmental air. Other type cables and conductors shall be installed in electrical metallic tubing, flexible metallic tubing, intermediate metal conduit, rigid metal conduit, metal surface raceway or wireway with metal covers where accessible, or flexible metal conduit. Electric equipment that is permitted within a building concealed space shall be permitted to be installed in other space used for environmental air if the associated wiring material and fixtures are suitable for the ambient temperature.

The above applies to other spaces such as spaces over hung ceilings which are used for environmental air-handling purposes.

*Exception No. 1: Liquidtight flexible metal conduit in single lengths not exceeding 6 feet (1.83 m).*

*Exception No. 2: Integral fan systems specifically identified for such use.*

*Exception No. 3: This section does not include habitable rooms or areas of buildings, the prime purpose of which is not air handling.*

*Exception No. 5: This section does not include the joist or stud spaces in dwelling units when wiring or equipment passes through such spaces perpendicular to the long dimension of such spaces.*



## ARTICLE 305 — TEMPORARY WIRING

**305-1. Scope.** The provisions of this article apply to temporary electrical power and lighting wiring methods which may be of a class less than would be required for a permanent installation. Except as specifically modified in this article, all other requirements of this Code for permanent wiring shall apply to temporary wiring installations.

(a) **During the Period of Construction.** Temporary electrical power and lighting installations shall be permitted during the period of construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment, or similar activities.

(b) **90 Days.** Temporary electrical power and lighting installations shall be permitted for a period not to exceed 90 days for Christmas decorative lighting, carnivals, and similar purposes.

(d) **Removal.** Temporary wiring shall be removed immediately upon completion of construction or purpose for which the wiring was installed.

### 305-2. General.

(a) **Services.** Services shall be installed in conformance with Article 230.

(b) **Feeders.** Feeders shall be protected as provided in Article 240. They shall originate in an approved distribution center. The conductors shall be permitted within multiconductor cord or cable assemblies or where not subject to physical damage; they shall be permitted to be run as open conductors on insulators not more than 10 feet (3.05 m) apart.

(c) **Branch Circuits.** All branch circuits shall originate in an approved power outlet or panelboard. Conductors shall be permitted within multiconductor cord or cable assemblies or as open conductors. All conductors shall be protected by overcurrent devices at their rated ampacity. Runs of open conductors shall be located where the conductors will not be subject to physical damage, and the conductors shall be fastened at intervals not exceeding 10 feet (3.05 m). No branch-circuit conductors shall be laid on the floor. Each branch circuit that supplies receptacles or fixed equipment shall contain a separate equipment grounding conductor when run as open conductors.

(d) **Receptacles.** All receptacles shall be of the grounding type. Unless installed in a complete metallic raceway all branch circuits shall contain a separate equipment grounding conductor and all receptacles shall be electrically connected to the grounding conductor. Receptacles on construction sites shall not be installed on branch circuits which supply temporary lighting. Receptacles shall not be connected to the same ungrounded conductor of multiwire circuits which supply temporary lighting.

See Section 210-8 for receptacles installed on construction sites.

(e) **Disconnecting Means.** Suitable disconnecting switches or plug connectors shall be installed to permit the disconnection of all ungrounded conductors of each temporary circuit.

| **(f) Lamp Protection.** All lamps for general illumination shall be protected from accidental contact or breakage. Protection shall be provided by elevation of at least 7 feet (2.13 m) from normal working surface or by a suitable fixture or lampholder with a guard.

| Brass shell, paper-lined sockets, or other metal-cased sockets shall not be used unless the shell is grounded.

| **(g) Splices.** On construction sites a box shall not be required for splices or junction connections where the circuit conductors are multiconductor cord or cable assemblies or open conductors. See Sections 110-14(b) and 400-9. A box shall be used wherever a change is made to a raceway system or a cable system which is metal clad or metal sheathed.

| **(h) Protection from Accidental Damage.** Flexible cords and cables shall be protected from accidental damage. Sharp corners and projections shall be avoided. When passing through doorways or other pinch points, protection shall be provided to avoid damage.

| **305-3. Grounding.** All grounding shall conform with Article 250.

## ARTICLE 310 — CONDUCTORS FOR GENERAL WIRING

**310-1. Scope.** This article covers general requirements for conductors and their type designations, insulations, markings, mechanical strengths, ampacity ratings, and uses. These requirements do not apply to conductors that form an integral part of equipment, such as motors, motor controllers, and similar equipment, or to conductors specifically provided for elsewhere in this Code.

For flexible cords and cables, see Article 400. For fixture wires, see Article 402.

### 310-2. Conductors.

**(a) Insulated.** Conductors shall be insulated.

*Exception: Where covered or bare conductors are specifically permitted elsewhere in this Code.*

See Section 250-152 in the NEC for insulation of neutral conductors of a solidly grounded high-voltage system.

**(b) Conductor Material.** Conductors in this article shall be of aluminum, copper-clad aluminum, or copper unless otherwise specified.

**310-3. Stranded Conductors.** Where installed in raceways, conductors of size No. 8 and larger shall be stranded.

**310-5. Minimum Size of Conductors.** Whether solid or stranded, conductors shall not be smaller than No. 14 copper or No. 12 aluminum or copper-clad aluminum.

*Exception No. 2: For fixture wire as permitted by Section 410-24 in the NEC.*

*Exception No. 6: For Class 1, Class 2, and Class 3 circuits as permitted by Sections 725-16, 725-37, and 725-40 in the NEC.*

*Exception No. 7: For fire protective signaling circuits as permitted by Sections 760-16, 760-27, and 760-30 in the NEC.*

### 310-8. Wet Locations.

**(a) Insulated Conductors.** Insulated conductors used in wet locations shall be (2) Types RHW, RUW, TW, THW, THWN, XHHW; or (3) of a type listed for use in wet locations.

**(b) Cables.** Cables of one or more conductors used in wet locations shall be of a type listed for use in wet locations.

Conductors used for direct burial applications shall be of a type listed for such use.

**310-10. Temperature Limitation of Conductors.** No conductor shall be used in such a manner that its operating temperature will exceed that designated for the type of insulated conductor involved. In no case shall conductors be associated together in such a way with respect to type of circuit, the wiring method employed, or the number of conductors that the limiting temperature of any conductor is exceeded.

The temperature rating of a conductor (see Tables 310-13 and 310-31 in the NEC) is the maximum temperature, at any location along its length, that the conductor can withstand over a prolonged time period without serious degradation.

Tables 310-16 through 310-19, the correction factors at the bottom of these tables, and the notes to the tables provide guidance for coordinating conductor sizes, types, allowable load currents, ambient temperatures, and number of associated conductors.

The principal determinants of operating temperature are:

1. Ambient temperature. Ambient temperature may vary along the conductor length as well as from time to time.
2. Heat generated internally in the conductor as the result of load current flow.
3. The rate at which generated heat dissipates into the ambient medium. Thermal insulation which covers or surrounds conductors will affect the rate of heat dissipation.
4. Adjacent load-carrying conductors. Adjacent conductors have the dual effect of raising the ambient temperature and impeding heat dissipation.

### **310-11. Marking.**

**(a) Required Information.** All conductors and cables shall be marked to indicate the following information, using the applicable method described in (b) below.

(1) The maximum rated voltage for which the conductor was listed.

(2) The proper type letter or letters for the type of wire or cable as specified elsewhere in this article, in Tables 310-13 and 310-31 in the NEC, and in Articles 336, 337 (in the NEC), 338, 339 and 340 (in the NEC).

(3) The manufacturer's name, trademark, or other distinctive marking by which the organization responsible for the product can be readily identified.

(4) The AWG size or circular-mil area.

#### **(b) Method of Marking.**

**(1) Surface Marking.** The following conductors and cables shall be durably marked on the surface at intervals not exceeding 24 inches (610 mm):

(a) Single- and multiconductor rubber- and thermoplastic- insulated wire and cable.

(b) Nonmetallic-sheathed cable.

(c) Service-entrance cable.

(d) Underground feeder and branch-circuit cable.

**(2) Marker Tape.** Metal-covered multiconductor cables shall employ a marker tape located within the cable and running for its complete length.

*Exception No. 2: Type AC cable.*

Included in the group of metal-covered cables are: Type AC cable (Article 333).

**(3) Tag Marking.** The following conductors and cables shall be marked by means of a printed tag attached to the coil, reel, or carton:

(c) Metal-covered, single-conductor cables.

(e) Type AC cable.

**310-12. Conductor Identification.**

**(a) Grounded Conductors.** Insulated conductors of No. 6 or smaller, intended for use as grounded conductors of circuits, shall have an outer identification of a white or natural gray color. Multiconductor flat cable No. 4 or larger shall be permitted to employ an external ridge on the grounded conductor.

*Exception No. 4: A conductor identified as required by Section 210-5(a) for branch circuits.*

Wires having their outer covering finished to show a white or natural gray color but having colored tracer threads in the braid, identifying the source of manufacture, shall be considered as meeting the provisions of this section.

For identification requirements for conductors larger than No. 6, see Section 200-6.

**(b) Equipment Grounding Conductors.** Bare, covered or insulated grounding conductors shall be permitted. Individually covered or insulated grounding conductors shall have a continuous outer finish that is either green, or green with one or more yellow stripes.

*Exception No. 1: An insulated conductor larger than No. 6 shall, at the time of installation, be permitted to be permanently identified as a grounding conductor at each end and at every point where the conductor is accessible. Identification shall be accomplished by one of the following means:*

- a. Stripping the insulation from the entire exposed length;*
- b. Coloring the exposed insulation green; or*
- c. Marking the exposed insulation with green colored tape or green colored adhesive labels.*

**(c) Ungrounded Conductors.** Conductors which are intended for use as ungrounded conductors, whether used as single conductors or in multiconductor cables, shall be finished to be clearly distinguishable from grounded and grounding conductors. Ungrounded conductors shall be distinguished by colors other than white, natural gray, or green; or by a combination of color plus distinguishing marking. Distinguishing markings shall also be in a color other than white, natural gray, or green, and shall consist of a stripe or stripes or a regularly spaced series of identical marks. Distinguishing markings shall not conflict in any manner with the surface markings required by Section 310-11(b)(1).

**310-14. Aluminum Conductor Material.** Solid aluminum conductors No. 8, 10, and 12 AWG shall be made of an aluminum alloy conductor material.

**310-15. Ampacity.**

**(a) Applications Covered by Tables.** Ampacities for conductors rated 0-2000 volts shall be as specified in Table 310-16 and its accompanying notes.

**Table 310-16. Allowable Ampacities of Insulated Conductors  
Rated 0-2000 Volts, 60° to 90°C**

Not More Than Three Conductors in Raceway or Cable or Earth  
(Directly Buried), Based on Ambient Temperature of 30°C (86°F)

Size	Temperature Rating of Conductor, See Table 310-13								Size
	60°C (140°F)	75°C (167°F)	85°C (185°F)	90°C (194°F)	60°C (140°F)	75°C (167°F)	85°C (185°F)	90°C (194°F)	
AWG	TYPES †RUW, †T, †TW, †UF	TYPES †FEPW, †RH, †RHW, †RUH, †THW, †THWN, †XHHW, †USE, †ZW	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, †FEP, †FEPB, †RHH, †THHN, †XHHW*	TYPES †RUW, †T, †TW, †UF	TYPES †RH, †RHW, †RUH, †THW, †THWN, †XHHW, †USE	TYPES V, MI	TYPES TA, TBS, SA, AVB, SIS, †RHH, †THHN, †XHHW*	AWG
MCM									MCM
COPPER				ALUMINUM OR COPPER-CLAD ALUMINUM					
18	....	....	....	14	....	....	....	....	....
16	....	....	18	18	....	....	....	....	....
14	20†	20†	25	25†	....	....	....	....	....
12	25†	25†	30	30†	20†	20†	25	25†	12
10	30†	35†	40	40†	25†	30†	30	35†	10
8	40	50	55	55	30	40	40	45	8
6	55	65	70	75	40	50	55	60	6
4	70	85	95	95	55	65	75	75	4
3	85	100	110	110	65	75	85	85	3
2	95	115	125	130	75	90	100	100	2
1	110	130	145	150	85	100	110	115	1
0	125	150	165	170	100	120	130	135	0
00	145	175	190	195	115	135	145	150	00
000	165	200	215	225	130	155	170	175	000
0000	195	230	250	260	150	180	195	205	0000
CORRECTION FACTORS									
Ambient Temp. °C	For ambient temperatures over 30°C, multiply the ampacities shown above by the appropriate correction factor to determine the maximum allowable load current.								Ambient Temp. °F
31-40	.82	.88	.90	.91	.82	.88	.90	.91	86-104
41-45	.71	.82	.85	.87	.71	.82	.85	.87	105-113
46-50	.58	.75	.80	.82	.58	.75	.80	.82	114-122
51-60	....	.58	.67	.71	....	.58	.67	.71	123-141
61-70	....	.35	.52	.58	....	.35	.52	.58	142-158
71-80	....	....	.30	.41	....	....	.30	.41	159-176

† The load current rating and the overcurrent protection for conductor types marked with an obelisk (†) shall not exceed 15 amperes for 14 AWG, 20 amperes for 12 AWG, and 30 amperes for 10 AWG copper; or 15 amperes for 12 AWG and 25 amperes for 10 AWG aluminum and copper-clad aluminum.

\* For dry locations only. See 75°C column for wet locations.

### Notes to Table 310-16

**1. Explanation of Table.** For explanation of Type Letters, and for recognized size of conductors for the various conductor insulations, see Section 310-13 in the NEC. For installation requirements, see Sections 310-1 through 310-10, and the various articles of this Code. For flexible cords, see Tables 400-4 and 400-5 in the NEC.

**3. Three-Wire, Single-Phase Dwelling Services.** In dwelling units, conductors, as listed below, shall be permitted to be utilized as three-wire, single-phase, service-entrance conductors and the three-wire, single-phase feeder that carries the total current supplied by that service.

**Conductor Types and Sizes**  
**RH-RHH-RHW-THW-THWN-THHN-XHHW**

<b>Copper</b>	<b>Aluminum and Copper-Clad AL</b>	<b>Service Rating in Amps</b>
AWG	AWG	
4	2	100
3	1	110
2	1/0	125
1	2/0	150
1/0	3/0	175
2/0	4/0	200

**8. More than Three Conductors in a Raceway or Cable.** Where the number of conductors in a raceway or cable exceeds three, the ampacity shall be as given in Tables 310-16 and 310-18, but the maximum allowable load current of each conductor shall be reduced as shown in the following table:

<b>Number of Conductors</b>	<b>Percent of Values in Tables 310-16 and 310-18</b>
4 thru 6	80
7 thru 24	70
25 thru 42	60
43 and above	50

Where single conductors or multiconductor cables are stacked or bundled without maintaining spacing and are not installed in raceways, the maximum allowable load current of each conductor shall be reduced as shown in the above table.

*Exception No. 1: When conductors of different systems, as provided in Section 300-3, are installed in a common raceway the derating factors shown above shall apply to the number of power and lighting (Articles 210, 215, 220, and 230) conductors only.*

*Exception No. 2: The derating factors of Sections 210-22(c), 220-2(a) and 220-10(b) in the NEC shall not apply when the above derating factors are also required.*

**11. Grounding Conductor.** A grounding conductor shall not be counted when applying the provisions of Note 8.

## ARTICLE 333 — ARMORED CABLE

### Type AC Cable

**333-1. Definition.** Type AC cable is a fabricated assembly of insulated conductors in a flexible metallic enclosure. See Section 333-4.

**333-2. Other Articles.** Type AC cable shall comply with this article and also with the applicable provisions of other articles in this Code, especially Article 300.

**333-3. Marking.** The provisions of Section 310-11 shall apply, except that Type AC cable shall have ready identification of the maker by distinctive external markers on the cable sheath throughout its entire length.

**333-4. Construction.** Type AC cable shall be an approved cable with acceptable metal covering. The insulated conductors shall conform with Section 333-5.

Type AC cables are branch-circuit and feeder cables with armor of flexible metal tape. Cables of the AC type, except ACL, shall have an internal bonding strip of copper or aluminum, in intimate contact with the armor for its entire length.

**333-5. Conductors.** Insulated conductors shall be of a type listed in Table 310-13 in the NEC. In addition, the conductors shall have an overall moisture-resistant and fire-retardant fibrous covering. For Type ACT, a moisture-resistant fibrous covering shall be required only on the individual conductors.

**333-6. Use.** Except where otherwise specified elsewhere in this Code, and where not subject to physical damage, Type AC cable shall be permitted for branch circuits and feeders in both exposed and concealed work.

Type AC cable shall be permitted in dry locations; for underplaster extensions as provided in Article 344 in the NEC; and embedded in plaster finish on brick or other masonry, except in damp or wet locations. It shall be permissible to run or fish this cable in the air voids of masonry block or tile walls; where such walls are exposed or subject to excessive moisture or dampness or are below grade line, Type ACL cable shall be used. This cable shall contain lead-covered conductors (Type ACL) if used where exposed to the weather or to continuous moisture; for underground runs in raceways and embedded in masonry, concrete, or fill in buildings in course of construction; or where exposed to oil, or other conditions having a deteriorating effect on the insulation.

Type ACL cable shall not be used for direct burial in the earth.

**333-7. Supports.** Type AC cable shall be secured by approved staples, straps, hangers, or similar fittings so designed and installed as not to injure the cable at intervals not exceeding 4½ feet (1.37 m) and within 12 inches (305 mm) from every outlet box or fitting.

*Exception No. 1: Where cable is fished.*

*Exception No. 2: Lengths of not more than 2 feet (610 mm) at terminals where flexibility is necessary.*



**333-8. Bends.** All bends shall be made so that the cable will not be injured, and the radius of the curve of the inner edge of any bend shall not be less than five times the diameter of the Type AC cable.

**333-9. Boxes and Fittings.** At all points where the armor of AC cable terminates, a fitting shall be provided to protect wires from abrasion, unless the design of the outlet boxes or fittings is such as to afford equivalent protection, and, in addition, an approved insulating bushing or its equivalent approved protection shall be provided between the conductors and the armor. The connector or clamp by which the Type AC cable is fastened to boxes or cabinets shall be of such design that the insulating bushing or its equivalent will be visible for inspection. This bushing shall not be required with lead-covered cables where so installed that the lead sheath will be visible for inspection. Where change is made from Type AC cable to other cable or raceway wiring methods, a box shall be installed at junction points as required in Section 300-15.

**333-10. Through Studs, Joists, and Rafters.** Type AC cable shall comply with Section 300-4 where installed through studs, joists, rafters, or similar wood members.

**333-11. Exposed Work.** Exposed runs of cable shall closely follow the surface of the building finish or of running boards.

*Exception No. 1: Lengths of not more than 24 inches (610 mm) at terminals where flexibility is necessary.*

*Exception No. 2: On the underside of floor joists in basements where supported at each joist and so located as not to be subject to physical damage.*

**333-12. In Accessible Attics.** Type AC cables in accessible attics or roof spaces shall be installed as specified in (a) and (b) below.

**(a) Where Run Across the Top of Floor Joists.** Where run across the top of floor joists, or within 7 feet (2.13 m) of floor or floor joists across the face of rafters or studding, in attics and roof spaces which are accessible, the cable shall be protected by substantial guard strips which are at least as high as the cable. Where this space is not accessible by permanent stairs or ladders, protection shall only be required within 6 feet (1.83 m) of the nearest edge of the scuttle hole or attic entrance.

**(b) Where Carried Along the Sides of Floor Joists.** Where cable is carried along the sides of rafters, studs, or floor joists, neither guard strips nor running boards shall be required.

## ARTICLE 336 — NONMETALLIC-SHEATHED CABLE

### Types NM and NMC

**336-1. Definition.** Nonmetallic-sheathed cable is a factory assembly of two or more insulated conductors having an outer sheath of moisture-resistant, flame-retardant, nonmetallic material.

**336-2. Construction.** Nonmetallic-sheathed cable shall be an approved Type NM or NMC in sizes No. 14 through 2 with copper conductors and in sizes No. 12 through 2 with aluminum or copper-clad aluminum conductors. In addition to the insulated conductors, the cable may have an approved size of insulated or bare conductor for equipment grounding purposes only.

Conductors of Types NM and NMC shall be one of the types listed in Table 310-13 in the NEC which is suitable for branch-circuit wiring or one which is identified for use in these cables. The ampacity of Types NM and NMC cable shall be that of 60°C (140°F) conductors in Table 310-16.

(a) **Type NM.** The overall covering shall have a flame-retardant and moisture-resistant finish.

(b) **Type NMC.** The overall covering shall be flame-retardant, moisture-resistant, fungus-resistant, and corrosion-resistant.

(c) **Marking.** In addition to the provisions of Section 310-11, the cable shall have a distinctive marking on the exterior for its entire length specifying the cable type.

**336-3. Uses Permitted or Not Permitted.** Type NM and Type NMC cables shall be permitted to be used in one- and two-family dwellings, or multifamily dwellings and other structures not exceeding three floors above grade. For the purpose of this article, the first floor of a building shall be that floor which is designed for human habitation and which has 50 percent or more of its perimeter level with or above finished grade of the exterior wall line.

(a) **Type NM.** This type of nonmetallic-sheathed cable shall be permitted to be installed for both exposed and concealed work in normally dry locations. It shall be permissible to install or fish Type NM cable in air voids in masonry block or tile walls where such walls are not exposed or subject to excessive moisture or dampness.

Type NM cable shall not be installed where exposed to corrosive fumes or vapors; nor shall it be imbedded in masonry, concrete, adobe, fill, or plaster; nor run in a shallow chase in masonry, concrete, or adobe and covered with plaster, adobe, or similar finish.

(b) **Type NMC.** Type NMC cable shall be permitted for both exposed and concealed work in dry, moist, damp, or corrosive locations, and in outside and inside walls of masonry block or tile.

(c) **Uses Not Permitted for Either Type NM or NMC.** Types NM and NMC cables shall not be used: (1) as service-entrance cable; (8) embedded in poured cement, concrete, or aggregate.

**336-4. Other Articles.** In addition to the provisions of this article, installations of nonmetallic-sheathed cable shall comply with the other applicable provisions of this Code, especially Article 300 and Note 8 to Tables 310-16 through 310-19.

**336-5. Supports.** Nonmetallic-sheathed cable shall be secured by staples, straps, or similar fittings so designed and installed as not to injure the cable. Cable shall be secured in place at intervals not exceeding 4½ feet (1.37 m) and within 12 inches (305 mm) from every cabinet, box, or fitting.

*Exception No. 1: For concealed work in finished buildings, or finished panels for prefabricated buildings where such supporting is impracticable, it shall be permissible to fish the cable between access points.*

*Exception No. 2: A wiring device identified for the use, without a separate outlet box, incorporating an integral cable clamp shall be permitted when the cable is secured in place at intervals not exceeding 4½ feet (1.37 m) and within 12 inches (305 mm) from the wiring device wall opening, and there shall be at least a 12-inch (305-mm) loop of unbroken cable or 6 inches (152 mm) of a cable end available on the interior side of the finished wall to permit replacement.*

**336-6. Exposed Work — General.** In exposed work, except as provided in Sections 336-8 and 336-9, the cable shall be installed as specified in (a) and (b) below.

**(a) To Follow Surface.** The cable shall closely follow the surface of the building finish or of running boards.

**(b) Protection from Physical Damage.** The cable shall be protected from physical damage where necessary by conduit, pipe, guard strips, or other means. Where passing through a floor the cable shall be enclosed in rigid metal conduit, intermediate metal conduit, or metal pipe extending at least 6 inches (152 mm) above the floor.

**336-7. Through Studs, Joists, and Rafters.** The cable shall comply with Section 300-4 where installed through studs, joists, rafters, and similar members.

**336-8. In Unfinished Basements.** Where the cable is run at angles with joists in unfinished basements, it shall be permissible to secure cables not smaller than two No. 6 or three No. 8 conductors directly to the lower edges of the joists. Smaller cables shall either be run through bored holes in joists or on running boards. Where run parallel to the joists, cable of any size shall be secured to the sides or faces of the joists.

**336-9. In Accessible Attics.** The installation of cable in accessible attics or roof spaces shall also comply with Section 333-12.

**336-10. Bends.** Bends in cable shall be so made, and other handling shall be such, that the protective coverings of the cable will not be injured, and no bend shall have a radius less than five times the diameter of the cable.

**336-11. Devices of Insulating Material.** Switch, outlet, and tap devices of insulating material shall be permitted to be used without boxes in exposed cable wiring, and for rewiring in existing buildings where the cable is concealed and fished. Openings in such devices shall form a close fit around the outer covering of the cable, and the device shall fully enclose that part of the cable from which any part of the covering has been removed.

Where connections to conductors are by binding-screw terminals, there shall be available as many terminals as conductors.

*Exception: Where cables are clamped within the structure, and terminals are of a type approved for multiconductors.*

**336-12. Boxes of Insulating Material.** Nonmetallic outlet boxes shall be permitted as provided in Section 370-3 in the NEC.

**336-13. Devices with Integral Enclosures.** Wiring devices with integral enclosures identified for such use shall be permitted as provided in Section 300-15(b), Exception No. 5.

## ARTICLE 338 — SERVICE-ENTRANCE CABLE

### Types SE and USE

**338-1. Definition.** Service-entrance cable is a single conductor or multi-conductor assembly provided with or without an overall covering, primarily used for services and of the following types:

(a) **Type SE.** Type SE, having a flame-retardant, moisture-resistant covering, but not required to have inherent protection against mechanical abuse.

(b) **Type USE.** Type USE, identified for underground use, having a moisture-resistant covering, but not required to have a flame-retardant covering or inherent protection against mechanical abuse.

Cabled single-conductor Type USE constructions recognized for underground use may have a bare copper conductor cabled with the assembly. Type USE single, parallel, or cabled conductor assemblies recognized for underground use may have a bare copper concentric conductor applied. These constructions do not require an outer overall covering.

See Section 230-40, Exception b.

(c) **One Uninsulated Conductor.** If Type SE or USE cable consists of two or more conductors, one shall be permitted to be uninsulated.

**338-2. Uses Permitted as Service-Entrance Conductors.** Service-entrance cable used as service-entrance conductors shall be installed as required by Article 230.

**338-3. Uses Permitted as Branch Circuits or Feeders.**

(a) **Grounded Conductor Insulated.** Type SE service-entrance cables shall be permitted in interior wiring systems where all of the circuit conductors of the cable are of the rubber-covered or thermoplastic type.

(b) **Grounded Conductor Not Insulated.** Type SE service-entrance cables without individual insulation on the grounded circuit conductor shall not be used as a branch circuit or as a feeder within a building, except a cable that has a final nonmetallic outer covering and is supplied by alternating current at not over 150 volts to ground shall be permitted: (1) as a branch circuit to supply only a range, wall-mounted oven, counter-mounted cooking unit, or clothes dryer as covered in Section 250-60, or (2) as a feeder to supply only other buildings on the same premises.

Service-entrance cable shall be permitted for interior use where the fully insulated conductors are used for circuit wiring and the uninsulated conductor is used for equipment grounding purposes.

(c) **Temperature Limitations.** Type SE service-entrance cable used to supply appliances shall not be subject to conductor temperatures in excess of the temperature specified for the type of insulation involved.

**338-4. Installation Methods.**

(a) **Interior Wiring.** In addition to the provisions of this article, Type SE service-entrance cable used for interior wiring shall comply with the applicable provisions of Article 300.

(b) **Unarmored Cable.** Unarmored cable shall be installed in accordance with the provisions of Article 336.

(c) **Through Studs, Joists, Rafters, or Similar Members.** Cables shall comply with Section 300-4 where installed through studs, joists, rafters, or similar members.

**338-5. Marking.** Service-entrance cable shall be marked as required in Section 310-11. Cable with the neutral conductor smaller than the ungrounded conductors shall be so marked.

## ARTICLE 339 — UNDERGROUND FEEDER AND BRANCH-CIRCUIT CABLE

### Type UF

#### 339-1. Description and Marking.

**(a) Description.** Underground feeder and branch-circuit cable shall be an approved Type UF cable in sizes No. 14 copper or No. 12 aluminum or copper-clad aluminum through No. 4/0. The conductors of Type UF shall be one of the moisture-resistant types listed in Table 310-13 in the NEC which is suitable for branch-circuit wiring or one which is identified for such use. The ampacity of Type UF cable shall be that of 60°C (140°F) conductors in Table 310-16. In addition to the insulated conductors, the cable shall be permitted to have an approved size of insulated or bare conductor for equipment grounding purposes only. The overall covering shall be flame-retardant, moisture-, fungus-, and corrosion-resistant, and suitable for direct burial in the earth.

**(b) Marking.** In addition to the provisions of Section 310-11, the cable shall have a distinctive marking on the exterior for its entire length specifying the cable type.

**339-2. Other Articles.** In addition to the provisions of this article, installations of underground feeder and branch-circuit cable (Type UF) shall comply with other applicable provisions of this Code, especially Article 300 and Section 310-13 in the NEC.

#### 339-3. Use.

##### **(a) Uses Permitted.**

(1) Type UF cable shall be permitted for use underground, including direct burial in the earth, as feeder or branch-circuit cable where provided with overcurrent protection of the rated ampacity as required in Section 339-4.

(2) Where single-conductor cables are installed, all cables of the feeder circuit, subfeeder circuit, or branch circuit, including the neutral conductor, if any, shall be run together in the same trench or raceway.

(3) For underground requirements, see Section 300-5.

(4) Type UF cable shall be permitted for interior wiring in wet, dry, or corrosive locations under the recognized wiring methods of this Code, and where installed as nonmetallic-sheathed cable, the installation shall comply with the provisions of Article 336 and shall be of the multiconductor type.

*Exception: Single-conductor cables shall be permitted as the nonheating leads for heating cables as provided in Section 424-43.*

Type UF cable supported by cable trays shall be of the multiconductor type.

**(b) Uses Not Permitted.** Type UF cable shall not be used: (1) as service-entrance cables; (8) embedded in poured cement, concrete, or aggregate, except where embedded in plaster as nonheating leads as

provided in Article 424; (9) where exposed to direct rays of the sun, unless identified as sunlight-resistant.

**339-4. Overcurrent Protection.** Overcurrent protection shall be provided in accordance with provisions of Section 240-3.

**339-5. Rated Ampacity.** The ampacities of conductors in Type UF cable shall be according to Table 310-16.



## ARTICLE 345 — INTERMEDIATE METAL CONDUIT

### A. General

**345-1. Definition.** Intermediate metal conduit is a metal raceway of circular cross section with integral or associated couplings, connectors and fittings approved for the installation of electrical conductors.

**345-2. Other Articles.** Installations for intermediate metal conduit shall comply with the provisions of the applicable sections of Article 300.

#### 345-3. Uses Permitted.

(a) **All Atmospheric Conditions and Occupancies.** Use of intermediate metal conduit shall be permitted under all atmospheric conditions and occupancies. Where practicable, dissimilar metals in contact anywhere in the system shall be avoided to eliminate the possibility of galvanic action. Intermediate metal conduit shall be permitted as an equipment grounding conductor.

See Section 250-91.

*Exception: Aluminum fittings and enclosures shall be permitted to be used with steel intermediate metal conduit.*

(b) **Corrosion Protection.** Intermediate metal conduit, elbows, couplings, and fittings shall be permitted to be installed in concrete, in direct contact with the earth, or in areas subject to severe corrosive influences when protected by corrosion protection and judged suitable for the condition.

See Section 300-6.

(c) **Cinder Fill.** Intermediate metal conduit shall be permitted to be installed in or under cinder fill where subject to permanent moisture when protected on all sides by a layer of noncinder concrete not less than 2 inches (50.8 mm) thick; when the conduit is not less than 18 inches (457 mm) under the fill; or when protected by corrosion protection and judged suitable for the condition.

See Section 300-6.

### B. Installation

**345-5. Wet Locations.** All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or protected against corrosion by corrosion-resistant materials.

See Section 300-6 for protection against corrosion.

#### 345-6. Size.

(a) **Minimum.** Conduit smaller than ½-inch electrical trade size shall not be used.

(b) **Maximum.** Conduit larger than 4-inch electrical trade size shall not be used.

**345-7. Number of Conductors in Conduit.** The number of conductors in a single conduit shall not exceed that permitted by the percentage fill specified in Table 1, Tables and Examples, using the conduit dimensions of Table 4, Tables and Examples.

**345-8. Reaming and Threading.** All cut ends of conduits shall be reamed or otherwise finished to remove rough edges. Where conduit is threaded in the field, an electrical conduit thread cutting die with a taper shall be used.

**345-9. Couplings and Connectors.**

**(a) Threadless.** Threadless couplings and connectors used with conduit shall be made tight. Where buried in masonry or concrete, they shall be the concretetight type. Where installed in wet locations, they shall be the raintight type.

**(b) Running Threads.** Running threads shall not be used on conduit for connection at couplings.

**345-10. Bends — How Made.** Bends of intermediate metal conduit shall be so made that the conduit will not be injured, and that the internal diameter of the conduit will not be effectively reduced. The radius of the curve of the inner edge of any field bend shall not be less than indicated in Table 346-10.

*Exception: For field bends for conductors without lead sheath and made with a single operation (one shot) bending machine designed for the purpose, the minimum radius shall not be less than that indicated in Table 346-10 Exception.*

**345-11. Bends — Number in One Run.** A run of conduit between outlet and outlet, between fitting and fitting, or between outlet and fitting, shall not contain more than the equivalent of four quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**345-12. Supports.** Intermediate metal conduit shall be installed as a complete system as provided in Article 300 and shall be securely fastened in place. Conduit shall be firmly fastened within 3 feet (914 mm) of each outlet box, junction box, cabinet, or fitting. Conduit shall be supported at least every 10 feet (3.05 m).

**345-13. Boxes and Fittings.** See Article 370.

**345-14. Splices and Taps.** Splices and taps shall be made only in junction, outlet boxes or conduit bodies. Conductors, including splices and taps, shall not fill a conduit body to more than 75 percent of its cross-sectional area at any point. All splices and taps shall be made by approved methods.

**345-15. Bushings.** Where a conduit enters a box or fitting, a bushing shall be provided to protect the wire from abrasion unless the design of the box or fitting is such as to afford equivalent protection. See Section 373-6(c) for the protection of conductors at bushings.

## ARTICLE 346 — RIGID METAL CONDUIT

**346-1. Use.** The use of rigid metal conduit shall be permitted under all atmospheric conditions and occupancies subject to the following:

(a) **Protected by Enamel.** Ferrous raceways and fittings protected from corrosion solely by enamel shall be permitted only indoors and in occupancies not subject to severe corrosive influences.

(b) **Dissimilar Metals.** Where practicable, dissimilar metals in contact anywhere in the system shall be avoided to eliminate the possibility of galvanic action.

(c) **Corrosion Protection.** Ferrous or nonferrous metal conduit, elbows, couplings, and fittings shall be permitted to be installed in concrete, in direct contact with the earth, or in areas subject to severe corrosive influences where protected by corrosion protection and judged suitable for the condition.

See Section 300-6.

**346-2. Other Articles.** Installations of rigid metal conduit shall comply with the applicable provisions of Article 300.

### A. Installation

**346-3. Cinder Fill.** Conduit shall not be used in or under cinder fill where subject to permanent moisture.

*Exception No. 1: Where of corrosion-resistant material suitable for the purpose.*

*Exception No. 2: Where protected on all sides by a layer of noncinder concrete at least 2 inches (50.8 mm) thick.*

*Exception No. 3: Where the conduit is at least 18 inches (457 mm) under the fill.*

**346-4. Wet Locations.** All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or protected against corrosion by corrosion-resistant materials.

See Section 300-6 for protection against corrosion.

**346-5. Minimum Size.** Conduit smaller than ½ inch electrical trade size shall not be used.

*Exception No. 1: For underplaster extensions as permitted in Section 344-2.*

*Exception No. 2: For enclosing the leads of motors as permitted in Section 430-145(b) in the NEC.*

**346-6. Number of Conductors in Conduit.** The number of conductors permitted in a single conduit shall not exceed the percentage fill specified in Table 1, Tables and Examples.

**346-7. Reaming and Threading.**

(a) **Reamed.** All cut ends of conduits shall be reamed or otherwise finished to remove rough edges.

(b) **Threaded.** Where conduit is threaded in the field, a standard conduit cutting die with a  $\frac{3}{4}$ -inch (19-mm) taper per foot (305 mm) shall be used.

**346-8. Bushings.** Where a conduit enters a box or other fitting, a bushing shall be provided to protect the wire from abrasion unless the design of the box or fitting is such as to afford equivalent protection.

See Section 373-6(c) for the protection of conductors at bushings.

**346-9. Couplings and Connectors.**

(a) **Threadless.** Threadless couplings and connectors used with conduit shall be made tight. Where buried in masonry or concrete, they shall be of the concretetight type. Where installed in wet locations, they shall be of the raintight type.

(b) **Running Threads.** Running threads shall not be used on conduit for connection at couplings.

**346-10. Bends — How Made.** Bends of rigid metal conduit shall be so made that the conduit will not be injured, and that the internal diameter of the conduit will not be effectively reduced. The radius of the curve of the inner edge of any field bend shall not be less than shown in Table 346-10.

*Exception: For field bends for conductors without lead sheath and made with a single operation (one shot) bending machine designed for the purpose, the minimum radius shall not be less than indicated in Table 346-10 Exception.*

**346-11. Bends — Number in One Run.** A run of conduit between outlet and outlet, fitting and fitting, or outlet and fitting shall not contain more than the equivalent of four quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**Table 346-10**  
**Radius of Conduit Bends (Inches)**

Size of Conduit (In.)	Conductors Without Lead Sheath (In.)	Conductors With Lead Sheath (In.)
$\frac{1}{2}$	4	6
$\frac{3}{4}$	5	8
1	6	11
$1\frac{1}{4}$	8	14
$1\frac{1}{2}$	10	16
2	12	21
$2\frac{1}{2}$	15	25
3	18	31
$3\frac{1}{2}$	21	36
4	24	40
$4\frac{1}{2}$	27	45
5	30	50
6	36	61

For SI units: (Radius) one inch = 25.4 millimeters.

**Table 346-10. Exception  
Radius of Conduit Bends (Inches)**

Size of Conduit (In.)	Radius to Center of Conduit (In.)
1/2	4
3/4	4 1/2
1	5 3/4
1 1/4	7 1/4
1 1/2	8 1/4
2	9 1/2
2 1/2	10 1/2
3	13
3 1/2	15
4	16
4 1/2	20
5	24
6	30

For SI units: (Radius) one inch = 25.4 millimeters.

**346-12. Supports.** Rigid metal conduit shall be installed as a complete system as provided in Article 300 and shall be securely fastened in place. Conduit shall be firmly fastened within 3 feet (914 mm) of each outlet box, junction box, cabinet, or fitting. Conduit shall be supported at least every 10 feet (3.05 m).

*Exception No. 1: If made up with threaded couplings, it shall be permissible to support straight runs of rigid metal conduit in accordance with Table 346-12, provided such supports prevent transmission of stresses to termination where conduit is deflected between supports.*

**Table 346-12. Supports for Rigid Metal Conduit**

Conduit Size (Inches)	Maximum Distance Between Rigid Metal Conduit Supports (Feet)
1/2-3/4	10
1	12
1 1/4-1 1/2	14
2-2 1/2	16
3 and larger	20

For SI units: (Supports) one foot = 0.3048 meter.

**346-13. Boxes and Fittings.** Boxes and fittings shall comply with the applicable provisions of Article 370.

**346-14. Splices and Taps.** Splices and taps shall be made only in junction, outlet boxes or conduit bodies. Conductors, including splices and taps, shall not fill a conduit body to more than 75 percent of its cross-sectional area at any point. All splices and taps shall be made by approved methods.

## ARTICLE 347 — RIGID NONMETALLIC CONDUIT

**347-1. Description.** This article shall apply to a type of conduit and fittings of suitable nonmetallic material that is resistant to moisture and chemical atmospheres. For use aboveground, it shall also be flame-retardant, resistant to impact and crushing, resistant to distortion from heat under conditions likely to be encountered in service, and resistant to low temperature and sunlight effects. For use underground, the material shall be acceptably resistant to moisture and corrosive agents and shall be of sufficient strength to withstand abuse, such as by impact and crushing, in handling and during installation. Where intended for direct burial, without encasement in concrete, the material shall also be capable of withstanding continued loading that is likely to be encountered after installation.

Materials that have been recognized as having suitable physical characteristics when properly formed and treated include fiber, asbestos cement, soapstone, rigid polyvinyl chloride, fiberglass epoxy, and high-density polyethylene for underground use, and rigid polyvinyl chloride for use aboveground.

**347-2. Uses Permitted.** The use of rigid nonmetallic conduit and fittings shall be permitted under the following conditions:

- | (a) **Concealed.** In walls, floors, and ceilings.
- | (b) **Corrosive Influences.** In locations subject to severe corrosive influences as covered in Section 300-6 and where subject to chemicals for which the materials are specifically approved.
- | (c) **Cinders.** In cinder fill.
- | (d) **Wet Locations.** In portions of dairies, laundries, canneries, or other wet locations and in locations where walls are frequently washed, the entire conduit system including boxes and fittings used therewith shall be so installed and equipped as to prevent water from entering the conduit. All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or be protected against corrosion by approved corrosion-resistant materials.
- | (e) **Dry and Damp Locations.** In dry and damp locations not prohibited by Section 347-3.
- | (f) **Exposed.** For exposed work where not subject to physical damage if identified for such use.
- | (g) **Underground Installations.** For underground installations, see Sections 300-5 and 710-3(b) in the NEC.

| **347-3. Uses Not Permitted.** Rigid nonmetallic conduit shall not be used:

- | (b) **Support of Fixtures.** For the support of fixtures or other equipment.
- | (c) **Physical Damage.** Where subject to physical damage unless identified for such use.
- | (d) **Ambient Temperatures.** Where subject to ambient temperatures exceeding those for which the conduit is approved.
- | (e) **Insulation Temperature Limitations.** For conductors whose insulation temperature limitations would exceed those for which the conduit is approved.

**347-4. Other Articles.** Installation of rigid nonmetallic conduit shall comply with the applicable provisions of Article 300. Where equipment grounding is required by Article 250, a separate equipment grounding conductor shall be installed in the conduit.

#### A. Installations

**347-5. Trimming.** All cut ends shall be trimmed inside and outside to remove rough edges.

**347-6. Joints.** All joints between lengths of conduit, and between conduit and couplings, fittings, and boxes, shall be made by an approved method.

**347-8. Supports.** Rigid nonmetallic conduit shall be supported as required in Table 347-8. In addition, there shall be a support within 3 feet (914 mm) of each box, cabinet, or other conduit termination.

**Table 347-8. Support of Rigid Nonmetallic Conduit**

Conduit Size (Inches)	Maximum Spacing Between Supports (Feet)
½-1	3
1¼-2	5
2½-3	6
3½-5	7
6	8

For SI units: (Supports) one foot = 0.3048 meter.

**347-9. Expansion Joints.** Expansion joints for rigid nonmetallic conduit shall be provided to compensate for thermal expansion and contraction.

**347-10. Minimum Size.** No conduit smaller than ½-inch electrical trade size shall be used.

**347-11. Number of Conductors.** The number of conductors permitted in a single conduit shall not exceed the percentage fill specified in Table 1, Tables and Examples.

**347-12. Bushings.** Where a conduit enters a box or other fitting, a bushing or adapter shall be provided to protect the wire from abrasion unless the design of the box or fitting is such as to provide equivalent protection.

See Section 373-6(c) for the protection of conductors at bushings.

**347-13. Bends — How Made.** Bends of rigid nonmetallic conduit shall be so made that the conduit will not be injured and that the internal diameter of the conduit will not be effectively reduced. Field bends shall be made only with bending equipment intended for the purpose, and the radius of the curve of the inner edge of such bends shall not be less than shown in Table 346-10.

**347-14. Bends — Number in One Run.** A run of conduit between outlet and outlet, fitting and fitting, or outlet and fitting shall not contain more than the equivalent of four quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**347-15. Boxes and Fittings.** Boxes and fittings shall comply with the applicable provisions of Article 370.

**347-16. Splices and Taps.** Splices and taps shall be made only in junction, outlet boxes or conduit bodies. Conductors, including splices and taps, shall not fill a conduit body to more than 75 percent of its cross-sectional area at any point. All splices and taps shall be made by approved methods.



## ARTICLE 348 — ELECTRICAL METALLIC TUBING

**348-1. Use.** The use of electrical metallic tubing shall be permitted for both exposed and concealed work. Electrical metallic tubing shall not be used: (1) where, during installation or afterward, it will be subject to severe physical damage; (2) where protected from corrosion solely by enamel; (3) in cinder concrete or cinder fill where subject to permanent moisture unless protected on all sides by a layer of noncinder concrete at least 2 inches (50.8 mm) thick or unless the tubing is at least 18 inches (457 mm) under the fill. Where practicable, dissimilar metals in contact anywhere in the system shall be avoided to eliminate the possibility of galvanic action.

*Exception: Aluminum fittings and enclosures shall be permitted to be used with steel electrical metallic tubing.*

Ferrous or nonferrous electrical metallic tubing, elbows, couplings, and fittings shall be permitted to be installed in concrete, in direct contact with the earth, or in areas subject to severe corrosive influences when protected by corrosion protection and judged suitable for the condition.

See Section 300-6.

**348-2. Other Articles.** Installations of electrical metallic tubing shall comply with the applicable provisions of Article 300.

### A. Installation

**348-4. Wet Locations.** All supports, bolts, straps, screws, etc., shall be of corrosion-resistant materials or protected against corrosion by corrosion-resistant metals.

See Section 300-6 for protection from corrosion.

**348-5. Size.**

(a) **Minimum.** Tubing smaller than 1/2-inch electrical trade size shall not be used.

*Exception No. 1: For underplaster extensions as permitted in Section 344-2.*

*Exception No. 2: For enclosing the leads of motors as permitted in Section 430-145(b) in the NEC.*

(b) **Maximum.** The maximum size of tubing shall be the 4-inch electrical trade size.

**348-6. Number of Conductors in Tubing.** The number of conductors permitted in a single tubing shall not exceed the percentage fill specified in Table 1, Chapter 9.

**348-7. Threads.** Electrical metallic tubing shall not be threaded. Where integral couplings are utilized, such couplings shall be permitted to be factory threaded.

**348-8. Couplings and Connectors.** Couplings and connectors used with tubing shall be made up tight. Where buried in masonry or concrete, they shall be concretetight type. Where installed in wet locations, they shall be of the raintight type.

**348-9. Bends — How Made.** Bends in the tubing shall be so made that the tubing will not be injured and that the internal diameter of the tubing will not be effectively reduced. The radius of the curve of the inner edge of any field bend shall not be less than shown in Table 346-10.

*Exception: For field bends made with a bending machine designed for the purpose, the minimum radius shall not be less than indicated in Table 346-10 Exception.*

**348-10. Bends — Number in One Run.** A run of electrical metallic tubing between outlet and outlet, fitting and fitting, or outlet and fitting shall not contain more than the equivalent of four quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

**348-11. Reaming.** All cut ends of electrical metallic tubing shall be reamed or otherwise finished to remove rough edges.

**348-12. Supports.** Electrical metallic tubing shall be installed as a complete system as provided in Article 300 and shall be securely fastened in place at least every 10 feet (3.05 m) and within 3 feet (914 mm) of each outlet box, junction box, cabinet, or fitting.

**348-13. Boxes and Fittings.** Boxes and fittings shall comply with the applicable provisions of Article 370.

**348-14. Splices and Taps.** Splices and taps shall be made only in junction, outlet boxes or conduit bodies. Conductors, including splices and taps, shall not fill a conduit body to more than 75 percent of its cross-sectional area at any point. All splices and taps shall be made by approved methods.

## ARTICLE 350 — FLEXIBLE METAL CONDUIT

**350-1. Other Articles.** Installations of flexible metal conduit shall comply with the applicable provisions of Articles 300, 333, and 346.

**350-2. Use.** Flexible metal conduit shall not be used: (1) in wet locations, unless conductors are of the lead-covered type or of other type approved for the specific conditions; nor (6) underground or embedded in poured concrete or aggregate.

**350-3. Minimum Size.** Flexible metal conduit less than ½-inch electrical trade size shall not be used.

*Exception No. 3: Flexible metal conduit of ⅜-inch nominal trade size shall be permitted in lengths not in excess of 6 feet (1.83 m) as a part of an approved assembly, or for tap connections to lighting fixtures as required in Section 410-67(c), or for lighting fixtures.*

**Table 350-3. Maximum Number of Insulated Conductors in ⅜-Inch Flexible Metal Conduit.\***

Col. A = With fitting inside conduit.

Col. B = With fitting outside conduit.

Size AWG	Types RFH-2, SF-2		Types TF, T, XHHW, AF, TW, RUH, RUW		Types TFN, THHN, THWN		Types FEP, FEPB, PF, PGF	
	A	B	A	B	A	B	A	B
18	..	3	3	7	4	8	5	8
16	..	2	2	4	3	7	4	8
14	..	..	..	4	3	7	3	7
12	..	..	..	3	..	4	..	4
10	..	..	..	..	..	2	..	3

\* In addition, one uninsulated grounding conductor of the same AWG size shall be permitted.

**350-4. Supports.** Flexible metal conduit shall be secured by an approved means at intervals not exceeding 4½ feet (1.37 m) and within 12 inches (305 mm) on each side of every outlet box or fitting.

*Exception No. 1: Where flexible metal conduit is fished.*

*Exception No. 2: Lengths of not more than 3 feet (914 mm) at terminals where flexibility is necessary.*

*Exception No. 3: Lengths of not more than 6 feet (1.83 m) from a fixture terminal connection for tap connections to lighting fixtures as required in Section 410-67(c).*

**350-5. Grounding.** Flexible metal conduit shall be permitted as a grounding means where both the conduit and the fittings are approved for grounding. Where an equipment bonding jumper is required around flexible metal conduit, it shall be installed in accordance with Section 250-79.

*Exception: Flexible metal conduit shall be permitted as a grounding means if the total length in any ground return path is 6 feet (1.83 m) or less, the conduit is terminated in fittings approved for grounding, and the circuit conductors contained therein are protected by overcurrent devices rated at 20 amperes or less.*

**350-6. Bends.** A run of conduit between outlet and outlet, fitting and fitting, or outlet and fitting shall not contain more than the equivalent of four quarter bends (360 degrees, total), including those bends located immediately at the outlet or fitting.

Angle connectors shall not be used for concealed raceway installations.

## ARTICLE 353 — MULTIOUTLET ASSEMBLY

**353-1. Other Articles.** A multioutlet assembly shall comply with applicable provisions of Article 300.

See definition in Article 100 in the NEC.

**353-2. Use.** The use of multioutlet assembly shall be permitted in dry locations. It shall not be installed: (1) where concealed, except that it shall be permissible to surround the back and sides of a metal multioutlet assembly by the building finish or recess a nonmetallic multioutlet assembly in a baseboard; (2) where subject to severe physical damage. |

**353-3. Metal Multioutlet Assembly Through Dry Partitions.** It shall be permissible to extend a metal multioutlet assembly through (not run within) dry partitions, if arrangements are made for removing the cap or cover on all exposed portions and no outlet is located within the partitions.

## ARTICLE 370 — OUTLET, SWITCH AND JUNCTION BOXES, AND FITTINGS

### A. Scope and General

**370-1. Scope.** This article covers the installation and use of boxes containing outlets, receptacles, switches or devices and junction or pull boxes and conduit bodies as required by Section 300-15. Fittings referred to in Section 300-15 used as outlet, junction or pull boxes shall conform with the provisions of this article depending on their use.

**370-2. Round Boxes.** Round boxes shall not be used where conduits or connectors requiring the use of locknuts or bushings are to be connected to the side of the box.

**370-3. Nonmetallic Boxes.** Nonmetallic boxes shall be permitted only with open wiring on insulators, concealed knob-and-tube wiring, nonmetallic-sheathed cable, and with rigid nonmetallic conduit.

In addition thereto, nonmetallic boxes over 100 cubic inches manufactured with bonding means between all raceway and cable entries shall also be permitted to be used with metal raceways and metal-sheathed cable.

**370-4. Metal Boxes.** Where used with knob-and-tube wiring or nonmetallic-sheathed cable, and mounted on or in contact with metal or metal lath ceilings, walls, or metallic surfaces, metal boxes shall be grounded.

### B. Installation

**370-5. Damp or Wet Locations.** In damp or wet locations, boxes and fittings shall be so placed or equipped as to prevent moisture from entering or accumulating within the box or fitting. Boxes and fittings installed in wet locations shall be listed for use in wet locations.

For boxes in floors, see Section 370-17(b).

For protection against corrosion, see Section 300-6.

**370-6. Number of Conductors in Switch, Outlet, Receptacle, Device, and Junction Boxes.** Boxes shall be of sufficient size to provide free space for all conductors enclosed in the box.

The provisions of this section shall not apply to terminal housings supplied with motors. (See Section 430-12 in the NEC.)

Boxes and conduit bodies containing conductors, size No. 4 or larger, shall also comply with the provisions of Section 370-18.

**(a) Standard Boxes.** The maximum number of conductors, not counting fixture wires, permitted in standard boxes shall be as is listed in Table 370-6(a). See Section 370-18 where boxes or conduit bodies are used as junction or pull boxes.

**(1)** Table 370-6(a) shall apply where no fittings or devices, such as fixture studs, cable clamps, hickies, switches, or receptacles, are contained in the box and where no grounding conductors are part of the wiring within the box. Where one or more of these types of devices, such as fixture studs, cable clamps, or hickies are contained in the box, the number of conductors shown in the table shall be reduced by one for each type of device; an

Table 370-6(a). Metal Boxes

Box Dimension, Inches Trade Size or Type	Min. Cu. In. Cap.	Maximum Number of Conductors				
		No. 14	No. 12	No. 10	No. 8	No. 6
4 x 1¼ Round or Octagonal	12.5	6	5	5	4	0
4 x 1½ Round or Octagonal	15.5	7	6	6	5	0
4 x 2½ Round or Octagonal	21.5	10	9	8	7	0
4 x 1¼ Square	18.0	9	8	7	6	0
4 x 1½ Square	21.0	10	9	8	7	0
4 x 2½ Square	30.3	15	13	12	10	6*
4½ x 1¼ Square	25.5	12	11	10	8	0
4½ x 1½ Square	29.5	14	13	11	9	0
4½ x 2½ Square	42.0	21	18	16	14	6
3 x 2 x 1½ Device	7.5	3	3	3	2	0
3 x 2 x 2 Device	10.0	5	4	4	3	0
3 x 2 x 2¼ Device	10.5	5	4	4	3	0
3 x 2 x 2½ Device	12.5	6	5	5	4	0
3 x 2 x 2¾ Device	14.0	7	6	5	4	0
3 x 2 x 3½ Device	18.0	9	8	7	6	0
4 x 2½ x 1½ Device	10.3	5	4	4	3	0
4 x 2½ x 1¾ Device	13.0	6	5	5	4	0
4 x 2½ x 2½ Device	14.5	7	6	5	4	0
3¼ x 2 x 2½ Masonry Box/Gang	14.0	7	6	5	4	0
3¼ x 2 x 3½ Masonry Box/Gang	21.0	10	9	8	7	0
FS—Minimum Internal Depth 1¼ Single Cover/Gang	13.5	6	6	5	4	0
FD—Minimum Internal Depth 2¾ Single Cover/Gang	18.0	9	8	7	6	3
FS—Minimum Internal Depth 1¼ Multiple Cover/Gang	18.0	9	8	7	6	0
FD—Minimum Internal Depth 2¾ Multiple Cover/Gang	24.0	12	10	9	8	4

\* Not to be used as a pull box. For termination only.

additional deduction of one conductor shall be made for each strap containing one or more devices; and a further deduction of one conductor shall be made for one or more grounding conductors entering the box. A conductor running through the box shall be counted as one conductor, and each conductor originating outside of the box and terminating inside the box is counted as one conductor. Conductors, no part of which leaves the box, shall not be counted. The volume of a wiring enclosure (box) shall be the total volume of the assembled sections, and, where used, the space provided by plaster rings, domed covers, extension rings, etc., that are marked with their volume in cubic inches, or are made from boxes the dimensions of which are listed in Table 370-6(a).

(2) For combinations of conductor sizes shown in Table 370-6(a), the volume per conductor listed in Table 370-6(b) shall apply. The maximum number and size of conductors listed in Table 370-6(a) shall not be exceeded.

(b) **Other Boxes.** Boxes 100 cubic inches or less other than those described in Table 370-6(a), conduit bodies having provision for more than

two conduit entries and nonmetallic boxes shall be durably and legibly marked by the manufacturer with their cubic inch capacity and the maximum number of conductors permitted shall be computed using the volume per conductor listed in Table 370-6(b) and the deductions provided for in Section 370-6(a)(1). Boxes described in Table 370-6(a) that have a larger cubic inch capacity than is designated in the table shall be permitted to have their cubic inch capacity marked as required by this section and the maximum number of conductors permitted shall be computed using the volume per conductor listed in Table 370-6(b).

**Table 370-6(b). Volume Required per Conductor**

Size of Conductor	Free Space Within Box for Each Conductor
No. 14 .....	2. cubic inches
No. 12 .....	2.25 cubic inches
No. 10 .....	2.5 cubic inches
No. 8 .....	3. cubic inches
No. 6 .....	5. cubic inches

Where No. 6 conductors are installed the minimum wire bending space required in Table 373-6(a) shall be provided.

**(c) Conduit Bodies.** Conduit bodies enclosing No. 6 conductors or smaller shall have a cross-sectional area not less than twice the cross-sectional area of the largest conduit to which it is attached. The maximum number of conductors permitted shall be the maximum number permitted by Table 1, Chapter 9, for the conduit to which it is attached.

Conduit bodies having provisions for less than three conduit entries shall not contain splices, taps, or devices unless they comply with the provisions of Section 370-6(b) and are supported in a rigid and secure manner.

**370-7. Conductors Entering Boxes or Fittings.** Conductors entering boxes or fittings shall be protected from abrasion, and shall comply with (a) through (d) below.

**(a) Openings to Be Closed.** Openings through which conductors enter shall be adequately closed.

**(b) Metal Boxes and Fittings.** Where metal outlet boxes or fittings are installed with open wiring or concealed knob-and-tube wiring, conductors shall enter through insulating bushings or, in dry places, through flexible tubing extending from the last insulating support and firmly secured to the box or fitting. Where raceway or cable is installed with metal outlet boxes or fittings, the raceway or cable shall be secured to such boxes and fittings.

**(c) Nonmetallic Boxes.** Where nonmetallic boxes are used with open wiring or concealed knob-and-tube wiring, the conductors shall enter the box through individual holes. Where flexible tubing is used to encase the conductors, the tubing shall extend from the last insulating support to no less than  $\frac{1}{4}$  inch (6.35 mm) inside the box. Where nonmetallic-sheathed cable is used, the cable assembly, including the sheath, shall extend into the



box no less than  $\frac{1}{4}$  inch (6.35 mm) through a nonmetallic-sheathed cable knockout opening. Where nonmetallic-sheathed cable is used with single gang boxes and where the cable is fastened within 8 inches (203 mm) of the box measured along the sheath and where the sheath extends into the box no less than  $\frac{1}{4}$  inch (6.35 mm), securing the cable to the box shall not be required. In all other instances all permitted wiring methods shall be secured to the boxes.

**(d) Conductors No. 4 AWG or Larger.** Installation shall comply with Section 373-6(c).

**370-8. Unused Openings.** Unused openings in boxes and fittings shall be effectively closed to afford protection substantially equivalent to that of the wall of the box or fitting. Metal plugs or plates used with nonmetallic boxes or fittings shall be recessed at least  $\frac{1}{4}$  inch (6.35 mm) from the outer surface.

**370-9. Boxes Enclosing Flush Devices.** Boxes used to enclose flush devices shall be of such design that the devices will be completely enclosed on back and sides, and that substantial support for the devices will be provided. Screws for supporting the box shall not be used in attachment of the device contained therein.

**370-10. In Wall or Ceiling.** In walls or ceilings of concrete, tile, or other noncombustible material, boxes and fittings shall be so installed that the front edge of the box or fitting will not set back of the finished surface more than  $\frac{1}{4}$  inch (6.35 mm). In walls and ceilings constructed of wood or other combustible material, outlet boxes and fittings shall be flush with the finished surface or project therefrom.

**370-11. Repairing Plaster and Drywall or Plasterboard.** Plaster, dry-wall or plasterboard surfaces that are broken or incomplete shall be repaired so there will be no gaps or open spaces at the edge of the box or fitting.

*Exception: On walls or ceilings of concrete, tile, or other noncombustible material.*

**370-12. Exposed Surface Extensions.** In making an exposed surface extension from an existing outlet of concealed wiring, a box or an extension ring shall be mounted over the original box and electrically and mechanically secured to it.

**370-13. Supports.** Boxes shall be securely and rigidly fastened to the surface upon which they are mounted, or securely and rigidly embedded in concrete or masonry. Where nails are used as a mounting means and pass through the interior of the box, they shall be located within  $\frac{1}{4}$  inch (6.35 mm) of the back or ends of the box. Boxes shall be supported from a structural member of the building either directly or by using a substantial and approved metal or wooden brace, or shall be supported as is otherwise provided in this section. If of wood, the brace shall not be less than nominal 1-inch (25.4-mm) thickness. If of metal it shall be corrosion-resistant and shall not be less than No. 24 MSG.

Boxes installed in walls of previously occupied buildings or in walls in which there are no structural members shall be supported by the use of devices, clamps, or anchors which will provide the secure and rigid installation required by this section of the Code.

Threaded boxes or fittings not over 100 cubic inches in size that do not contain devices or support fixtures shall be considered adequately supported if two or more conduits are threaded into the box wrenchtight and are supported within 3 feet (914 mm) of the box on two or more sides as is required by this section.

Threaded boxes or fittings not over 100 cubic inches in size shall be considered to be adequately supported if two or more conduits are threaded into the box wrenchtight and are supported as required by this section within 18 inches (457 mm) of the box.

**370-14. Depth of Outlet Boxes.** No box shall have an internal depth of less than  $\frac{1}{2}$  inch (12.7 mm). Boxes intended to enclose flush devices shall have an internal depth of not less than  $\frac{15}{16}$  inch (23.8 mm).

**370-15. Covers and Canopies.** In completed installations each outlet box shall have a cover, faceplate, or fixture canopy.

**(a) Nonmetallic or Metal Covers and Plates.** Nonmetallic or metal covers and plates shall be permitted with nonmetallic outlet boxes. Where metal covers or plates are used, they shall comply with the grounding requirements of Section 250-42.

See Sections 410-18(a) and 410-56(b) for metal faceplates.

**(b) Exposed Combustible Wall or Ceiling Finish.** Where a fixture canopy or pan is used, any combustible wall or ceiling finish exposed between the edge of the canopy or pan and the outlet box shall be covered with noncombustible material.

**(c) Flexible Cord Pendants.** Covers of outlet boxes having holes through which flexible cord pendants pass shall be provided with bushings designed for the purpose or shall have smooth, well-rounded surfaces on which the cords may bear. So-called hard-rubber or composition bushings shall not be used.

**370-17. Outlet Boxes.**

**(a) Boxes at Lighting Fixture Outlets.** Boxes used at lighting fixture outlets shall be designed for the purpose. At every outlet used exclusively for lighting, the box shall be so designed or installed that a lighting fixture may be attached.

**(b) Floor Boxes.** Boxes listed specifically for this application shall be used for receptacles located in the floor.

*Exception: Boxes located in elevated floors of show windows and similar locations where the authority having jurisdiction judges them to be free from physical damage, moisture, and dirt.*

**370-18. Pull and Junction Boxes.** Boxes and conduit bodies used as pull or junction boxes shall comply with (a) through (d) of this section.

**(a) Minimum Size.** For raceways  $\frac{3}{4}$  inch trade size or larger, containing conductors of No. 4 or larger, and for cables containing conductors of No. 4 or larger, the minimum dimensions of pull or junction boxes installed in a raceway or cable run shall comply with the following:

**(1) Straight Pulls.** In straight pulls the length of the box shall not be less than eight times the trade diameter of the largest raceway.

**(2) Angle or U Pulls.** Where angle or U pulls are made, the distance between each raceway entry inside the box and the opposite wall of the box shall not be less than six times the trade diameter of the largest raceway. This distance shall be increased for additional entries by the amount of the sum of the diameters of all other raceway entries on the same wall of the box. The distance between raceway entries enclosing the same conductor shall not be less than six times the trade diameter of the larger raceway.

*Exception: Where a conduit or cable entry is in the wall of a box or conduit body opposite to a removable cover and where the distance from that wall to the cover is in conformance with the column for one wire per terminal in Table 373-6(a).*

When transposing cable size into raceway size in (a)(1) and (a)(2) above, the minimum trade size raceway required for the number and size of conductors in the cable shall be used.

**(3) Boxes of dimensions less than those required in (a)(1) and (a)(2) above shall be permitted for installations of combinations of conductors that are less than the maximum conduit fill (of conduits being used) permitted by Table 1, Chapter 9, provided the box has been approved for and is permanently marked with the maximum number and maximum size of conductors permitted.**

*Exception: Terminal housings supplied with motors which shall comply with the provisions of Section 430-12 in the NEC.*

**(c) Covers.** All pull boxes, junction boxes, and fittings shall be provided with covers compatible with the box or fitting construction and suitable for the conditions of use. Where metal covers are used, they shall comply with the grounding requirements of Section 250-42.

**(d) Permanent Barriers.** Where permanent barriers are installed in a box, each section shall be considered as a separate box.

**370-19. Junction, Pull and Outlet Boxes to Be Accessible.** Junction, pull and outlet boxes shall be so installed that the wiring contained in them can be rendered accessible without removing any part of the building or in underground circuits without excavating sidewalks, paving, earth, or other substance that is to be used to establish the finished grade.

*Exception: Listed boxes shall be permitted where covered by gravel, light aggregate, or noncohesive granulated soil if their location is effectively identified and accessible for excavation.*

## ARTICLE 373 — CABINETS AND CUTOUT BOXES

**373-1. Scope.** This article covers the installation of cabinets and cutout boxes.

### A. Installation

**373-2. Damp or Wet Locations.** In damp or wet locations, cabinets and cutout boxes of the surface type shall be so placed or equipped as to prevent moisture or water from entering and accumulating within the cabinet or cutout box, and shall be mounted so there is at least  $\frac{1}{4}$ -inch (6.35-mm) air space between the enclosure and the wall or other supporting surface. Cabinets or cutout boxes installed in wet locations shall be weatherproof.

For protection against corrosion, see Section 300-6.

**373-3. Position in Wall.** In walls of concrete, tile, or other noncombustible material, cabinets shall be so installed that the front edge of the cabinet will not set back of the finished surface more than  $\frac{1}{4}$  inch (6.35 mm). In walls constructed of wood or other combustible material, cabinets shall be flush with the finished surface or project therefrom.

**373-4. Unused Openings.** Unused openings in cabinet or cutout boxes shall be effectively closed to afford protection substantially equivalent to that of the wall of the cabinet or cutout box. Where metal plugs or plates are used with nonmetallic cabinets or cutout boxes, they shall be recessed at least  $\frac{1}{4}$  inch (6.35 mm) from the outer surface.

**373-5. Conductors Entering Cabinets or Cutout Boxes.** Conductors entering cabinets or cutout boxes shall be protected from abrasion and shall comply with (a) through (c) below.

**(a) Openings to Be Closed.** Openings through which conductors enter shall be adequately closed.

**(b) Metal Cabinets and Cutout Boxes.** Where metal cabinets or cutout boxes are installed with open wiring or concealed knob-and-tube wiring, conductors shall enter through insulating bushings or, in dry places, through flexible tubing extending from the last insulating support and firmly secured to the cabinet or cutout box.

**(c) Cables.** Where cable is used, each cable shall be secured to the cabinet or cutout box.

**373-6. Deflection of Conductors.** Conductors at terminals or conductors entering or leaving cabinets or cutout boxes and the like shall comply with (b) through (c) below.

**Table 373-6(a). Minimum Wire Bending Space at Terminals and Minimum Width of Wiring Gutters in Inches**

AWG or Circular-Mil Size of Wire	Wires per Terminal				
	1	2	3	4	5
14-10	Not Specified	—	—	—	—
8-6	1½	—	—	—	—
4-3	2	—	—	—	—
2	2½	—	—	—	—
1	3	—	—	—	—
0-00	3½	5	7	—	—
000-0000	4	6	8	—	—

For SI units: one inch = 25.4 millimeters.

Bending space at terminals shall be measured in a straight line from the end of the lug or wire connector (in the direction that the wire leaves the terminal) to the wall, barrier, or obstruction.

**(b) Wire Bending Space at Terminals.** Wire bending space at each terminal shall be provided in accordance with (1) or (2) below:

(1) Table 373-6(a) shall apply where the conductor does not enter or leave the enclosure through the wall opposite its terminal.

*Exception: A conductor shall be permitted to enter or leave an enclosure through the wall opposite its terminal provided the conductor enters or leaves the enclosure at a point where the wire bending space conforms to Table 373-6(b) for that conductor.*

(2) Table 373-6(b) shall apply where the conductor enters or leaves the enclosure through the wall opposite its terminal.

**Table 373-6(b). Minimum Wire Bending Space at Terminals for Section 373-6(b)(2) in Inches**

Wire Size	Wires per Terminal			
	1	2	3	4 or More
14-10	Not Specified	—	—	—
8	1½	—	—	—
6	2	—	—	—
4	3	—	—	—
3	3	—	—	—
2	3½	—	—	—
1	4½	—	—	—
0	5½	5½	7	—
2/0	6	6	7½	—
3/0	6½	6½	8	—
4/0	7	7½	8½	—

For SI units: one inch = 25.4 millimeters.

Bending space at terminals shall be measured in a straight line from the end of the lug or wire connector (in the direction that the wire leaves the terminal) to the wall, barrier, or obstruction.

**(c) Insulated Bushings.** Where ungrounded conductors of No. 4 or larger enter a raceway in a cabinet, pull box, junction box, or auxiliary gutter, the conductors shall be protected by a substantial bushing providing a smoothly rounded insulating surface, unless the conductors are separated from the raceway fitting by substantial insulating material securely fastened in place. Where conduit bushings are constructed wholly of insulating material, a locknut shall be installed both inside and outside the enclosure to which the conduit is attached. The insulating bushing or insulating material shall have a temperature rating not less than the insulation temperature rating of the installed conductors.

**373-7. Space in Enclosures.** Cabinets and cutout boxes shall have sufficient space to accommodate all conductors installed in them without crowding.

**373-8. Enclosures for Switches or Overcurrent Devices.** Enclosures for switches or overcurrent devices shall not be used as junction boxes, auxiliary gutters, or raceways for conductors feeding through or tapping off to other switches or overcurrent devices.

*Exception: Where adequate space is provided so that the conductors do not fill the wiring space at any cross section to more than 40 percent of the cross-sectional area of the space, and so that the conductors, splices, and taps do not fill the wiring space at any cross section to more than 75 percent of the cross-sectional area of the space.*

## ARTICLE 380—SWITCHES

### A. Installation

**380-1. Scope.** The provisions of this article shall apply to all switches, switching devices, and circuit breakers where used as switches.

### 380-2. Switch Connections.

**(a) Three-Way and Four-Way Switches.** Three-way and four-way switches shall be so wired that all switching is done only in the ungrounded circuit conductor. Where in metal enclosures, wiring between switches and outlets shall be run with both polarities in the same enclosure.

**(b) Grounded Conductors.** Switches or circuit breakers shall not disconnect the grounded conductor of a circuit.

*Exception No. 1: Where the switch or circuit breaker simultaneously disconnects all conductors of the circuit.*

*Exception No. 2: Where the switch or circuit breaker is so arranged that the grounded conductor cannot be disconnected until all the ungrounded conductors of the circuit have been disconnected.*

**380-3. Enclosure.** Switches and circuit breakers shall be of the externally operable type mounted in an enclosure listed for the intended use. The minimum wire bending space at terminals and minimum gutter space provided in switch enclosures shall be as required in Section 373-6.

*Exception: Pendant- and surface-type snap switches and knife switches mounted on an open-face switchboard or panelboard.*

**380-4. Wet Locations.** A switch or circuit breaker in a wet location or outside of a building shall be enclosed in a weatherproof enclosure or cabinet that shall comply with Section 373-2.

**380-5. Time Switches, Flashers, and Similar Devices.** Time switches, flashers, and similar devices need not be of the externally operable type. They shall be enclosed in metal boxes or cabinets.

*Exception No. 2: Where enclosed in approved individual housings with no live parts exposed to the operator.*

### 380-8. Accessibility and Grouping.

**(a) Location.** All switches and circuit breakers used as switches shall be so located that they may be operated from a readily accessible place. They shall be so installed that the center of the grip of the operating handle of the switch or circuit breaker, when in its highest position, will not be more than 6½ feet (1.98 m) above the floor or working platform.

*Exception No. 2: Switches installed adjacent to motors, appliances, or other equipment which they supply shall be permitted to be located higher than specified in the foregoing and to be accessible by portable means.*

**380-9. Faceplates for Flush-Mounted Snap Switches.** Flush snap switches, that are mounted in ungrounded metal boxes and located within reach of conducting floors or other conducting surfaces, shall be provided with faceplates of nonconducting, noncombustible material. Metal faceplates shall be of ferrous metal not less than 0.030 inch (0.762 mm) in thickness or of nonferrous metal not less than 0.040 inch (1.016 mm) in

thickness. Faceplates of insulating material shall be noncombustible and not less than 0.10 inch (2.54 mm) in thickness but they shall be permitted to be less than 0.10 inch (2.54 mm) in thickness if formed or reinforced to provide adequate mechanical strength. Faceplates shall be installed so as to completely cover the wall opening and seat against the wall surface.

### **380-10. Mounting of Snap Switches.**

(b) **Box Mounted.** Flush-type snap switches mounted in boxes that are set back of the wall surface as permitted in Section 370-10 shall be installed so that the extension plaster ears are seated against the surface of the wall. Flush-type snap switches mounted in boxes that are flush with the wall surface or project therefrom shall be so installed that the mounting yoke or strap of the switch is seated against the box.

**380-11. Circuit Breakers as Switches.** A hand-operable circuit breaker equipped with a lever or handle, or a power-operated circuit breaker capable of being opened by hand in the event of a power failure, shall be permitted to serve as a switch if it has the required number of poles.

**380-12. Grounding of Enclosures.** Enclosures for switches or circuit breakers on circuits of over 150 volts to ground shall be grounded as specified in Article 250. Where nonmetallic enclosures are used with metal-sheathed cables or metallic conduits, provision shall be made for grounding continuity.

**380-14. Rating and Use of Snap Switches.** Snap switches shall be used within their ratings and as follows:

(a) **AC General-Use Snap Switch.** A form of general-use snap switch suitable only for use on alternating-current circuits for controlling the following:

(1) Resistive and inductive loads, including electric-discharge lamps, not exceeding the ampere rating of the switch at the voltage involved.

(2) Tungsten-filament lamp loads not exceeding the ampere rating of the switch at 120 volts.

(3) Motor loads not exceeding 80 percent of the ampere rating of the switch at its rated voltage.

(b) **AC-DC General-Use Snap Switch.** A form of general-use snap switch suitable for use on either ac or dc circuits for controlling the following:

(1) Resistive loads not exceeding the ampere rating of the switch at the voltage applied.

(2) Inductive loads not exceeding 50 percent of the ampere rating of the switch at the applied voltage. Switches rated in horsepower are suitable for controlling motor loads within their rating at voltage applied.

(3) Tungsten-filament lamp loads not exceeding the ampere rating of the switch at the applied voltage if "T" rated.

For switches controlling motors, see Sections 430-83, 430-109, and 430-110 in the NEC.

(c) **CO/ALR Snap Switches.** Snap switches rated 20 amperes or less directly connected to aluminum conductors shall be listed and marked CO/ALR.



## ARTICLE 384 — PANELBOARDS

### 384-1. General.

(a) **Scope.** This article covers panelboards and distribution boards installed for the control of light and power circuits.

(b) **Other Articles.** Switches, circuit breakers, and overcurrent devices used on switchboards, panelboards, and distribution boards, and their enclosures, shall comply with the requirements of Articles 240, 250, 370, 380, and other articles that apply.

### 384-3. Support and Arrangement of Busbars and Conductors.

(c) **Used as Service Equipment.** Each panelboard, if used as service equipment, shall be provided with a main bonding jumper sized in accordance with Section 250-79(c) or the equivalent placed within the service disconnect section for connecting the grounded service conductor on its supply side to the panelboard frame.

### B. Panelboards

**384-13. General.** All panelboards shall have a rating not less than the minimum feeder capacity required for the load computed in accordance with Article 220. Panelboards shall be durably marked by the manufacturer with the voltage and the current rating and the number of phases for which they are designed and with the manufacturer's name or trademark in such a manner as to be visible after installation, without disturbing the interior parts or wiring.

**384-14. Lighting and Appliance Branch-Circuit Panelboard.** For the purposes of this article, a lighting and appliance branch-circuit panelboard is one having more than 10 percent of its overcurrent devices rated 30 amperes or less, for which neutral connections are provided.

**384-15. Number of Overcurrent Devices on One Panelboard.** Not more than forty-two overcurrent devices (other than those provided for in the mains) of a lighting and appliance branch-circuit panelboard shall be installed in any one cabinet or cutout box.

A lighting and appliance branch-circuit panelboard shall be provided with physical means to prevent the installation of more overcurrent devices than that number for which the panelboard was designed, rated, and approved.

For the purposes of this article, a 2-pole circuit breaker shall be considered two overcurrent devices; a 3-pole breaker shall be considered three overcurrent devices.

### 384-16. Overcurrent Protection.

(a) **Lighting and Appliance Branch-Circuit Panelboard Individually Protected.** Each lighting and appliance branch-circuit panelboard shall be individually protected on the supply side by not more than two main circuit breakers or two sets of fuses having a combined rating not greater than that of the panelboard.

*Exception No. 1: Individual protection for a lighting and appliance panelboard shall not be required if the panelboard feeder has overcurrent protection not greater than that of the panelboard.*

*Exception No. 2: For existing installations, individual protection for lighting and appliance branch-circuit panelboards is not required where such panelboards are used as service equipment in supplying an individual residential occupancy.*

**(b) Snap Switches Rated at 30 Amperes or Less.** Panelboards equipped with snap switches rated at 30 amperes or less shall have overcurrent protection not in excess of 200 amperes.

**(c) Continuous Load.** The total load on any overcurrent device located in a panelboard shall not exceed 80 percent of its rating where in normal operation the load will continue for 3 hours or more.

*Exception: Where the assembly including the overcurrent device is approved for continuous duty at 100 percent of its rating.*

**(d) Supplied through a Transformer.** Where a panelboard is supplied through a transformer, the overcurrent protection required in (a) and (b) above shall be located on the secondary side of the transformer.

*Exception: A panelboard supplied by the secondary side of a single-phase transformer having a two-wire (single-voltage) secondary shall be considered as protected by overcurrent protection provided on the primary (supply) side of the transformer, provided this protection is in accordance with Section 450-3(b)(1) in the NEC and does not exceed the value determined by multiplying the panelboard rating by the secondary-to-primary voltage ratio.*

This is intended to prohibit the use of "delta breakers" in panelboards.

**384-17. Panelboards in Damp or Wet Locations.** Panelboards in damp or wet locations shall be installed to comply with Section 373-2.

**384-18. Enclosure.** Panelboards shall be mounted in cabinets, cutout boxes, or enclosures designed for the purpose and shall be dead front.

*Exception: Panelboards other than of the dead front externally operable type shall be permitted where accessible only to qualified persons.*

**384-19. Relative Arrangement of Switches and Fuses.** In panelboards, fuses of any type shall be installed on the load side of any switches.

*Exception: As provided in Section 230-94 for use as service equipment.*

**384-27. Grounding of Panelboards.** Panelboard cabinets shall be grounded in the manner specified in Article 250 or Section 384-3(c). An approved terminal bar for equipment grounding conductors shall be provided and secured inside of the cabinet for the attachment of all the feeder and branch-circuit equipment grounding conductors, where the panelboard is used with nonmetallic raceway or cable, or where separate grounding conductors are provided. The terminal bar shall be bonded to the cabinet or panelboard frame and shall not be connected to the neutral bar in other than service equipment.

*Exception No. 2: The terminal bar for equipment grounding conductors shall be permitted to be connected to the neutral bar at separate buildings in accordance with the provisions of Section 250-24.*

## ARTICLE 400 — FLEXIBLE CORDS AND CABLES

### A. General

**400-1. Scope.** This article covers general requirements, applications, and construction specifications for flexible cords and flexible cables.

**400-2. Other Articles.** Flexible cords and flexible cables shall comply with this article and with the applicable provisions of other articles of this Code.

**400-3. Suitability.** Flexible cords and cables and their associated fittings shall be suitable for the conditions of use and location.

#### **400-7. Uses Permitted.**

(a) **Uses.** Flexible cords and cables shall be used only for (1) pendants; (2) wiring of fixtures; (3) connection of portable lamps or appliances; (6) connection of stationary equipment to facilitate their frequent interchange; (7) prevention of the transmission of noise or vibration; (8) appliances where the fastening means and mechanical connections are designed to permit removal for maintenance and repair.

(b) **Attachment Plugs.** Where used as permitted in subsections (a)(3), (a)(6), and (a)(8) of this section, each flexible cord shall be equipped with an attachment plug and shall be energized from an approved receptacle outlet.

**400-8. Uses Not Permitted.** Unless specifically permitted in Section 400-7 flexible cords and cables shall not be used (1) as a substitute for the fixed wiring of a structure; (2) where run through holes in walls, ceilings, or floors; (3) where run through doorways, windows, or similar openings; (4) where attached to building surfaces; or (5) where concealed behind building walls, ceilings, or floors.

**400-9. Splices.** Flexible cord shall be used only in continuous lengths without splice or tap when initially installed in applications permitted by Section 400-7(a).

## ARTICLE 410 — LIGHTING FIXTURES, LAMPHOLDERS, LAMPS, AND RECEPTACLES

### A. General

**410-1. Scope.** This article covers lighting fixtures, lampholders, pendants, receptacles, and rosettes, incandescent filament lamps, arc lamps, electric-discharge lamps, the wiring and equipment forming part of such lamps, fixtures and lighting installations which shall conform to the provisions of this article.

*Exception: As otherwise provided in this Code.*

**410-3. Live Parts.** Fixtures, lampholders, lamps, rosettes, and receptacles shall have no live parts normally exposed to contact. Exposed accessible terminals in lampholders, receptacles, and switches shall not be installed in metal fixture canopies or in open bases of portable table or floor lamps.

### B. Fixture Locations

#### 410-4. Fixtures in Specific Locations.

**(a) Wet and Damp Locations.** Fixtures installed in wet or damp locations shall be so constructed or installed that water cannot enter or accumulate in wireways, lampholders, or other electrical parts. All fixtures installed in wet locations shall be marked, "Suitable for Wet Locations." All fixtures installed in damp locations shall be marked, "Suitable for Wet Locations" or "Suitable for Damp Locations."

Installations underground or in concrete slabs or masonry in direct contact with the earth, and locations subject to saturation with water or other liquids, such as locations exposed to weather and unprotected, vehicle washing areas, and like locations, shall be considered to be wet locations with respect to the above requirement.

Interior locations protected from weather but subject to moderate degrees of moisture, such as some basements, some barns, some cold-storage warehouses and the like, the partially protected locations under canopies, marquees, roofed open porches, and the like, shall be considered to be damp locations with respect to the above requirement.

See Article 680 in the NEC for lighting fixtures in swimming pools, fountains, and similar installations.

**(b) Corrosive Locations.** Fixtures installed in corrosive locations shall be of a type approved for such locations.

See Section 210-7 for receptacles in fixtures.

**(d) Pendants.** Hanging fixtures and pendants where located directly above any part of the bathtub shall be so installed that the fixture is not less than 8 feet (2.44 m) above the top of the bathtub.

**410-5. Fixtures Near Combustible Material.** Fixtures shall be so constructed, or installed, or equipped with shades or guards that combustible material will not be subjected to temperatures in excess of 90°C (194°F).

**410-6. Fixtures Over Combustible Material.** Lampholders installed over highly combustible material shall be of the unswitched type. Unless an individual switch is provided for each fixture, lampholders shall be located

at least 8 feet (2.44 m) above the floor, or shall be so located or guarded that the lamps cannot be readily removed or damaged.

#### **410-8. Fixtures in Clothes Closets.**

**(a) Location.** A fixture in a clothes closet shall be permitted to be installed:

**(1)** On the wall above the closet door, provided the clearance between the fixture and a storage area where combustible material may be stored within the closet is not less than 18 inches (457 mm), or

**(2)** On the ceiling over an area which is unobstructed to the floor, maintaining an 18-inch (457-mm) clearance horizontally between the fixture and a storage area where combustible material may be stored within the closet.

A flush recessed fixture with a solid lens or a ceiling-mounted fluorescent fixture shall be permitted to be installed provided there is a 6-inch (152-mm) clearance, horizontally, between the fixture and the storage area.

**(b) Pendants.** Pendants shall not be installed in clothes closets.

**410-9. Space for Cove Lighting.** Coves shall have adequate space and shall be so located that lamps and equipment can be properly installed and maintained.

### **C. Provisions at Fixture Outlet Boxes, Canopies, and Pans**

**410-10. Space for Conductors.** Canopies and outlet boxes taken together shall provide adequate space so that fixture conductors and their connecting devices can be properly installed.

**410-11. Temperature Limit of Conductors in Outlet Boxes.** Fixtures shall be of such construction or so installed that the conductors in outlet boxes shall not be subjected to temperatures greater than that for which the conductors are rated.

Branch-circuit wiring shall not be passed through an outlet box that is an integral part of an incandescent fixture unless the fixture is identified for through wiring.

**410-12. Outlet Boxes to Be Covered.** In a completed installation, each outlet box shall be provided with a cover unless covered by means of a fixture canopy, lampholder, receptacle, rosette, or similar device.

**410-13. Covering of Combustible Material at Outlet Boxes.** Any combustible wall or ceiling finish exposed between the edge of a fixture canopy or pan and an outlet box shall be covered with noncombustible material.

#### **410-14. Connection of Electric-Discharge Lighting Fixtures.**

**(a) Independently of the Outlet Box.** Where electric-discharge lighting fixtures are supported independently of the outlet box, they shall be connected through metal raceways, metal-clad cables, or nonmetallic-sheathed cables.

**(b) Access to Boxes.** Electric discharge lighting fixtures surface mounted over concealed outlet, pull, or junction boxes shall be installed with suitable openings in back of the fixture to provide access to the boxes.

### D. Fixture Supports

**410-15. Supports — General.** Fixtures, lampholders, rosettes, and receptacles shall be securely supported. A fixture that weighs more than 6 pounds (2.72 kg) or exceeds 16 inches (406 mm) in any dimension shall not be supported by the screw shell of a lampholder.

**410-16. Means of Support.**

(a) **Outlet Boxes.** Where the outlet box or fitting will provide adequate support, a fixture shall be attached thereto or be supported as required by Section 370-13 for boxes. A fixture that weighs more than 50 pounds (22.7 kg) shall be supported independently of the outlet box.

(b) **Inspection.** Fixtures shall be so installed that the connections between the fixture conductors and the circuit conductors can be inspected without requiring the disconnection of any part of the wiring.

*Exception: Fixtures connected by attachment plugs and receptacles.*

(c) **Suspended Ceilings.** Framing members of suspended ceiling systems used to support fixtures shall be securely fastened to each other and shall be securely attached to the building structure at appropriate intervals. Fixtures so supported shall be securely fastened to the ceiling framing member by mechanical means, such as bolts, screws, or rivets. Clips identified for use with the type of ceiling framing member(s) and fixture(s) shall also be permitted.

(d) **Fixture Studs.** Fixture studs that are not a part of outlet boxes, hickies, tripods, and crowfeet shall be made of steel, malleable iron, or other approved material.

(e) **Insulating Joints.** Insulating joints that are not designed to be mounted with screws or bolts shall have an exterior metal casing, insulated from both screw connections.

(f) **Raceway Fittings.** Raceway fittings used to support lighting fixtures shall be suitable to support the fixture(s).

### E. Grounding

**410-17. General.** Fixtures and lighting equipment shall be grounded as provided in Part E of this article.

**410-18. Exposed Fixture Parts.**

(a) **With Exposed Conductive Parts.** The exposed conductive parts of lighting fixtures and equipment directly wired or attached to outlets supplied by a wiring method which provides an equipment ground shall be grounded.

(b) **Made of Insulating Material.** Fixtures directly wired or attached to outlets supplied by a wiring method which does not provide a ready means for grounding shall be made of insulating material and shall have no exposed conductive parts.

**410-20. Equipment Grounding Conductor Attachment.** Fixtures with exposed metal parts shall be provided with a means for connecting an equipment grounding conductor for such fixtures.

*Exception: This requirement shall become effective April 1, 1982.*

**410-21. Methods of Grounding.** Equipment shall be considered grounded where mechanically connected in a permanent and effective manner to metal raceway, the armor of armored cable, mineral-insulated, metal-sheathed cable, and the continuous sheath of Type MC cable, the grounding conductor in nonmetallic-sheathed cable, or to a separate grounding conductor sized in accordance with Table 250-95, provided that the raceway, armor, or grounding conductor is grounded in a manner specified in Article 250.

#### F. Wiring of Fixtures

**410-22. Fixture Wiring — General.** Wiring on or within fixtures shall be neatly arranged and shall not be exposed to physical damage. Excess wiring shall be avoided. Conductors shall be so arranged that they shall not be subjected to temperatures above those for which they are rated.

**410-23. Polarization of Fixtures.** Fixtures shall be so wired that the screw shells of lampholders will be connected to the same fixture or circuit conductor or terminal. The identified grounded conductor, where connected to a screw-shell lampholder, shall be connected to the screw shell.

#### **410-28. Protection of Conductors and Insulation.**

(a) **Properly Secured.** Conductors shall be secured in a manner that will not tend to cut or abrade the insulation.

(b) **Protection Through Metal.** Conductor insulation shall be protected from abrasion where it passes through metal.

(c) **Fixture Stems.** Splices and taps shall not be located within fixture arms or stems.

(d) **Splices and Taps.** No unnecessary splices or taps shall be made within or on a fixture.

For approved means of making connections, see Section 110-14.

(e) **Stranding.** Stranded conductors shall be used for wiring on fixture chains and on other movable or flexible parts.

(f) **Tension.** Conductors shall be so arranged that the weight of the fixture or movable parts will not put a tension on the conductors.

#### **410-30. Cord-Connected Lampholders and Fixtures.**

(c) **Electric-Discharge Fixtures.** It shall be permissible to locate cord-equipped fixtures directly below the outlet box, if the cord is continuously visible for its entire length outside the fixture and is not subject to strain or physical damage. Such cord-equipped fixtures shall terminate at the outer end of the cord in a grounding-type attachment plug (cap) or busway plug.

**410-31. Fixtures as Raceways.** Fixtures shall not be used as a raceway for circuit conductors.

*Exception No. 1: Fixtures approved for use as a raceway.*

*Exception No. 2: Fixtures designed for end-to-end assembly to form a continuous raceway or fixtures connected together by recognized wiring methods shall be permitted to carry through conductors of a two-wire or multiwire branch circuit supplying the fixtures.*

*Exception No. 3: One additional two-wire branch circuit separately supplying one or more of the connected fixtures described in Exception No. 2 shall be permitted to be carried through the fixtures.*

See Article 100 in the NEC for definition of multiwire branch circuit.

Branch-circuit conductors within 3 inches (76 mm) of a ballast within the ballast compartment shall be recognized for use at temperatures not lower than 90°C (194°F), such as Types RHH, THW, THHN, FEP, FEPB, SA, XHHW, and AVA.

#### H. Installation of Lampholders

**410-47. Screw-Shell Type.** Lampholders of the screw-shell type shall be installed for use as lampholders only. Where supplied by a circuit having a grounded conductor, the grounded conductor shall be connected to the screw shell.

**410-48. Double-Pole Switched Lampholders.** Where used on unidentified two-wire circuits tapped from the ungrounded conductors of multiwire circuits, the switching device of lampholders of the switched type shall simultaneously disconnect both conductors of the circuit in accordance with Section 210-10.

**410-49. Lampholders in Wet or Damp Locations.** Lampholders installed in wet or damp locations shall be of the weatherproof type.

#### L. Receptacles, Cord Connectors, and Attachment Plugs (Caps)

##### 410-56. Rating and Type.

**(a) Receptacles.** Receptacles installed for the attachment of portable cords shall be rated at not less than 15 amperes, 125 volts, or 15 amperes, 250 volts, and shall be of a type not suitable for use as lampholders.

*Exception: The use of receptacles of 10-ampere, 250-volt rating used in nonresidential occupancies for the supply of equipment other than portable hand tools, portable handlamps, and extension cords shall be permitted.*

**(b) Faceplates.** Metal faceplates shall be of ferrous metal not less than 0.030 inch (762 micrometers) in thickness or of nonferrous metal not less than 0.040 inch (1 mm) in thickness. Metal faceplates shall be grounded. Faceplates of insulating material shall be noncombustible and not less than 0.10 inch (2.54 mm) in thickness but shall be permitted to be less than 0.10 inch (2.54 mm) in thickness if formed or reinforced to provide adequate mechanical strength.

**(c) Position of Receptacle Faces.** After installation, receptacle faces shall be flush with or project from faceplates of insulating material and shall project a minimum of 0.015 inch (381 micrometers) from metal faceplates. Faceplates shall be installed so as to completely cover the opening and seat against the mounting surface. Boxes shall be installed in accordance with Section 370-10.

**(g) Conductors.** Receptacles rated 20 amperes or less directly connected to aluminum conductors shall be marked CO/ALR.

##### 410-57. Receptacles in Damp or Wet Locations.

**(a) Damp Locations.** A receptacle installed outdoors in a location protected from the weather or in other damp locations shall have an



enclosure for the receptacle that is weatherproof when the receptacle is covered (attachment plug cap not inserted and receptacle covers closed).

An installation suitable for wet locations shall also be considered suitable for damp locations.

A receptacle shall be considered to be in a location protected from the weather where located under roofed open porches, canopies, marquees, and the like, and will not be subjected to a beating rain or water run-off.

**(b) Wet Locations.** A receptacle installed outdoors where exposed to weather or in other wet locations shall be in a weatherproof enclosure, the integrity of which is not affected when the receptacle is in use (attachment plug cap inserted).

*Exception: An enclosure that is weatherproof only when a self-closing receptacle cover is closed shall be permitted to be used for a receptacle installed outdoors where the receptacle is not to be used with other than portable tools or other portable equipment not left connected to the outlet indefinitely.*

**(d) Flush Mounting with Faceplate.** The enclosure for a receptacle installed in an outlet box flush-mounted on a wall surface shall be made weatherproof by means of a weatherproof faceplate assembly that provides a watertight connection between the plate and the wall surface.

**(e) Installation.** A receptacle outlet installed outdoors shall be located so that water accumulation is not likely to touch the outlet cover or plate.

#### **410-58. Grounding-type Receptacles, Adapters, Cord Connectors, and Attachment Plugs.**

**(c) Grounding Terminal Use.** A grounding terminal or grounding-type device shall not be used for purposes other than grounding.

### **N. Special Provisions for Flush and Recessed Fixtures**

**410-64. General.** Fixtures installed in recessed cavities in walls or ceilings shall comply with Sections 410-65 through 410-67.

#### **410-65. Temperature.**

**(a) Combustible Material.** Fixtures shall be so installed that adjacent combustible material will not be subjected to temperatures in excess of 90°C (194°F).

**(b) Fire-Resistant Construction.** Where a fixture is recessed in fire-resistant material in a building of fire-resistant construction, a temperature higher than 90°C (194°F), but not higher than 150°C (302°F), shall be considered acceptable if the fixture is plainly marked that it is approved for that service.

**(c) Recessed Incandescent Fixtures.** Incandescent fixtures shall have thermal protection and shall so be identified as thermally protected.

*Exception No. 1: Recessed incandescent fixtures identified for use and installed in poured concrete.*

*Exception No. 2: Recessed incandescent fixtures identified as suitable for installation in cavities where the thermal insulation will be in direct contact with the fixture.*

The requirements of Section 410-65(c) shall become effective April 1, 1982.

**410-66. Clearance.** Recessed portions of enclosures, other than at points of support, shall be spaced at least  $\frac{1}{2}$  inch (12.7 mm) from combustible material. Thermal insulation shall not be installed within 3 inches (76 mm) of the recessed fixture enclosure, wiring compartment, or ballast and shall not be so installed above the fixture as to entrap heat and prevent the free circulation of air unless the fixture is otherwise identified for installation within thermal insulation.

**410-67. Wiring.**

(a) **General.** Conductors having insulation suitable for the temperature encountered shall be used.

(b) **Circuit Conductors.** Branch-circuit conductors having an insulation suitable for the temperature encountered shall be permitted to terminate in the fixture.

(c) **Tap Conductors.** Tap conductors of a type suitable for the temperature encountered shall be permitted to run from the fixture terminal connection to an outlet box placed at least 1 foot (305 mm) from the fixture. Such tap conductors shall be in a suitable metal raceway of at least 4 feet (1.22 m) but not more than 6 feet (1.83 m) in length.

**Q. Special Provisions for Electric-Discharge Lighting Systems of 1000 Volts or Less**

**410-73. General.**

(a) **Open-Circuit Voltage of 1000 Volts or Less.** Equipment for use with electric-discharge lighting systems and designed for an open-circuit voltage of 1000 volts or less shall be of a type intended for such service.

(e) **Thermal Protection.** Where fluorescent fixtures are installed indoors, the ballasts shall have thermal protection integral within the ballast. Replacements for these ballasts shall also be integrally protected.

*Exception to (e) above: Fluorescent fixtures with simple reactance ballasts.*

(f) **Recessed High-Intensity Discharge Fixtures.** Where recessed high-intensity discharge fixtures with integral ballast are installed indoors, the ballasts shall have thermal protection integral within the ballast. Replacements for these ballasts shall also be integrally protected.

*Exception: This requirement shall become effective January 1, 1982.*

**410-75. Voltages — Dwelling Occupancies.**

(a) **Open-Circuit Voltage Exceeding 1000 Volts.** Equipment having an open-circuit voltage exceeding 1000 volts shall not be installed in dwelling occupancies.

(b) **Open-Circuit Voltage Exceeding 300 Volts.** Equipment having an open-circuit voltage exceeding 300 volts shall not be installed in dwelling occupancies unless such equipment is so designed that there will be no exposed live parts when lamps are being inserted, are in place, or are being removed.

**410-76. Fixture Mounting.**

(a) **Exposed Ballasts.** Fixtures having exposed ballasts or transformers shall be so installed that such ballasts or transformers will not be in contact with combustible material.

**(b) Combustible Low-Density Cellulose Fiberboard.** Where a surface-mounted fixture containing a ballast is to be installed on combustible low-density cellulose fiberboard, it shall be approved for this condition or shall be spaced not less than 1½ inches (38 mm) from the surface of the fiberboard. Where such fixtures are partially or wholly recessed, the provisions of Sections 410-64 through 410-67 shall apply.

Combustible low-density cellulose fiberboard includes sheets, panels, and tiles that have a density of 20 pounds per cubic foot (320.36 kg/cu m) or less, and that are formed of bonded plant fiber material but does not include solid or laminated wood, nor fiberboard that has a density in excess of 20 pounds per cubic foot (320.36 kg/cu m) or is a material that has been integrally treated with fire-retarding chemicals to the degree that the flame spread in any plane of the material will not exceed 25, determined in accordance with tests for surface burning characteristics of building materials. See Method of Test for Surface Burning Characteristics of Building Materials, ANSI A2.5-1977.

## ARTICLE 422 — APPLIANCES

### A. General

**422-1. Scope.** This article covers electric appliances used in any occupancy.

**422-2. Live Parts.** Appliances shall have no live parts normally exposed to contact.

*Exception: Toasters, grills, or other appliances in which the current-carrying parts at high temperatures are necessarily exposed.*

### B. Branch-Circuit Requirements

**422-5. Branch-Circuit Sizing.** This section specifies sizes of conductors capable of carrying appliance current without overheating under the conditions specified. This section shall not apply to conductors that form an integral part of an appliance.

**(a) Individual Circuits.** The rating of an individual branch circuit shall not be less than the marked rating of the appliance or the marked rating of an appliance having combined loads as provided in Section 422-32.

*Exception No. 1: For motor-operated appliances not having a marked rating the branch-circuit size shall be in accordance with Part B of Article 430.*

*Exception No. 2: For an appliance, other than a motor-operated appliance, that is continuously loaded, the branch-circuit rating shall not be less than 125 percent of the marked rating; or not less than 100 percent if the branch-circuit device and its assembly is approved for continuous loading at 100 percent of its rating.*

*Exception No. 3: Branch circuits for household cooking appliances shall be permitted to be in accordance with Table 220-19.*

**(b) Circuits Supplying Two or More Loads.** For branch circuits supplying appliance and other loads, the rating shall be determined in accordance with Section 210-23.

**422-6. Branch-Circuit Overcurrent Protection.** Branch circuits shall be protected in accordance with Section 240-3.

If a protective device rating is marked on an appliance, the branch-circuit overcurrent device rating shall not exceed the protective device rating marked on the appliance.

### C. Installation of Appliances

**422-7. General.** All appliances shall be installed in an approved manner.

**422-8. Flexible Cords.**

**(c) Other Appliances.** Flexible cord shall be permitted: (1) for connection of appliances to facilitate their frequent interchange or to prevent the transmission of noise or vibration, or (2) to facilitate the removal or disconnection of appliances, that are fastened in place, for maintenance or repair.

**(d) Specific Appliances.**

(1) Electrically operated kitchen waste disposers intended for dwelling unit use and provided with a Type S, SO, ST, STO, SJ, SJO, SJT, SJTO, or SPT-3, three-conductor cord terminated with a grounding-type attachment plug shall be permitted where all of the following conditions are met:

a. The length of the cord shall not be less than 18 inches (457 mm) and not over 36 inches (914 mm).

b. Receptacles shall be located to avoid physical damage to the flexible cord.

c. The receptacle shall be accessible.

(2) Built-in dishwashers and trash compactors intended for dwelling unit use and provided with a Type S, SO, ST, STO, SJ, SJO, SJT, SJTO or SPT-3, three-conductor cord terminated with a grounding-type attachment plug shall be permitted where all of the following conditions are met:

a. The length of the cord shall be 3 to 4 feet (0.914 to 1.22 m).

b. Receptacles shall be located to avoid physical damage to the flexible cord.

c. The receptacle shall be located in the space occupied by the appliance or adjacent thereto.

d. The receptacle shall be accessible.

*Exception: Listed kitchen waste disposers, dishwashers and trash compactors protected by a system of double insulation, or its equivalent, shall not be required to be grounded. Where such a system is employed, the equipment shall be distinctively marked.*

**422-10. Protection of Combustible Material.** Each electrically heated appliance that is intended by size, weight, and service to be located in a fixed position shall be so placed as to provide ample protection between the appliance and adjacent combustible material.

**422-14. Water Heaters.**

**(a) Storage- and Instantaneous-type Water Heaters.** Each storage- or instantaneous-type water heater shall be equipped with a temperature-limiting means in addition to its control thermostat to disconnect all ungrounded conductors, and such means shall be: (1) installed to sense maximum water temperature and, (2) either a trip-free, manually reset type or a type having a replacement element. Such water heaters shall be marked to require the installation of a temperature and pressure relief valve.

See Listing Requirements for Relief Valves and Automatic Gas Shutoff Devices for Hot Water Supply Systems (ANSI Z21.22-1972).

*Exception: Water heaters with supply water temperature of 82°C (180°F) or above and a capacity of 60 kW or above and identified as being suitable for this use; and water heaters with a capacity of 1 gallon (3.785 L) or less and identified as being suitable for such use.*

**(b) Storage-type Water Heaters.** All fixed storage-type water heaters having a capacity of 120 gallons (454.2 L) or less shall have a branch-circuit rating not less than 125 percent of the nameplate rating of the water heater.

For branch-circuit sizing, see Section 422-5(a), Exception No. 2.