



# UL 789

## STANDARD FOR SAFETY

### Indicator Posts for Fire-Protection Service

ULNORM.COM : Click to view the full PDF of UL 789 2018

ULNORM.COM : Click to view the full PDF of UL 789 2018

UL Standard for Safety for Indicator Posts for Fire-Protection Service, UL 789

Tenth Edition, Dated January 9, 2004

### **SUMMARY OF TOPICS**

***This revision of ANSI/UL 789 is being issued to Revised Requirements to Above Ground Valve Mounted Indicator Post.***

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated March 23, 2018 and July 13, 2018.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 789 2018

**JANUARY 9, 2004**

(Title Page Reprinted: September 4, 2018)



**ANSI/UL 789-2018**

**1**

## **UL 789**

### **Standard for Indicator Posts for Fire-Protection Service**

The First and Second editions were titled "Standard for Indicator Posts" and numbered UL 262C.

First Edition – March, 1931  
Second Edition – May, 1951  
Third Edition – June, 1966  
Fourth Edition – May, 1971  
Fifth Edition – January, 1975  
Sixth Edition – July, 1976  
Seventh Edition – July, 1982  
Eighth Edition – June, 1987  
Ninth Edition – September, 1993

#### **Tenth Edition**

**January 9, 2004**

This ANSI/UL Standard for Safety consists of the Tenth Edition including revisions through September 4, 2018.

The most recent designation of ANSI/UL 789 as an American National Standard (ANSI) occurred on September 4, 2018. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

**COPYRIGHT © 2018 UNDERWRITERS LABORATORIES INC.**

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 789 2018

## CONTENTS

### INTRODUCTION

1 Scope .....	5
2 Components .....	5
3 Units of Measurement .....	6
4 Undated References .....	6

### CONSTRUCTION

5 Barrels .....	6
6 Caps .....	6B
7 Operating Stems .....	6B
7.1 General .....	6B
7.2 Underground types .....	6B
8 Position Indicators .....	7
8.1 General .....	7
8.2 Rotating target mechanisms .....	9
8.3 Vertically moving target mechanisms .....	10
9 Extension Rods .....	10
10 Handwheels and Wrenches .....	10
11 Locking and Sealing .....	10
12 Polymeric Materials and Nonmetallic Parts .....	11

### PERFORMANCE

13 Strength of Parts Test .....	11
14 Elastomeric Parts (Except Gaskets) Test .....	12
15 Polymeric Parts Tests .....	12A
15.1 Air oven aging test .....	12A
15.2 Light and water test .....	13
15.3 1000 cycle operation test .....	13

### MARKING

16 Details .....	14
------------------	----

**Appendix A**

A1 Example of an Above Ground Indicator Post .....	A1
--	----

ULNORM.COM : Click to view the full PDF of UL 789 2018



## INTRODUCTION

### 1 Scope

1.1 These requirements cover indicator posts, including wall, underground, and above ground types, for use in operating valves of the inside-screw pattern and for indicating the position of the gates in such valves. Indicator posts are primarily intended for use with valves controlling water supplies to sprinkler, deluge, water spray, foam, and standpipe systems used in private fire service where connections enter buildings.

1.2 Requirements for the installation and use of the indicator posts covered by this standard are included in the following Standards of the National Fire Protection Association:

- a) NFPA 11, Low Expansion Foam and Combined Agent Systems;
- b) NFPA 13, Installation of Sprinkler Systems;
- c) NFPA 14, Installation of Standpipe and Hose Systems; and
- d) NFPA 24, Installation of Private Fire Service Mains.

### 2 Components

2.1 Except as indicated in 2.2, a component of a product covered by this standard shall comply with the requirements for that component.

2.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

### 3 Units of Measurement

3.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

### 4 Undated References

4.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

## CONSTRUCTION

### 5 Barrels

5.1 The walls of a barrel shall be made of material having physical and corrosion resistant properties at least equivalent to one of the following:

a) Gray iron extra-heavy soil pipe (0.25 inch nominal thickness) in accordance with the Standard Specification for Cast Iron Soil Pipe and Fittings, ASTM A74, for either the upper or lower barrel;

b) Minimum 0.21-inch thick ductile iron in accordance with the Standard for Ductile Iron Pipe Centrifugally Cast, for Water, ANSI/AWWA C151/A21.51, for either the upper or lower barrel;

c) Schedule 40 steel pipe for either the upper or lower barrel in accordance with Standard Specification for Pipe, Steel, Black, and Hot-Dipped, Zinc-Coated, Welded and Seamless, ASTM A53, and the Standard Specification for Electric-Resistance-Welded Steel Pipe, ASTM A135;

c1) Steel tubing made in accordance with Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes, ASTM A500, with a minimum wall thickness at least equivalent to schedule 40 steel pipe of the same size.

d) Class 200 polyvinyl chloride (PVC) pipe in accordance with the Standard for Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 4 inch through 12 inch for Water Distribution, AWWA C-900, for the lower barrel of indicator posts for underground use.

5.2 Ferrous materials having wall thickness less than those specified in 5.1 and provided with a protective interior and exterior coating may be used when determined to be equivalent using comparative corrosion analysis.

5.3 The inside diameter shall be nominally 4 inches (102 mm) at any point throughout its length. The inside diameter at the bottom of the lower part shall be not less than 8 inches (203 mm) over the length required to provide for clearance to the valve bonnet when attached to the valve flange.

5.4 The length of a barrel for an underground valve shall be such that the middle of the target windows can be placed at least 30 inches (760 mm) above the "bury" line marked on the barrel.

5.5 If the length of a barrel for an underground valve is adjustable:

- a) The upper part shall extend below the ground a distance of not less than 6 inches (152 mm);
- b) The means for connecting the upper and lower parts shall prevent dirt from entering inside the barrel. Means for dirt entrance prevention may include the use of an "O"-ring seal installed in a groove between the upper and lower parts of the barrel constructed to resist dislodgement; having the upper barrel part telescope over the lower barrel part with the top of the lower part extending above the "bury" line; or the like; and
- c) The parts shall be clamped together by two 3/4 inch (19.1 mm) diameter mild-steel setscrews, complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M, or having equivalent strength, placed one above the other in the upper part. The lower part shall be arranged so as to prevent separation or rotation of the upper part.

5.6 Prevention of separation may be accomplished by providing on the lower part either deeply spotted holes for the ends of the setscrews or a series of horizontal ribs spaced the same distance apart as the setscrews. Prevention of rotation may be accomplished by casting four vertical ribs on the exterior of the lower part. Setscrews may also be used to prevent separation and rotation.

5.7 The upper part of a barrel for underground service shall be constructed so that there is no projection, flange, taper, or roughness by which the action of frost may lift the part. A bead, if used to mark the "bury" line, shall not be raised more than 1/8 inch (3.2 mm) on the casting.

5.8 An indicator post shall be provided with a base flange for connection to the indicator-post flange provided as part of the inside-screw gate valve. The indicator-post flange shall be drilled for four 5/8 inch (15.9 mm) diameter mild-steel bolts, complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M, or having equivalent strength, placed at 90 degrees on a bolt circle of 10-1/2 inches (267 mm) for valves up to and including 14 inches (356 mm).

5.9 The barrel for a wall-mounted indicator post shall be provided with an integral flange for bolting to the outside of the wall. The flange shall provide for four 5/8 inch (15.9 mm) diameter mild-steel bolts, complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M, or having equivalent strength, placed at 90 degrees on a bolt circle of at least 10-1/2 inches (267 mm). The inside diameter of the barrel shall provide a minimum 1/2 inch (12.7 mm) clearance between moving parts and the barrel.

5.10 An above ground indicator post shall be provided with a base flange for connection to the indicator-post flange provided as part of the inside-screw gate valve. The base flange shall be integral to the barrel or be securely fastened to the barrel, such as by the use of two 1/2 inch (12.7 mm) diameter mild-steel bolts complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M. The indicator post flange shall be drilled for four 5/8 inch (15.9 mm) diameter mild-steel bolts, complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M, or having equivalent strength, placed at 90 degrees on a bolt circle of 10-1/2 inches (267 mm) for valves up to and including 14 inches (356 mm). An example of an above ground indicator post is shown in Appendix A. The overall height of an above ground indicator post, the distance from the bottom of the base flange to the top of the handwheel or operating wrench, shall be limited to 20 inches.

## 6 Caps

6.1 A cap shall:

- a) Be of weatherproof construction;
- b) Be securely fastened to the barrel, such as by the use of two 1/2 inch (12.7 mm) diameter mild-steel bolts complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M;
- c) Furnish a bearing complying with the requirements of 7.1.1; and
- d) Provide means for lubrication of this bearing.

## 7 Operating Stems

### 7.1 General

7.1.1 An operating stem shall:

- a) Turn freely in its bearing;
- b) Not become clamped to its bearing by locknuts; and
- c) Turn no matter what the position may be of any target nut, target, or other indicating mechanism.

7.1.2 The size and length of thread on the operating stem or stem nut for operation of a moving-target mechanism shall be such that the indicator post may be used interchangeably for all sizes of the particular make of valve for which the post is designed.

### 7.2 Underground types

7.2.1 An operating stem and stem nut shall be made of material having the physical and corrosion resistant properties at least equivalent to those complying with the Specification for Composition Bronze or Ounce Metal Castings, ASTM B62, Copper Alloy No. C83600, or the Specification for Free-Cutting Brass Rod, Bar, and Shapes for Use in Screw Machines, ASTM B16, brass or bronze, except that materials not inherently resistant to corrosion, but otherwise equivalent, may be used if sealed in a housing completely filled with a protective grease lubricant. A stem nut shall be cored at least 4 inches (102 mm) deep to fit loosely over the extension rod.

7.2.2 The upper end of an operating stem nut shall be finished in a solid nut, 1-1/4 inches (31.8 mm) square by 1 inch (25.4 mm) high, unless otherwise specifically ordered to have a different size and shape to fit existing equipment.

7.2.3 The shape of the operating stem nut at the base of the nut shall form a cap of weatherproof construction over the bearing area in the post cap.

## 8 Position Indicators

### 8.1 General

8.1.1 An indicator post shall provide a means for visually indicating the OPEN and SHUT positions of a valve to which it is connected. The means provided shall consist of words appearing on movable targets indicating OPEN and SHUT positions or provide equivalent visual indication of the valve position when viewed from at least two positions 180 degrees apart.

8.1.2 The mechanical or other means used for positioning the visual indicators shall be operated in a manner equivalent to that obtained by gearing to the operating stem or stem nut of the valve.

ULNORM.COM : Click to view the full PDF of UL 789 2018

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 789 2018

8.1.3 An indicator operating mechanism shall be constructed so that it is not subject to disarrangement in operation. The mechanism shall not limit the turning of the operating stem or stem nut.

8.1.4 Two window openings shall be provided on opposite sides of the barrel near its top for position indicators of the movable-target type. Window openings shall be at least 1-1/4 inches (31.8 mm) high and at least as wide as the word width plus the thickness of the window material, and shall be constructed to show the targets clearly.

8.1.5 Windows for openings shall be of transparent material. When of glass, they shall be at least 1/2 inch (12.7 mm) thick clear sheet or float glass conforming to Federal Specification DD-G-451-C. Glass shall be held in place by a corrosion-resistant metallic ferrule or grating. When constructed of an acrylic or polycarbonate material the minimum thickness shall be 1/8 inch (3.2 mm).

8.1.6 Glass window material shall be protected with a grating of bars 1/8 inch (3.2 mm) wide and 1/4 inch (6.4 mm) deep, arranged with one central horizontal bar and several vertical bars, the latter to come between the target letters. There shall be a space of at least 1/4 inch between the grating and window material.

8.1.7 Target-plate material shall be of aluminum or other equivalent light-colored weather- and corrosion-resistant material.

8.1.8 The words OPEN and SHUT shall be used on targets, and each word shall be on a separate plate. The letters shall be at least 1 inch (25.4 mm) high and raised at least 1/8 inch (3.2 mm). The words shall be not less than 2-1/2 inches (63.5 mm) wide. The face of the letters shall be smoothly finished and shall be 1/8 inch (3.2 mm) wide.

8.1.9 A target background shall be black.

8.1.10 When targets are adjusted as intended, the appropriate word shall be visible at both windows when the valve is open or shut.

8.1.11 Target plates shall be interchangeable to suit valves opening either counterclockwise (right hand) or clockwise (left hand).

## **8.2 Rotating target mechanisms**

8.2.1 Threads and gears shall be made of material having the physical and corrosion resistant properties at least equivalent to bronze complying with the Specification for Composition Bronze or Ounce Metal Castings, ASTM B62, Copper Alloy No. 836, or brass complying with the Specification for Free-Cutting Brass Rod, Bar, and Shapes for Use in Screw Machines, ASTM B16, except that materials not inherently resistant to corrosion, but otherwise equivalent, may be used if sealed in a housing completely filled with a protective grease lubricant. Where other moving parts are in contact outside of a grease-lubricated housing, at least one shall be of brass or bronze.

8.2.2 If the post is adjustable for different sizes of valves, the words OPEN and SHUT shall be on separate plates.

### 8.3 Vertically moving target mechanisms

8.3.1 Target nut threads shall be made of material having corrosion resistant properties at least equivalent to brass or bronze.

8.3.2 Target plates shall be adjustable relative to each other to suit the number of turns required by the different sizes of the make of valve for which the post is designed.

8.3.3 A target mechanism shall be such that, when adjusted as intended, the words OPEN or SHUT will not show when the target nut travels off the thread at the top or bottom of the operating stem.

## 9 Extension Rods

9.1 An extension rod shall be made of material having physical properties at least equivalent to malleable iron complying with the Specification for Cupola Malleable Iron, ASTM A197, or mild-steel complying with the Specification for Carbon Steel Forgings for Piping Components, ASTM A105/A105M.

9.2 An extension rod shall be secured to the valve-stem nut in a manner permitting the axis of the extension rod to swing in any direction at least 5 degrees off the vertical, thus allowing for nonalignment of parts.

## 10 Handwheels and Wrenches

10.1 A wrench or a handwheel shall be provided with each indicator post.

10.2 A wrench shall be not less than 12 inches (305 mm) long, measured from the center of the operating nut.

10.3 A handwheel shall be not less than 14 inches (356 mm) in outside diameter. A component that secures a handwheel to the operating nut shall be constructed of high strength metal, such as mild steel.

## 11 Locking and Sealing

11.1 An indicator post shall permit the operating-stem nut to be sealed in the open or shut position to make it necessary to break the seal before the operating-stem nut can be turned more than two complete turns, or before a post cap can be removed.

11.2 If the method of sealing is by use of a common lead and twisted wire seal inserted through a hole in the operating-stem nut, such hole shall be located so that the sealing wire will not become abraded or broken by repeated applications of the wrench or handwheel to the operating nut during inspection testing of the valve.

11.3 All holes for sealing wire shall be 3/32 inch (2.4 mm) diameter minimum.

11.4 A locking arrangement shall be furnished.



## 12 Polymeric Materials and Nonmetallic Parts

12.1 A polymeric or other nonmetallic part, other than an "O" ring, a window as described in 8.1.5, or gasket, shall be evaluated on the basis of:

- a) Mechanical strength, see Strength of Parts Test, Section 13;
- b) Flammability, see 12.2;
- c) Resistance to deterioration due to aging, see Air Oven Aging Tests, 15.1;
- d) Exposure to light and water, see Light and Water Test, 15.2;
- e) Operation, see 1000 Cycle Operation Test, 15.3.

*Exception: A lower barrel complying with 5.1(d) is not required to comply with 12.1 (b), (c), (d), and (e).*

12.2 With reference to flammability, polymeric materials shall be classified as Type HB, V-0, V-1, V-2, 5VA, or 5VB when tested in accordance with the Standard for Tests for Flammability of Plastic Materials for Parts in Devices and Appliances, UL 94. Other nonmetallic materials shall have equivalent characteristics.

## PERFORMANCE

### 13 Strength of Parts Test

13.1 Representative samples of each indicator-post design shall be subjected to the Strength of Parts Test.

13.2 An indicator-post assembly, including the barrel, cap, operating stem, stem nut, extension rod, and wrench or handwheel shall withstand, without damage, the turning effort specified in Table 13.1 applied through the wrench or handwheel regularly furnished with the post. The higher torque requirements shall apply in cases where the post is intended for use with both wrench and handwheel.

**Table 13.1**  
**Torque requirements**

Wrench length		Handwheel diameter		Minimum torque	
inches	(mm)	inches	(mm)	foot-pounds	(N·m)
12	(305)	—	—	260	(352)
14	(356)	—	—	325	(440)
16	(407)	14	(356)	450	(610)
18	(457)	16	(407)	640	(867)
20	(508)	18	(457)	900	(1220)

13.3 The indicator post is to be bolted in place in accordance with the manufacturer's installation instructions.

- a) A wall-type indicator is to be supported primarily by its wall flange.

b) An underground-type indicator is to be bolted to a rigidly supported flange representing the flange furnished for this purpose as part of an inside screw valve. The underground-type post may also be supported at the intended ground or "bury" line.

c) An above ground type is to be tested in two orientations, perpendicular to the wall which represents a vertical installation and perpendicular to the floor which represents a horizontal installation. The test specimen shall be bolted to a rigidly supported flange representing the flange furnished for this purpose as part of an inside screw valve.

13.4 The extension-rod coupling or other means normally engaging the nut of the valve to be operated by the indicator post is to be secured against turning.

13.5 The turning force is to be applied using a torque wrench strapped or otherwise secured to the regular handwheel or wrench furnished with the post.

13.6 The turning force is to be applied both in the clockwise and counterclockwise directions and is to be maintained at the value designated in Table 13.1 for not less than 1 minute for each application of the force.

#### **14 Elastomeric Parts (Except Gaskets) Test**

14.1 An elastomeric part used to provide a seal shall have the following properties when tested as specified in the Standard for Gaskets and Seals, UL 157:

a) For silicone rubber (having poly-organo-siloxane as its constituent characteristic), a minimum tensile strength of 500 psi (3.4 MPa) and a minimum ultimate elongation of 100 percent.

b) For natural rubber and synthetic rubber other than silicone rubber, a minimum tensile strength of 1500 psi (10.3 MPa) and minimum ultimate elongation of 150 percent; or a minimum tensile strength of 2200 psi (15.2 MPa) and a minimum ultimate elongation of 100 percent.

c) Those properties relating to maximum tensile set; minimum tensile strength and elongation after oven aging; and hardness after oven aging, all as specified in UL 157. The maximum service temperature used to determine the oven time and temperature for oven aging is considered to be 60°C (140°F).

14.2 The Standard for Gaskets and Seals, UL 157, provides for the testing of either finished elastomeric parts or sheet or slab material. Sheet or slab material is to be tested when the elastomeric parts are O-rings having diameters of less than 1 inch (25.4 mm). The material tested is to be the same as that used in the product, regardless of whether finished elastomeric parts or sheet or slab material is tested.

## 15 Polymeric Parts Tests

### 15.1 Air oven aging test

15.1.1 Following air-oven aging for 180 days at 121°C (250°F), there shall be no warping, creeping, or other signs of deterioration of a polymeric component that precludes the intended operation of the indicator post. There shall be no cracking of any polymeric component. A valve with aged polymeric components shall demonstrate intended performance when subjected to the Strength of Part Test, Section 13, and the 1000 Cycle Operation Test, 15.3.

15.1.2 A complete assembly, including the polymeric parts, and sample polymeric components to be aged are to be supported in a full-draft, circulating-air oven that has been preheated at full draft, to  $121 \pm 1^\circ\text{C}$  ( $250 \pm 1.8^\circ\text{F}$ ). The manner of support is to be such that the samples are prevented from touching one another or the sides of the oven. The samples are to be aged for 180 days at full draft and then allowed to cool in air at  $23 \pm 2^\circ\text{C}$  ( $73.4 \pm 3.6^\circ\text{F}$ ) for at least 24 hours before conducting any test or dimensional check. As used in this test, the term "full draft" refers to the air flow over the samples in the oven with the air inlet and outlets fully open. The oven used for accelerated aging is to be Type IIA as specified in the Standard Specification for Gravity-Convection and Forced-Ventilation Ovens, ASTM E145.

ULNORM.COM : Click to view the full PDF of UL 789 2018

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 789 2018